

Date: 09 September 2025

The Executive Director: Water Services Department

Harry Gwala District Municipality

40 Main Street

Ixopo

3276

Attention: Basetsana Khathalib and Bheki Nene

AUGUST 2025 TREATED WATER (FINAL) RESULTS

Please find August 2025 Treated Water (Final) results tabulated below for samples received during August 2025. Determinands marked with an asterix are unaccredited and are not included in uMngeni-uThukela Water's schedule of accreditation.

Please contact us immediately should you have any queries.

Yours' Sincerely

Mr M Sewcharan

Client Services Manager

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Sample Date	Sample Number	Sampling Point	Description	Determinand	Result	UOM	Unit
01-Aug-25	2443537	TIB002	Ibisi Final	Al (AE)	291	±7.6%	µg Al/L
01-Aug-25	2443532	TIB002	Ibisi Final	Batch No.*	20250201	-	-
01-Aug-25	2443532	TIB002	Ibisi Final	Cl ₂ (F) OS*	1.17	-	mg Cl ₂ /L
01-Aug-25	2443532	TIB002	Ibisi Final	Cl ₂ (T) OS*	1.30	-	mg Cl ₂ /L
01-Aug-25	2443533	TIB002	Ibisi Final	Coliforms*	>201	±15%	MPN/100mL
01-Aug-25	2443533	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
01-Aug-25	2443532	TIB002	Ibisi Final	Coll Time OS*	06:12	-	-
01-Aug-25	2443535	TIB002	Ibisi Final	Colour	<1.00	±6.5%	mg Pt-Co/L
01-Aug-25	2443536	TIB002	Ibisi Final	Conductivity	10.6	±1.5%	mS/m
01-Aug-25	2443533	TIB002	Ibisi Final	E.coli*	>201	±14%	MPN/100mL
01-Aug-25	2443537	TIB002	Ibisi Final	Fe (AE)	0.20	±5.4%	mg Fe/L
01-Aug-25	2443533	TIB002	Ibisi Final	HPC 37*	56	±21%	cfu/mL
01-Aug-25	2443535	TIB002	Ibisi Final	Odour*	Nil	-	-
01-Aug-25	2443532	TIB002	Ibisi Final	pH OS*	7.10	-	-
01-Aug-25	2443532	TIB002	Ibisi Final	Temperature OS*	12.5	-	°C
01-Aug-25	2443535	TIB002	Ibisi Final	Turbidity	3.4	±6.1%	NTU
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Al (AE)	196	±7.6%	µg Al/L
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	As (AE)*	<5.00	±7.5%	µg As/L
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	B (AE)	<25.0	±6.6%	µg B/L
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Ba (AE)	13.6	±6.9%	µg Ba/L
01-Aug-25	2443538	TIB003	Ibisi Police Station Reticulation	Batch No.*	20250201	-	-
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Cd (AE)	<1.00	±6%	µg Cd/L
01-Aug-25	2443547	TIB003	Ibisi Police Station Reticulation	CHBr ₃	<10	±6.4%	µg/L
01-Aug-25	2443547	TIB003	Ibisi Police Station Reticulation	CHCl ₂ Br	<10	±5.7%	µg/L
01-Aug-25	2443547	TIB003	Ibisi Police Station Reticulation	CHCl ₃	<10	±6%	µg/L
01-Aug-25	2443547	TIB003	Ibisi Police Station Reticulation	CHClBr ₂	<10	±5.3%	µg/L
01-Aug-25	2443545	TIB003	Ibisi Police Station Reticulation	Cl*	6.03	±1.8%	mg Cl/L
01-Aug-25	2443538	TIB003	Ibisi Police Station Reticulation	Cl ₂ (F) OS*	0.53	-	mg Cl ₂ /L
01-Aug-25	2443538	TIB003	Ibisi Police Station Reticulation	Cl ₂ (T) OS*	0.67	-	mg Cl ₂ /L
01-Aug-25	2443542	TIB003	Ibisi Police Station Reticulation	CN (T)	<25.0	±8.6%	µg CN/L
01-Aug-25	2443539	TIB003	Ibisi Police Station Reticulation	Coliforms*	0	±15%	MPN/100mL
01-Aug-25	2443539	TIB003	Ibisi Police Station Reticulation	Coliphages*	0	±8%	PFU/10ml
01-Aug-25	2443538	TIB003	Ibisi Police Station Reticulation	Coll Time OS*	06:08	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

01-Aug-25	2443545	TIB003	Ibisi Police Station Reticulation	Combined NO3 + NO2 ratio*	0.15	-	-
01-Aug-25	2443547	TIB003	Ibisi Police Station Reticulation	Combined THM Ratio*	<0.40	-	-
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Cr (T)*	<5.00	±5.3%	µg Cr/L
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Cu (AE)	<0.05	±4.1%	mg Cu/L
01-Aug-25	2443539	TIB003	Ibisi Police Station Reticulation	E.coli*	0	±14%	MPN/100mL
01-Aug-25	2443545	TIB003	Ibisi Police Station Reticulation	F	151	±5.3%	µg F/L
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Fe (AE)	0.08	±5.4%	mg Fe/L
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Hg (AE)*	<1.00	±6.5%	µg Hg/L
01-Aug-25	2443539	TIB003	Ibisi Police Station Reticulation	HPC 37*	0	±21%	cfu/mL
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Mn (AE)	<0.01	±6.2%	mg Mn/L
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Na (AE)	<5.00	±7.5%	mg Na/L
01-Aug-25	2443545	TIB003	Ibisi Police Station Reticulation	NH3*	0.21	±5.5%	mg N/L
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Ni (AE)	<10.0	±5.9%	µg Ni/L
01-Aug-25	2443545	TIB003	Ibisi Police Station Reticulation	NO2*	<0.10	±2.4%	mg N/L
01-Aug-25	2443545	TIB003	Ibisi Police Station Reticulation	NO3*	0.47	±2.9%	mg N/L
01-Aug-25	2443543	TIB003	Ibisi Police Station Reticulation	Odour*	Nil	-	-
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Pb (AE)	<4.00	±6.7%	µg Pb/L
01-Aug-25	2443538	TIB003	Ibisi Police Station Reticulation	pH OS*	7.60	-	-
01-Aug-25	2443544	TIB003	Ibisi Police Station Reticulation	Phenols*	<10.0	-	µg/L
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Sb (AE)*	<5.00	±7%	µg Sb/L
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Se (AE)*	<5.00	±7.7%	µg Se/L
01-Aug-25	2443545	TIB003	Ibisi Police Station Reticulation	SO4*	1.49	±1.8%	mg SO4/L
01-Aug-25	2443543	TIB003	Ibisi Police Station Reticulation	SS	<10.0	±3.7%	mg /L
01-Aug-25	2443543	TIB003	Ibisi Police Station Reticulation	TDS	95.00	±2.5%	mg /L
01-Aug-25	2443538	TIB003	Ibisi Police Station Reticulation	Temperature OS*	13.9	-	°C
01-Aug-25	2443543	TIB003	Ibisi Police Station Reticulation	TOC	<1.00	±5%	mg C/L
01-Aug-25	2443543	TIB003	Ibisi Police Station Reticulation	Turbidity	2.9	±6.1%	NTU
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	U (AE)*	<10.0	±7.6%	µg U/L
01-Aug-25	2443546	TIB003	Ibisi Police Station Reticulation	Zn (AE)	<0.03	±7.2%	mg Zn/L
01-Aug-25	2443552	TRT002	Rietvlei Final	Batch No.*	20250201	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

01-Aug-25	2443552	TRT002	Rietvlei Final	Cl ₂ (F) OS*	1.34	-	mg Cl ₂ /L
01-Aug-25	2443552	TRT002	Rietvlei Final	Cl ₂ (T) OS*	1.42	-	mg Cl ₂ /L
01-Aug-25	2443553	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
01-Aug-25	2443552	TRT002	Rietvlei Final	Coll Time OS*	05:10	-	-
01-Aug-25	2443556	TRT002	Rietvlei Final	Conductivity	19.5	±1.5%	mS/m
01-Aug-25	2443553	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
01-Aug-25	2443553	TRT002	Rietvlei Final	HPC 37*	28	±21%	cfu/mL
01-Aug-25	2443552	TRT002	Rietvlei Final	pH OS*	7.80	-	-
01-Aug-25	2443552	TRT002	Rietvlei Final	Temperature OS*	11.6	-	°C
01-Aug-25	2443555	TRT002	Rietvlei Final	Turbidity	2.1	±6.1%	NTU
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Al (AE)	165	±7.6%	µg Al/L
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	As (AE)*	<5.00	±7.5%	µg As/L
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	B (AE)	<25.0	±6.6%	µg B/L
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Ba (AE)	13.9	±6.9%	µg Ba/L
01-Aug-25	2443557	TRT004	Rietvlei Hospital Reticulation	Batch No.*	20250201	-	-
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Cd (AE)	<1.00	±6%	µg Cd/L
01-Aug-25	2443566	TRT004	Rietvlei Hospital Reticulation	CHBr ₃	<10	±6.4%	µg/L
01-Aug-25	2443566	TRT004	Rietvlei Hospital Reticulation	CHCl ₂ Br	<10	±5.7%	µg/L
01-Aug-25	2443566	TRT004	Rietvlei Hospital Reticulation	CHCl ₃	<10	±6%	µg/L
01-Aug-25	2443566	TRT004	Rietvlei Hospital Reticulation	CHClBr ₂	<10	±5.3%	µg/L
01-Aug-25	2443564	TRT004	Rietvlei Hospital Reticulation	Cl*	18.7	±1.8%	mg Cl/L
01-Aug-25	2443557	TRT004	Rietvlei Hospital Reticulation	Cl ₂ (F) OS*	0.92	-	mg Cl ₂ /L
01-Aug-25	2443557	TRT004	Rietvlei Hospital Reticulation	Cl ₂ (T) OS*	1.04	-	mg Cl ₂ /L
01-Aug-25	2443561	TRT004	Rietvlei Hospital Reticulation	CN (T)	<25.0	±8.6%	µg CN/L
01-Aug-25	2443558	TRT004	Rietvlei Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
01-Aug-25	2443558	TRT004	Rietvlei Hospital Reticulation	Coliphages*	0	±8%	PFU/10ml
01-Aug-25	2443557	TRT004	Rietvlei Hospital Reticulation	Coll Time OS*	05:09	-	-
01-Aug-25	2443564	TRT004	Rietvlei Hospital Reticulation	Combined NO ₃ + NO ₂ ratio*	0.19	-	-
01-Aug-25	2443566	TRT004	Rietvlei Hospital Reticulation	Combined THM Ratio*	<0.40	-	-
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Cr (T)*	<5.00	±5.3%	µg Cr/L
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Cu (AE)	<0.05	±4.1%	mg Cu/L
01-Aug-25	2443558	TRT004	Rietvlei Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
01-Aug-25	2443564	TRT004	Rietvlei Hospital Reticulation	F	168	±5.3%	µg F/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Fe (AE)	0.15	±5.4%	mg Fe/L
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Hg (AE)*	<1.00	±6.5%	µg Hg/L
01-Aug-25	2443558	TRT004	Rietvlei Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Mn (AE)	<0.01	±6.2%	mg Mn/L
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Na (AE)	19.0	±7.5%	mg Na/L
01-Aug-25	2443564	TRT004	Rietvlei Hospital Reticulation	NH3*	<0.10	±5.5%	mg N/L
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Ni (AE)	<10.0	±5.9%	µg Ni/L
01-Aug-25	2443564	TRT004	Rietvlei Hospital Reticulation	NO2*	<0.10	±2.4%	mg N/L
01-Aug-25	2443564	TRT004	Rietvlei Hospital Reticulation	NO3*	0.87	±2.9%	mg N/L
01-Aug-25	2443562	TRT004	Rietvlei Hospital Reticulation	Odour*	Nil	-	-
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Pb (AE)	<4.00	±6.7%	µg Pb/L
01-Aug-25	2443557	TRT004	Rietvlei Hospital Reticulation	pH OS*	7.80	-	-
01-Aug-25	2443563	TRT004	Rietvlei Hospital Reticulation	Phenols*	<10.0	-	µg/L
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Sb (AE)*	<5.00	±7%	µg Sb/L
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Se (AE)*	<5.00	±7.7%	µg Se/L
01-Aug-25	2443564	TRT004	Rietvlei Hospital Reticulation	SO4*	2.40	±1.8%	mg SO4/L
01-Aug-25	2443562	TRT004	Rietvlei Hospital Reticulation	SS	11.2	±3.7%	mg /L
01-Aug-25	2443562	TRT004	Rietvlei Hospital Reticulation	TDS	139.00	±2.5%	mg /L
01-Aug-25	2443557	TRT004	Rietvlei Hospital Reticulation	Temperature OS*	11.5	-	°C
01-Aug-25	2443562	TRT004	Rietvlei Hospital Reticulation	TOC	<1.00	±5%	mg C/L
01-Aug-25	2443562	TRT004	Rietvlei Hospital Reticulation	Turbidity	5.2	±6.1%	NTU
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	U (AE)*	<10.0	±7.6%	µg U/L
01-Aug-25	2443565	TRT004	Rietvlei Hospital Reticulation	Zn (AE)	<0.03	±7.2%	mg Zn/L
04-Aug-25	2445986	TFR002	Franklin Final	Al (AE)	<25.0	±7.6%	µg Al/L
04-Aug-25	2445981	TFR002	Franklin Final	Batch No.*	20250201	-	-
04-Aug-25	2445981	TFR002	Franklin Final	Cl2 (F) OS*	2.07	-	mg Cl2/L
04-Aug-25	2445981	TFR002	Franklin Final	Cl2 (T) OS*	2.18	-	mg Cl2/L
04-Aug-25	2445982	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
04-Aug-25	2445982	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
04-Aug-25	2445981	TFR002	Franklin Final	Coll Time OS*	09:30	-	-
04-Aug-25	2445985	TFR002	Franklin Final	Conductivity	13.5	±1.5%	mS/m
04-Aug-25	2445982	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
04-Aug-25	2445982	TFR002	Franklin Final	HPC 37*	0	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

04-Aug-25	2445981	TFR002	Franklin Final	pH OS*	7.30	-	-
04-Aug-25	2445981	TFR002	Franklin Final	Temperature OS*	13.1	-	°C
04-Aug-25	2445984	TFR002	Franklin Final	Turbidity	0.3	±6.1%	NTU
04-Aug-25	2445997	TKK002	Kokstad Final	Al (AE)	269	±7.6%	µg Al/L
04-Aug-25	2445992	TKK002	Kokstad Final	Batch No.*	20250201	-	-
04-Aug-25	2445992	TKK002	Kokstad Final	Cl2 (F) OS*	1.88	-	mg Cl2/L
04-Aug-25	2445992	TKK002	Kokstad Final	Cl2 (T) OS*	2.01	-	mg Cl2/L
04-Aug-25	2445993	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
04-Aug-25	2445993	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
04-Aug-25	2445992	TKK002	Kokstad Final	Coll Time OS*	08:50	-	-
04-Aug-25	2445996	TKK002	Kokstad Final	Conductivity	13.2	±1.5%	mS/m
04-Aug-25	2445993	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
04-Aug-25	2445993	TKK002	Kokstad Final	HPC 37*	2	±21%	cfu/mL
04-Aug-25	2445992	TKK002	Kokstad Final	pH OS*	7.30	-	-
04-Aug-25	2445992	TKK002	Kokstad Final	Temperature OS*	14.1	-	°C
04-Aug-25	2445995	TKK002	Kokstad Final	Turbidity	0.9	±6.1%	NTU
04-Aug-25	2446017	TNJU002	KwaNjunga Final	Batch No.*	20250201	-	-
04-Aug-25	2446017	TNJU002	KwaNjunga Final	Cl2 (F) OS*	0.71	-	mg Cl2/L
04-Aug-25	2446017	TNJU002	KwaNjunga Final	Cl2 (T) OS*	0.79	-	mg Cl2/L
04-Aug-25	2446018	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
04-Aug-25	2446017	TNJU002	KwaNjunga Final	Coll Time OS*	10:06	-	-
04-Aug-25	2446021	TNJU002	KwaNjunga Final	Conductivity	17.9	±1.5%	mS/m
04-Aug-25	2446018	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
04-Aug-25	2446018	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	cfu/mL
04-Aug-25	2446017	TNJU002	KwaNjunga Final	pH OS*	7.20	-	-
04-Aug-25	2446017	TNJU002	KwaNjunga Final	Temperature OS*	12.4	-	°C
04-Aug-25	2446020	TNJU002	KwaNjunga Final	Turbidity	0.5	±6.1%	NTU
05-Aug-25	2446531	TJO001	Jolivet RRT frn Vulamehlo	Batch No.*	20250401	-	-
05-Aug-25	2446531	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (F) OS*	0.53	-	mg Cl2/L
05-Aug-25	2446531	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (T) OS*	0.64	-	mg Cl2/L
05-Aug-25	2446532	TJO001	Jolivet RRT frn Vulamehlo	Coliforms*	0	±15%	MPN/100mL
05-Aug-25	2446531	TJO001	Jolivet RRT frn Vulamehlo	Coll Time OS*	08:45	-	-
05-Aug-25	2446534	TJO001	Jolivet RRT frn Vulamehlo	Colour	1.10	±6.5%	mg Pt-Co/L
05-Aug-25	2446535	TJO001	Jolivet RRT frn Vulamehlo	Conductivity	14.4	±1.5%	mS/m
05-Aug-25	2446532	TJO001	Jolivet RRT frn Vulamehlo	E.coli*	0	±14%	MPN/100mL
05-Aug-25	2446532	TJO001	Jolivet RRT frn Vulamehlo	HPC 37*	0	±21%	cfu/mL
05-Aug-25	2446534	TJO001	Jolivet RRT frn Vulamehlo	Odour*	Nil	-	-
05-Aug-25	2446531	TJO001	Jolivet RRT frn Vulamehlo	pH OS*	7.60	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

05-Aug-25	2446531	TJO001	Jolivet RRT frn Vulamehlo	Temperature OS*	15.2	-	°C
05-Aug-25	2446534	TJO001	Jolivet RRT frn Vulamehlo	Turbidity	1.1	±6.1%	NTU
05-Aug-25	2446579	TQU002	Mnqumeni Final	Batch No.*	20250201	-	-
05-Aug-25	2446579	TQU002	Mnqumeni Final	Cl2 (F) OS*	1.94	-	mg Cl2/L
05-Aug-25	2446579	TQU002	Mnqumeni Final	Cl2 (T) OS*	2.04	-	mg Cl2/L
05-Aug-25	2446580	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
05-Aug-25	2446579	TQU002	Mnqumeni Final	Coll Time OS*	7:09	-	-
05-Aug-25	2446583	TQU002	Mnqumeni Final	Conductivity	14.8	±1.5%	mS/m
05-Aug-25	2446580	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
05-Aug-25	2446580	TQU002	Mnqumeni Final	HPC 37*	0	±21%	cfu/mL
05-Aug-25	2446579	TQU002	Mnqumeni Final	pH OS*	7.00	-	-
05-Aug-25	2446579	TQU002	Mnqumeni Final	Temperature OS*	11.8	-	°C
05-Aug-25	2446582	TQU002	Mnqumeni Final	Turbidity	0.7	±6.1%	NTU
06-Aug-25	2447165	TBU002	Bulwer Final	Batch No.*	20250201	-	-
06-Aug-25	2447165	TBU002	Bulwer Final	Cl2 (F) OS*	0.87	-	mg Cl2/L
06-Aug-25	2447165	TBU002	Bulwer Final	Cl2 (T) OS*	0.99	-	mg Cl2/L
06-Aug-25	2447166	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
06-Aug-25	2447165	TBU002	Bulwer Final	Coll Time OS*	10:00	-	-
06-Aug-25	2447169	TBU002	Bulwer Final	Conductivity	6.10	±1.5%	mS/m
06-Aug-25	2447166	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
06-Aug-25	2447166	TBU002	Bulwer Final	HPC 37*	3	±21%	cfu/mL
06-Aug-25	2447165	TBU002	Bulwer Final	pH OS*	7.40	-	-
06-Aug-25	2447165	TBU002	Bulwer Final	Temperature OS*	14.9	-	°C
06-Aug-25	2447168	TBU002	Bulwer Final	Turbidity	3.1	±6.1%	NTU
06-Aug-25	2447180	TCR002	Creighton Final	Al (AE)	238	±7.6%	µg Al/L
06-Aug-25	2447175	TCR002	Creighton Final	Batch No.*	20250201	-	-
06-Aug-25	2447175	TCR002	Creighton Final	Cl2 (F) OS*	1.09	-	mg Cl2/L
06-Aug-25	2447175	TCR002	Creighton Final	Cl2 (T) OS*	1.19	-	mg Cl2/L
06-Aug-25	2447176	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
06-Aug-25	2447175	TCR002	Creighton Final	Coll Time OS*	07:40	-	-
06-Aug-25	2447179	TCR002	Creighton Final	Conductivity	9.38	±1.5%	mS/m
06-Aug-25	2447176	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
06-Aug-25	2447176	TCR002	Creighton Final	HPC 37*	0	±21%	cfu/mL
06-Aug-25	2447175	TCR002	Creighton Final	pH OS*	7.20	-	-
06-Aug-25	2447175	TCR002	Creighton Final	Temperature OS*	10.4	-	°C
06-Aug-25	2447178	TCR002	Creighton Final	Turbidity	0.3	±6.1%	NTU
06-Aug-25	2447185	THL002	Hlanganani Final	Batch No.*	20250201	-	-
06-Aug-25	2447185	THL002	Hlanganani Final	Cl2 (F) OS*	0.47	-	mg Cl2/L
06-Aug-25	2447185	THL002	Hlanganani Final	Cl2 (T) OS*	0.54	-	mg Cl2/L
06-Aug-25	2447186	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
06-Aug-25	2447185	THL002	Hlanganani Final	Coll Time OS*	11:00	-	-
06-Aug-25	2447189	THL002	Hlanganani Final	Conductivity	10.4	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

06-Aug-25	2447186	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
06-Aug-25	2447186	THL002	Hlanganani Final	HPC 37*	0	±21%	cfu/mL
06-Aug-25	2447185	THL002	Hlanganani Final	pH OS*	7.30	-	-
06-Aug-25	2447185	THL002	Hlanganani Final	Temperature OS*	13.7	-	°C
06-Aug-25	2447188	THL002	Hlanganani Final	Turbidity	<0.2	±6.1%	NTU
06-Aug-25	2447208	TMQA002	Mqatsheni Final	Batch No.*	20250201	-	-
06-Aug-25	2447208	TMQA002	Mqatsheni Final	Cl2 (F) OS*	1.60	-	mg Cl2/L
06-Aug-25	2447208	TMQA002	Mqatsheni Final	Cl2 (T) OS*	1.72	-	mg Cl2/L
06-Aug-25	2447209	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
06-Aug-25	2447208	TMQA002	Mqatsheni Final	Coll Time OS*	06:59	-	-
06-Aug-25	2447212	TMQA002	Mqatsheni Final	Conductivity	26.0	±1.5%	mS/m
06-Aug-25	2447209	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
06-Aug-25	2447209	TMQA002	Mqatsheni Final	HPC 37*	1	±21%	cfu/mL
06-Aug-25	2447208	TMQA002	Mqatsheni Final	pH OS*	9.00	-	-
06-Aug-25	2447208	TMQA002	Mqatsheni Final	Temperature OS*	10.0	-	°C
06-Aug-25	2447211	TMQA002	Mqatsheni Final	Turbidity	0.3	±6.1%	NTU
06-Aug-25	2447229	TRV002	Riverside Final	Batch No.*	20250201	-	-
06-Aug-25	2447229	TRV002	Riverside Final	Cl2 (F) OS*	1.24	-	mg Cl2/L
06-Aug-25	2447229	TRV002	Riverside Final	Cl2 (T) OS*	1.30	-	mg Cl2/L
06-Aug-25	2447230	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
06-Aug-25	2447229	TRV002	Riverside Final	Coll Time OS*	08:13	-	-
06-Aug-25	2447233	TRV002	Riverside Final	Conductivity	13.2	±1.5%	mS/m
06-Aug-25	2447230	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
06-Aug-25	2447234	TRV002	Riverside Final	Fe (AE)	0.13	±5.4%	mg Fe/L
06-Aug-25	2447230	TRV002	Riverside Final	HPC 37*	0	±21%	cfu/mL
06-Aug-25	2447229	TRV002	Riverside Final	pH OS*	7.30	-	-
06-Aug-25	2447229	TRV002	Riverside Final	Temperature OS*	10.0	-	°C
06-Aug-25	2447232	TRV002	Riverside Final	Turbidity	2.3	±6.1%	NTU
06-Aug-25	2447240	TST002	St Appollinaris Final	Batch No.*	20250201	-	-
06-Aug-25	2447240	TST002	St Appollinaris Final	Cl2 (F) OS*	0.44	-	mg Cl2/L
06-Aug-25	2447240	TST002	St Appollinaris Final	Cl2 (T) OS*	0.56	-	mg Cl2/L
06-Aug-25	2447241	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
06-Aug-25	2447240	TST002	St Appollinaris Final	Coll Time OS*	09:18	-	-
06-Aug-25	2447244	TST002	St Appollinaris Final	Conductivity	10.3	±1.5%	mS/m
06-Aug-25	2447241	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
06-Aug-25	2447241	TST002	St Appollinaris Final	HPC 37*	0	±21%	cfu/mL
06-Aug-25	2447240	TST002	St Appollinaris Final	pH OS*	7.30	-	-
06-Aug-25	2447240	TST002	St Appollinaris Final	Temperature OS*	12.2	-	°C
06-Aug-25	2447243	TST002	St Appollinaris Final	Turbidity	1.5	±6.1%	NTU
06-Aug-25	2447255	TUN002	Underberg Final	Al (AE)	28.3	±7.6%	µg Al/L
06-Aug-25	2447250	TUN002	Underberg Final	Batch No.*	20250201	-	-
06-Aug-25	2447250	TUN002	Underberg Final	Cl2 (F) OS*	0.40	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

06-Aug-25	2447250	TUN002	Underberg Final	Cl2 (T) OS*	0.48	-	mg Cl2/L
06-Aug-25	2447251	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
06-Aug-25	2447250	TUN002	Underberg Final	Coll Time OS*	07:56	-	-
06-Aug-25	2447254	TUN002	Underberg Final	Conductivity	7.63	±1.5%	mS/m
06-Aug-25	2447251	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
06-Aug-25	2447251	TUN002	Underberg Final	HPC 37*	2	±21%	cfu/mL
06-Aug-25	2447250	TUN002	Underberg Final	pH OS*	7.70	-	-
06-Aug-25	2447250	TUN002	Underberg Final	Temperature OS*	8.7	-	°C
06-Aug-25	2447253	TUN002	Underberg Final	Turbidity	0.7	±6.1%	NTU
07-Aug-25	2447223	TMZ002	Umzimkhulu Final	Al (AE)	164	±7.6%	µg Al/L
07-Aug-25	2447218	TMZ002	Umzimkhulu Final	Batch No.*	20250201	-	-
07-Aug-25	2447218	TMZ002	Umzimkhulu Final	Cl2 (F) OS*	1.24	-	mg Cl2/L
07-Aug-25	2447218	TMZ002	Umzimkhulu Final	Cl2 (T) OS*	1.32	-	mg Cl2/L
07-Aug-25	2447219	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
07-Aug-25	2447219	TMZ002	Umzimkhulu Final	Coliphages*	1	±8%	PFU/10ml
07-Aug-25	2447218	TMZ002	Umzimkhulu Final	Coll Time OS*	6:36	-	-
07-Aug-25	2447221	TMZ002	Umzimkhulu Final	Colour	1.40	±6.5%	mg Pt-Co/L
07-Aug-25	2447222	TMZ002	Umzimkhulu Final	Conductivity	13.0	±1.5%	mS/m
07-Aug-25	2447219	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
07-Aug-25	2447219	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	cfu/mL
07-Aug-25	2447221	TMZ002	Umzimkhulu Final	Odour*	Mild Chlorinous	-	-
07-Aug-25	2447218	TMZ002	Umzimkhulu Final	pH OS*	7.20	-	-
07-Aug-25	2447221	TMZ002	Umzimkhulu Final	Taste*	Nil	-	-
07-Aug-25	2447218	TMZ002	Umzimkhulu Final	Temperature OS*	11.9	-	°C
07-Aug-25	2447221	TMZ002	Umzimkhulu Final	Turbidity	0.6	±6.1%	NTU
07-Aug-25	2447827	TNO002	Nokweja Final	Al (AE)	252	±7.6%	µg Al/L
07-Aug-25	2447822	TNO002	Nokweja Final	Batch No.*	20250201	-	-
07-Aug-25	2447822	TNO002	Nokweja Final	Cl2 (F) OS*	2.50	-	mg Cl2/L
07-Aug-25	2447822	TNO002	Nokweja Final	Cl2 (T) OS*	3.05	-	mg Cl2/L
07-Aug-25	2447823	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
07-Aug-25	2447823	TNO002	Nokweja Final	Coliphages*	8	±8%	PFU/10ml
07-Aug-25	2447822	TNO002	Nokweja Final	Coll Time OS*	7:37	-	-
07-Aug-25	2447826	TNO002	Nokweja Final	Conductivity	13.8	±1.5%	mS/m
07-Aug-25	2447823	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
07-Aug-25	2447823	TNO002	Nokweja Final	HPC 37*	10	±21%	cfu/mL
07-Aug-25	2447822	TNO002	Nokweja Final	pH OS*	7.00	-	-
07-Aug-25	2447822	TNO002	Nokweja Final	Temperature OS*	12.6	-	°C
07-Aug-25	2447825	TNO002	Nokweja Final	Turbidity	2.8	±6.1%	NTU
07-Aug-25	2446594	TSQ002	Esiqanduleni Final	Al (AE)	107	±7.6%	µg Al/L
07-Aug-25	2446589	TSQ002	Esiqanduleni Final	Batch No.*	20250201	-	-
07-Aug-25	2446589	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	0.86	-	mg Cl2/L
07-Aug-25	2446589	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	0.99	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

07-Aug-25	2446590	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
07-Aug-25	2446589	TSQ002	Esiqanduleni Final	Coll Time OS*	6:20	-	-
07-Aug-25	2446593	TSQ002	Esiqanduleni Final	Conductivity	20.7	±1.5%	mS/m
07-Aug-25	2446590	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
07-Aug-25	2446590	TSQ002	Esiqanduleni Final	HPC 37*	2	±21%	cfu/mL
07-Aug-25	2446589	TSQ002	Esiqanduleni Final	pH OS*	7.40	-	-
07-Aug-25	2446589	TSQ002	Esiqanduleni Final	Temperature OS*	10.2	-	°C
07-Aug-25	2446592	TSQ002	Esiqanduleni Final	Turbidity	1.3	±6.1%	NTU
07-Aug-25	2447862	TWA002	Washbank Final	Al (AE)	326	±7.6%	µg Al/L
07-Aug-25	2447857	TWA002	Washbank Final	Batch No.*	20250201	-	-
07-Aug-25	2447857	TWA002	Washbank Final	Cl2 (F) OS*	0.51	-	mg Cl2/L
07-Aug-25	2447857	TWA002	Washbank Final	Cl2 (T) OS*	0.63	-	mg Cl2/L
07-Aug-25	2447858	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
07-Aug-25	2447857	TWA002	Washbank Final	Coll Time OS*	5:36	-	-
07-Aug-25	2447861	TWA002	Washbank Final	Conductivity	7.81	±1.5%	mS/m
07-Aug-25	2447858	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
07-Aug-25	2447858	TWA002	Washbank Final	HPC 37*	1	±21%	cfu/mL
07-Aug-25	2447857	TWA002	Washbank Final	pH OS*	7.10	-	-
07-Aug-25	2447857	TWA002	Washbank Final	Temperature OS*	11.2	-	°C
07-Aug-25	2447860	TWA002	Washbank Final	Turbidity	2.5	±6.1%	NTU
08-Aug-25	2448124	TIB002	Ibisi Final	Al (AE)	351	±7.6%	µg Al/L
08-Aug-25	2448119	TIB002	Ibisi Final	Batch No.*	20250201	-	-
08-Aug-25	2448119	TIB002	Ibisi Final	Cl2 (F) OS*	1.01	-	mg Cl2/L
08-Aug-25	2448119	TIB002	Ibisi Final	Cl2 (T) OS*	1.10	-	mg Cl2/L
08-Aug-25	2448120	TIB002	Ibisi Final	Coliforms*	>201	±15%	MPN/100mL
08-Aug-25	2448120	TIB002	Ibisi Final	Coliphages*	1	±8%	PFU/10ml
08-Aug-25	2448119	TIB002	Ibisi Final	Coll Time OS*	07:40	-	-
08-Aug-25	2448123	TIB002	Ibisi Final	Conductivity	10.7	±1.5%	mS/m
08-Aug-25	2448120	TIB002	Ibisi Final	E.coli*	83	±14%	MPN/100mL
08-Aug-25	2448120	TIB002	Ibisi Final	HPC 37*	95	±21%	cfu/mL
08-Aug-25	2448119	TIB002	Ibisi Final	pH OS*	7.50	-	-
08-Aug-25	2448119	TIB002	Ibisi Final	Temperature OS*	12.2	-	°C
08-Aug-25	2448122	TIB002	Ibisi Final	Turbidity	4.1	±6.1%	NTU
11-Aug-25	2450307	TFR002	Franklin Final	Al (AE)	187	±7.6%	µg Al/L
11-Aug-25	2450302	TFR002	Franklin Final	Batch No.*	20250201	-	-
11-Aug-25	2450302	TFR002	Franklin Final	Cl2 (F) OS*	1.36	-	mg Cl2/L
11-Aug-25	2450302	TFR002	Franklin Final	Cl2 (T) OS*	1.45	-	mg Cl2/L
11-Aug-25	2450303	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
11-Aug-25	2450303	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
11-Aug-25	2450302	TFR002	Franklin Final	Coll Time OS*	8:18	-	-
11-Aug-25	2450305	TFR002	Franklin Final	Colour	<1.00	±6.5%	mg Pt-Co/L
11-Aug-25	2450306	TFR002	Franklin Final	Conductivity	14.9	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Aug-25	2450303	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
11-Aug-25	2450307	TFR002	Franklin Final	Fe (AE)	0.03	±5.4%	mg Fe/L
11-Aug-25	2450303	TFR002	Franklin Final	HPC 37*	0	±21%	cfu/mL
11-Aug-25	2450307	TFR002	Franklin Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
11-Aug-25	2450302	TFR002	Franklin Final	pH OS*	7.40	-	-
11-Aug-25	2450302	TFR002	Franklin Final	Temperature OS*	8.2	-	°C
11-Aug-25	2450305	TFR002	Franklin Final	Turbidity	0.9	±6.1%	NTU
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Al (AE)	179	±7.6%	µg Al/L
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	As (AE)*	<5.00	±7.5%	µg As/L
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	B (AE)	<25.0	±6.6%	µg B/L
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Ba (AE)	15.9	±6.9%	µg Ba/L
11-Aug-25	2450308	TFR003	Franklin Police Station Retic	Batch No.*	20250201	-	-
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Cd (AE)	<1.00	±6%	µg Cd/L
11-Aug-25	2450317	TFR003	Franklin Police Station Retic	CHBr3	<10	±6.4%	µg/L
11-Aug-25	2450317	TFR003	Franklin Police Station Retic	CHCl2Br	<10	±5.7%	µg/L
11-Aug-25	2450317	TFR003	Franklin Police Station Retic	CHCl3	14.8	±6%	µg/L
11-Aug-25	2450317	TFR003	Franklin Police Station Retic	CHClBr2	<10	±5.3%	µg/L
11-Aug-25	2450315	TFR003	Franklin Police Station Retic	Cl*	24.7	±1.8%	mg Cl/L
11-Aug-25	2450308	TFR003	Franklin Police Station Retic	Cl2 (F) OS*	0.15	-	mg Cl2/L
11-Aug-25	2450308	TFR003	Franklin Police Station Retic	Cl2 (T) OS*	0.23	-	mg Cl2/L
11-Aug-25	2450312	TFR003	Franklin Police Station Retic	CN (T)	<25.0	±8.6%	µg CN/L
11-Aug-25	2450309	TFR003	Franklin Police Station Retic	Coliforms*	0	±15%	MPN/100mL
11-Aug-25	2450309	TFR003	Franklin Police Station Retic	Coliphages*	0	±8%	PFU/10ml
11-Aug-25	2450308	TFR003	Franklin Police Station Retic	Coll Time OS*	8:25	-	-
11-Aug-25	2450315	TFR003	Franklin Police Station Retic	Combined NO3 + NO2 ratio*	<0.12	-	-
11-Aug-25	2450317	TFR003	Franklin Police Station Retic	Combined THM Ratio*	0.42	-	-
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Cr (T)*	<5.00	±5.3%	µg Cr/L
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Cu (AE)	<0.05	±4.1%	mg Cu/L
11-Aug-25	2450309	TFR003	Franklin Police Station Retic	E.coli*	0	±14%	MPN/100mL
11-Aug-25	2450315	TFR003	Franklin Police Station Retic	F	<100	±5.3%	µg F/L
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Fe (AE)	0.04	±5.4%	mg Fe/L
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Hg (AE)*	<1.00	±6.5%	µg Hg/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Aug-25	2450309	TFR003	Franklin Police Station Retic	HPC 37*	0	±21%	cfu/mL
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Mn (AE)	<0.01	±6.2%	mg Mn/L
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Na (AE)	12.6	±7.5%	mg Na/L
11-Aug-25	2450315	TFR003	Franklin Police Station Retic	NH3*	<0.10	±5.5%	mg N/L
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Ni (AE)	<10.0	±5.9%	µg Ni/L
11-Aug-25	2450315	TFR003	Franklin Police Station Retic	NO2*	<0.10	±2.4%	mg N/L
11-Aug-25	2450315	TFR003	Franklin Police Station Retic	NO3*	<0.10	±2.9%	mg N/L
11-Aug-25	2450313	TFR003	Franklin Police Station Retic	Odour*	Mild Chlorinous	-	-
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Pb (AE)	<4.00	±6.7%	µg Pb/L
11-Aug-25	2450308	TFR003	Franklin Police Station Retic	pH OS*	7.30	-	-
11-Aug-25	2450314	TFR003	Franklin Police Station Retic	Phenols*	<10.0	-	µg/L
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Sb (AE)*	<5.00	±7%	µg Sb/L
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Se (AE)*	<5.00	±7.7%	µg Se/L
11-Aug-25	2450315	TFR003	Franklin Police Station Retic	SO4*	<1.00	±1.8%	mg SO4/L
11-Aug-25	2450313	TFR003	Franklin Police Station Retic	SS	<10.0	±3.7%	mg /L
11-Aug-25	2450313	TFR003	Franklin Police Station Retic	TDS	93.00	±2.5%	mg /L
11-Aug-25	2450308	TFR003	Franklin Police Station Retic	Temperature OS*	12.2	-	°C
11-Aug-25	2450313	TFR003	Franklin Police Station Retic	TOC	1.70	±5%	mg C/L
11-Aug-25	2450313	TFR003	Franklin Police Station Retic	Turbidity	1.2	±6.1%	NTU
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	U (AE)*	<10.0	±7.6%	µg U/L
11-Aug-25	2450316	TFR003	Franklin Police Station Retic	Zn (AE)	<0.03	±7.2%	mg Zn/L
11-Aug-25	2450328	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
11-Aug-25	2450323	TKK002	Kokstad Final	Batch No.*	20250201	-	-
11-Aug-25	2450323	TKK002	Kokstad Final	Cl2 (F) OS*	1.32	-	mg Cl2/L
11-Aug-25	2450323	TKK002	Kokstad Final	Cl2 (T) OS*	1.46	-	mg Cl2/L
11-Aug-25	2450324	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
11-Aug-25	2450324	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
11-Aug-25	2450323	TKK002	Kokstad Final	Coll Time OS*	7:13	-	-
11-Aug-25	2450326	TKK002	Kokstad Final	Colour	1.00	±6.5%	mg Pt-Co/L
11-Aug-25	2450327	TKK002	Kokstad Final	Conductivity	14.1	±1.5%	mS/m
11-Aug-25	2450324	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
11-Aug-25	2450324	TKK002	Kokstad Final	HPC 37*	0	±21%	cfu/mL
11-Aug-25	2450326	TKK002	Kokstad Final	Odour*	Mild Chlorinous	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Aug-25	2450323	TKK002	Kokstad Final	pH OS*	7.60	-	-
11-Aug-25	2450326	TKK002	Kokstad Final	Taste*	Nil	-	-
11-Aug-25	2450323	TKK002	Kokstad Final	Temperature OS*	9.8	-	°C
11-Aug-25	2450326	TKK002	Kokstad Final	Turbidity	<0.2	±6.1%	NTU
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Al (AE)	<25.0	±7.6%	µg Al/L
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	As (AE)*	<5.00	±7.5%	µg As/L
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	B (AE)	<25.0	±6.6%	µg B/L
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Ba (AE)	16.2	±6.9%	µg Ba/L
11-Aug-25	2450334	TKK005	Kokstad Khanyiselani Rectification	Batch No.*	20250201	-	-
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Cd (AE)	<1.00	±6%	µg Cd/L
11-Aug-25	2450343	TKK005	Kokstad Khanyiselani Rectification	CHBr3	<10	±6.4%	µg/L
11-Aug-25	2450343	TKK005	Kokstad Khanyiselani Rectification	CHCl2Br	<10	±5.7%	µg/L
11-Aug-25	2450343	TKK005	Kokstad Khanyiselani Rectification	CHCl3	33.0	±6%	µg/L
11-Aug-25	2450343	TKK005	Kokstad Khanyiselani Rectification	CHClBr2	<10	±5.3%	µg/L
11-Aug-25	2450341	TKK005	Kokstad Khanyiselani Rectification	Cl*	9.61	±1.8%	mg Cl/L
11-Aug-25	2450334	TKK005	Kokstad Khanyiselani Rectification	Cl2 (F) OS*	0.86	-	mg Cl2/L
11-Aug-25	2450334	TKK005	Kokstad Khanyiselani Rectification	Cl2 (T) OS*	0.99	-	mg Cl2/L
11-Aug-25	2450338	TKK005	Kokstad Khanyiselani Rectification	CN (T)	<25.0	±8.6%	µg CN/L
11-Aug-25	2450335	TKK005	Kokstad Khanyiselani Rectification	Coliforms*	0	±15%	MPN/100mL
11-Aug-25	2450335	TKK005	Kokstad Khanyiselani Rectification	Coliphages*	0	±8%	PFU/10ml
11-Aug-25	2450334	TKK005	Kokstad Khanyiselani Rectification	Coll Time OS*	9:27	-	-
11-Aug-25	2450339	TKK005	Kokstad Khanyiselani Rectification	Colour	1.10	±6.5%	mg Pt-Co/L
11-Aug-25	2450341	TKK005	Kokstad Khanyiselani Rectification	Combined NO3 + NO2 ratio*	0.14	-	-
11-Aug-25	2450343	TKK005	Kokstad Khanyiselani Rectification	Combined THM Ratio*	0.48	-	-
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Cr (T)*	<5.00	±5.3%	µg Cr/L
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Cu (AE)	<0.05	±4.1%	mg Cu/L
11-Aug-25	2450335	TKK005	Kokstad Khanyiselani Rectification	E.coli*	0	±14%	MPN/100mL
11-Aug-25	2450341	TKK005	Kokstad Khanyiselani Rectification	F	231	±5.3%	µg F/L
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Fe (AE)	<0.02	±5.4%	mg Fe/L
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Hg (AE)*	<1.00	±6.5%	µg Hg/L
11-Aug-25	2450335	TKK005	Kokstad Khanyiselani Rectification	HPC 37*	0	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Mn (AE)	<0.01	±6.2%	mg Mn/L
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Na (AE)	8.99	±7.5%	mg Na/L
11-Aug-25	2450341	TKK005	Kokstad Khanyiselani Rectification	NH3*	<0.10	±5.5%	mg N/L
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Ni (AE)	<10.0	±5.9%	µg Ni/L
11-Aug-25	2450341	TKK005	Kokstad Khanyiselani Rectification	NO2*	<0.10	±2.4%	mg N/L
11-Aug-25	2450341	TKK005	Kokstad Khanyiselani Rectification	NO3*	0.27	±2.9%	mg N/L
11-Aug-25	2450339	TKK005	Kokstad Khanyiselani Rectification	Odour*	Mild Chlorinous	-	-
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Pb (AE)	<4.00	±6.7%	µg Pb/L
11-Aug-25	2450334	TKK005	Kokstad Khanyiselani Rectification	pH OS*	7.50	-	-
11-Aug-25	2450340	TKK005	Kokstad Khanyiselani Rectification	Phenols*	<10.0	-	µg/L
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Sb (AE)*	<5.00	±7%	µg Sb/L
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Se (AE)*	<5.00	±7.7%	µg Se/L
11-Aug-25	2450341	TKK005	Kokstad Khanyiselani Rectification	SO4*	1.47	±1.8%	mg SO4/L
11-Aug-25	2450339	TKK005	Kokstad Khanyiselani Rectification	SS	<10.0	±3.7%	mg /L
11-Aug-25	2450339	TKK005	Kokstad Khanyiselani Rectification	Taste*	Nil	-	-
11-Aug-25	2450339	TKK005	Kokstad Khanyiselani Rectification	TDS	90.00	±2.5%	mg /L
11-Aug-25	2450334	TKK005	Kokstad Khanyiselani Rectification	Temperature OS*	10.4	-	°C
11-Aug-25	2450339	TKK005	Kokstad Khanyiselani Rectification	TOC	1.96	±5%	mg C/L
11-Aug-25	2450339	TKK005	Kokstad Khanyiselani Rectification	Turbidity	<0.2	±6.1%	NTU
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	U (AE)*	<10.0	±7.6%	µg U/L
11-Aug-25	2450342	TKK005	Kokstad Khanyiselani Rectification	Zn (AE)	<0.03	±7.2%	mg Zn/L
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Al (AE)	<25.0	±7.6%	µg Al/L
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	As (AE)*	<5.00	±7.5%	µg As/L
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	B (AE)	<25.0	±6.6%	µg B/L
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Ba (AE)	15.7	±6.9%	µg Ba/L
11-Aug-25	2450344	TKK006	Kokstad Bongweni Correctional Serv Retic	Batch No.*	20250201	-	-
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Cd (AE)	<1.00	±6%	µg Cd/L
11-Aug-25	2450353	TKK006	Kokstad Bongweni Correctional Serv Retic	CHBr3	<10	±6.4%	µg/L
11-Aug-25	2450353	TKK006	Kokstad Bongweni Correctional Serv Retic	CHCl2Br	<10	±5.7%	µg/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Aug-25	2450353	TKK006	Kokstad Bongweni Correctional Serv Retic	CHCl ₃	34.4	±6%	µg/L
11-Aug-25	2450353	TKK006	Kokstad Bongweni Correctional Serv Retic	CHClBr ₂	<10	±5.3%	µg/L
11-Aug-25	2450351	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl*	8.64	±1.8%	mg Cl/L
11-Aug-25	2450344	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl ₂ (F) OS*	0.90	-	mg Cl ₂ /L
11-Aug-25	2450344	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl ₂ (T) OS*	1.10	-	mg Cl ₂ /L
11-Aug-25	2450348	TKK006	Kokstad Bongweni Correctional Serv Retic	CN (T)	<25.0	±8.6%	µg CN/L
11-Aug-25	2450345	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliforms*	0	±15%	MPN/100mL
11-Aug-25	2450345	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliphages*	0	±8%	PFU/10ml
11-Aug-25	2450344	TKK006	Kokstad Bongweni Correctional Serv Retic	Coll Time OS*	7:38	-	-
11-Aug-25	2450351	TKK006	Kokstad Bongweni Correctional Serv Retic	Combined NO ₃ + NO ₂ ratio*	0.13	-	-
11-Aug-25	2450353	TKK006	Kokstad Bongweni Correctional Serv Retic	Combined THM Ratio*	0.48	-	-
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Cr (T)*	<5.00	±5.3%	µg Cr/L
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Cu (AE)	<0.05	±4.1%	mg Cu/L
11-Aug-25	2450345	TKK006	Kokstad Bongweni Correctional Serv Retic	E.coli*	0	±14%	MPN/100mL
11-Aug-25	2450351	TKK006	Kokstad Bongweni Correctional Serv Retic	F	166	±5.3%	µg F/L
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Fe (AE)	<0.02	±5.4%	mg Fe/L
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Hg (AE)*	<1.00	±6.5%	µg Hg/L
11-Aug-25	2450345	TKK006	Kokstad Bongweni Correctional Serv Retic	HPC 37*	0	±21%	cfu/mL
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Mn (AE)	<0.01	±6.2%	mg Mn/L
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Na (AE)	8.00	±7.5%	mg Na/L
11-Aug-25	2450351	TKK006	Kokstad Bongweni Correctional Serv Retic	NH ₃ *	<0.10	±5.5%	mg N/L
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Ni (AE)	<10.0	±5.9%	µg Ni/L
11-Aug-25	2450351	TKK006	Kokstad Bongweni Correctional Serv Retic	NO ₂ *	<0.10	±2.4%	mg N/L
11-Aug-25	2450351	TKK006	Kokstad Bongweni Correctional Serv Retic	NO ₃ *	0.23	±2.9%	mg N/L
11-Aug-25	2450349	TKK006	Kokstad Bongweni Correctional Serv Retic	Odour*	Mild Chlorinous	-	-
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Pb (AE)	<4.00	±6.7%	µg Pb/L
11-Aug-25	2450344	TKK006	Kokstad Bongweni Correctional Serv Retic	pH OS*	7.30	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Aug-25	2450350	TKK006	Kokstad Bongweni Correctional Serv Retic	Phenols*	<10.0	-	µg/L
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Sb (AE)*	<5.00	±7%	µg Sb/L
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Se (AE)*	<5.00	±7.7%	µg Se/L
11-Aug-25	2450351	TKK006	Kokstad Bongweni Correctional Serv Retic	SO ₄ *	1.42	±1.8%	mg SO ₄ /L
11-Aug-25	2450349	TKK006	Kokstad Bongweni Correctional Serv Retic	SS	<10.0	±3.7%	mg /L
11-Aug-25	2450349	TKK006	Kokstad Bongweni Correctional Serv Retic	Taste*	Nil	-	-
11-Aug-25	2450349	TKK006	Kokstad Bongweni Correctional Serv Retic	TDS	86.00	±2.5%	mg /L
11-Aug-25	2450344	TKK006	Kokstad Bongweni Correctional Serv Retic	Temperature OS*	10.6	-	°C
11-Aug-25	2450349	TKK006	Kokstad Bongweni Correctional Serv Retic	TOC	1.85	±5%	mg C/L
11-Aug-25	2450349	TKK006	Kokstad Bongweni Correctional Serv Retic	Turbidity	0.2	±6.1%	NTU
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	U (AE)*	<10.0	±7.6%	µg U/L
11-Aug-25	2450352	TKK006	Kokstad Bongweni Correctional Serv Retic	Zn (AE)	<0.03	±7.2%	mg Zn/L
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Al (AE)	<25.0	±7.6%	µg Al/L
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	As (AE)*	<5.00	±7.5%	µg As/L
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	B (AE)	<25.0	±6.6%	µg B/L
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Ba (AE)	15.9	±6.9%	µg Ba/L
11-Aug-25	2450354	TKK007	Kokstad Shayamoya Reticulation	Batch No.*	20250201	-	-
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Cd (AE)	<1.00	±6%	µg Cd/L
11-Aug-25	2450363	TKK007	Kokstad Shayamoya Reticulation	CHBr ₃	<10	±6.4%	µg/L
11-Aug-25	2450363	TKK007	Kokstad Shayamoya Reticulation	CHCl ₂ Br	<10	±5.7%	µg/L
11-Aug-25	2450363	TKK007	Kokstad Shayamoya Reticulation	CHCl ₃	35.5	±6%	µg/L
11-Aug-25	2450363	TKK007	Kokstad Shayamoya Reticulation	CHClBr ₂	<10	±5.3%	µg/L
11-Aug-25	2450361	TKK007	Kokstad Shayamoya Reticulation	Cl*	9.62	±1.8%	mg Cl/L
11-Aug-25	2450354	TKK007	Kokstad Shayamoya Reticulation	Cl ₂ (F) OS*	1.15	-	mg Cl ₂ /L
11-Aug-25	2450354	TKK007	Kokstad Shayamoya Reticulation	Cl ₂ (T) OS*	1.20	-	mg Cl ₂ /L
11-Aug-25	2450358	TKK007	Kokstad Shayamoya Reticulation	CN (T)	<25.0	±8.6%	µg CN/L
11-Aug-25	2450355	TKK007	Kokstad Shayamoya Reticulation	Coliforms*	0	±15%	MPN/100mL
11-Aug-25	2450355	TKK007	Kokstad Shayamoya Reticulation	Coliphages*	0	±8%	PFU/10ml

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Aug-25	2450354	TKK007	Kokstad Shayamoya Reticulation	Coll Time OS*	9:47	-	-
11-Aug-25	2450359	TKK007	Kokstad Shayamoya Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
11-Aug-25	2450361	TKK007	Kokstad Shayamoya Reticulation	Combined NO3 + NO2 ratio*	0.14	-	-
11-Aug-25	2450363	TKK007	Kokstad Shayamoya Reticulation	Combined THM Ratio*	0.48	-	-
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Cr (T)*	<5.00	±5.3%	µg Cr/L
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Cu (AE)	<0.05	±4.1%	mg Cu/L
11-Aug-25	2450355	TKK007	Kokstad Shayamoya Reticulation	E.coli*	0	±14%	MPN/100mL
11-Aug-25	2450361	TKK007	Kokstad Shayamoya Reticulation	F	153	±5.3%	µg F/L
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Fe (AE)	<0.02	±5.4%	mg Fe/L
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Hg (AE)*	<1.00	±6.5%	µg Hg/L
11-Aug-25	2450355	TKK007	Kokstad Shayamoya Reticulation	HPC 37*	0	±21%	cfu/mL
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Mn (AE)	<0.01	±6.2%	mg Mn/L
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Na (AE)	9.13	±7.5%	mg Na/L
11-Aug-25	2450361	TKK007	Kokstad Shayamoya Reticulation	NH3*	<0.10	±5.5%	mg N/L
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Ni (AE)	<10.0	±5.9%	µg Ni/L
11-Aug-25	2450361	TKK007	Kokstad Shayamoya Reticulation	NO2*	<0.10	±2.4%	mg N/L
11-Aug-25	2450361	TKK007	Kokstad Shayamoya Reticulation	NO3*	0.27	±2.9%	mg N/L
11-Aug-25	2450359	TKK007	Kokstad Shayamoya Reticulation	Odour*	Mild Chlorinous	-	-
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Pb (AE)	<4.00	±6.7%	µg Pb/L
11-Aug-25	2450354	TKK007	Kokstad Shayamoya Reticulation	pH OS*	7.40	-	-
11-Aug-25	2450360	TKK007	Kokstad Shayamoya Reticulation	Phenols*	<10.0	-	µg/L
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Sb (AE)*	<5.00	±7%	µg Sb/L
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Se (AE)*	<5.00	±7.7%	µg Se/L
11-Aug-25	2450361	TKK007	Kokstad Shayamoya Reticulation	SO4*	1.45	±1.8%	mg SO4/L
11-Aug-25	2450359	TKK007	Kokstad Shayamoya Reticulation	SS	<10.0	±3.7%	mg /L
11-Aug-25	2450359	TKK007	Kokstad Shayamoya Reticulation	Taste*	Nil	-	-
11-Aug-25	2450359	TKK007	Kokstad Shayamoya Reticulation	TDS	91.00	±2.5%	mg /L
11-Aug-25	2450354	TKK007	Kokstad Shayamoya Reticulation	Temperature OS*	11.3	-	°C
11-Aug-25	2450359	TKK007	Kokstad Shayamoya Reticulation	TOC	1.93	±5%	mg C/L
11-Aug-25	2450359	TKK007	Kokstad Shayamoya Reticulation	Turbidity	<0.2	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	U (AE)*	<10.0	±7.6%	µg U/L
11-Aug-25	2450362	TKK007	Kokstad Shayamoya Reticulation	Zn (AE)	<0.03	±7.2%	mg Zn/L
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Al (AE)	<25.0	±7.6%	µg Al/L
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	As (AE)*	<5.00	±7.5%	µg As/L
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	B (AE)	<25.0	±6.6%	µg B/L
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Ba (AE)	15.7	±6.9%	µg Ba/L
11-Aug-25	2450364	TKK009	Kokstad Farm Fresh Produce Market	Batch No.*	20250201	-	-
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Cd (AE)	<1.00	±6%	µg Cd/L
11-Aug-25	2450374	TKK009	Kokstad Farm Fresh Produce Market	CHBr3	<10	±6.4%	µg/L
11-Aug-25	2450374	TKK009	Kokstad Farm Fresh Produce Market	CHCl2Br	<10	±5.7%	µg/L
11-Aug-25	2450374	TKK009	Kokstad Farm Fresh Produce Market	CHCl3	28.7	±6%	µg/L
11-Aug-25	2450374	TKK009	Kokstad Farm Fresh Produce Market	CHClBr2	<10	±5.3%	µg/L
11-Aug-25	2450371	TKK009	Kokstad Farm Fresh Produce Market	Cl*	8.73	±1.8%	mg Cl/L
11-Aug-25	2450364	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (F) OS*	1.26	-	mg Cl2/L
11-Aug-25	2450364	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (T) OS*	1.30	-	mg Cl2/L
11-Aug-25	2450368	TKK009	Kokstad Farm Fresh Produce Market	CN (T)	<25.0	±8.6%	µg CN/L
11-Aug-25	2450365	TKK009	Kokstad Farm Fresh Produce Market	Coliforms*	0	±15%	MPN/100mL
11-Aug-25	2450365	TKK009	Kokstad Farm Fresh Produce Market	Coliphages*	0	±8%	PFU/10ml
11-Aug-25	2450364	TKK009	Kokstad Farm Fresh Produce Market	Coll Time OS*	10:12	-	-
11-Aug-25	2450371	TKK009	Kokstad Farm Fresh Produce Market	Combined NO3 + NO2 ratio*	0.13	-	-
11-Aug-25	2450374	TKK009	Kokstad Farm Fresh Produce Market	Combined THM Ratio*	0.46	-	-
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Cr (T)*	<5.00	±5.3%	µg Cr/L
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Cu (AE)	<0.05	±4.1%	mg Cu/L
11-Aug-25	2450365	TKK009	Kokstad Farm Fresh Produce Market	E.coli*	0	±14%	MPN/100mL
11-Aug-25	2450371	TKK009	Kokstad Farm Fresh Produce Market	F	137	±5.3%	µg F/L
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Fe (AE)	<0.02	±5.4%	mg Fe/L
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Hg (AE)*	<1.00	±6.5%	µg Hg/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Aug-25	2450365	TKK009	Kokstad Farm Fresh Produce Market	HPC 37*	0	±21%	cfu/mL
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Mn (AE)	<0.01	±6.2%	mg Mn/L
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Na (AE)	7.97	±7.5%	mg Na/L
11-Aug-25	2450371	TKK009	Kokstad Farm Fresh Produce Market	NH3*	<0.10	±5.5%	mg N/L
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Ni (AE)	<10.0	±5.9%	µg Ni/L
11-Aug-25	2450371	TKK009	Kokstad Farm Fresh Produce Market	NO2*	<0.10	±2.4%	mg N/L
11-Aug-25	2450371	TKK009	Kokstad Farm Fresh Produce Market	NO3*	0.23	±2.9%	mg N/L
11-Aug-25	2450369	TKK009	Kokstad Farm Fresh Produce Market	Odour*	Mild Chlorinous	-	-
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Pb (AE)	<4.00	±6.7%	µg Pb/L
11-Aug-25	2450364	TKK009	Kokstad Farm Fresh Produce Market	pH OS*	7.50	-	-
11-Aug-25	2450370	TKK009	Kokstad Farm Fresh Produce Market	Phenols*	<10.0	-	µg/L
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Sb (AE)*	<5.00	±7%	µg Sb/L
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Se (AE)*	<5.00	±7.7%	µg Se/L
11-Aug-25	2450371	TKK009	Kokstad Farm Fresh Produce Market	SO4*	1.58	±1.8%	mg SO4/L
11-Aug-25	2450369	TKK009	Kokstad Farm Fresh Produce Market	SS	<10.0	±3.7%	mg /L
11-Aug-25	2450369	TKK009	Kokstad Farm Fresh Produce Market	Taste*	Nil	-	-
11-Aug-25	2450369	TKK009	Kokstad Farm Fresh Produce Market	TDS	85.00	±2.5%	mg /L
11-Aug-25	2450364	TKK009	Kokstad Farm Fresh Produce Market	Temperature OS*	12.1	-	°C
11-Aug-25	2450369	TKK009	Kokstad Farm Fresh Produce Market	TOC	1.80	±5%	mg C/L
11-Aug-25	2450369	TKK009	Kokstad Farm Fresh Produce Market	Turbidity	<0.2	±6.1%	NTU
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	U (AE)*	<10.0	±7.6%	µg U/L
11-Aug-25	2450372	TKK009	Kokstad Farm Fresh Produce Market	Zn (AE)	<0.03	±7.2%	mg Zn/L
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Al (AE)	218	±7.6%	µg Al/L
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	As (AE)*	<5.00	±7.5%	µg As/L
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	B (AE)	<25.0	±6.6%	µg B/L
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Ba (AE)	16.9	±6.9%	µg Ba/L
11-Aug-25	2450376	TKK012	Kokstad FET College Reticulation	Batch No.*	20250201	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Cd (AE)	<1.00	±6%	µg Cd/L
11-Aug-25	2450385	TKK012	Kokstad FET College Reticulation	CHBr3	<10	±6.4%	µg/L
11-Aug-25	2450385	TKK012	Kokstad FET College Reticulation	CHCl2Br	<10	±5.7%	µg/L
11-Aug-25	2450385	TKK012	Kokstad FET College Reticulation	CHCl3	20.5	±6%	µg/L
11-Aug-25	2450385	TKK012	Kokstad FET College Reticulation	CHClBr2	<10	±5.3%	µg/L
11-Aug-25	2450383	TKK012	Kokstad FET College Reticulation	Cl*	9.85	±1.8%	mg Cl/L
11-Aug-25	2450376	TKK012	Kokstad FET College Reticulation	Cl2 (F) OS*	1.19	-	mg Cl2/L
11-Aug-25	2450376	TKK012	Kokstad FET College Reticulation	Cl2 (T) OS*	1.34	-	mg Cl2/L
11-Aug-25	2450380	TKK012	Kokstad FET College Reticulation	CN (T)	<25.0	±8.6%	µg CN/L
11-Aug-25	2450377	TKK012	Kokstad FET College Reticulation	Coliforms*	0	±15%	MPN/100mL
11-Aug-25	2450377	TKK012	Kokstad FET College Reticulation	Coliphages*	0	±8%	PFU/10ml
11-Aug-25	2450376	TKK012	Kokstad FET College Reticulation	Coll Time OS*	9:00	-	-
11-Aug-25	2450381	TKK012	Kokstad FET College Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
11-Aug-25	2450383	TKK012	Kokstad FET College Reticulation	Combined NO3 + NO2 ratio*	0.13	-	-
11-Aug-25	2450385	TKK012	Kokstad FET College Reticulation	Combined THM Ratio*	0.44	-	-
11-Aug-25	2450383	TKK012	Kokstad FET College Reticulation	Conductivity	15.4	±1.5%	mS/m
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Cr (T)*	<5.00	±5.3%	µg Cr/L
11-Aug-25	2450377	TKK012	Kokstad FET College Reticulation	E.coli*	0	±14%	MPN/100mL
11-Aug-25	2450383	TKK012	Kokstad FET College Reticulation	F	172	±5.3%	µg F/L
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Fe (AE)	<0.02	±5.4%	mg Fe/L
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Hg (AE)*	<1.00	±6.5%	µg Hg/L
11-Aug-25	2450377	TKK012	Kokstad FET College Reticulation	HPC 37*	0	±21%	cfu/mL
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Mn (AE)	<0.01	±6.2%	mg Mn/L
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Na (AE)	9.17	±7.5%	mg Na/L
11-Aug-25	2450383	TKK012	Kokstad FET College Reticulation	NH3*	<0.10	±5.5%	mg N/L
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Ni (AE)	<10.0	±5.9%	µg Ni/L
11-Aug-25	2450383	TKK012	Kokstad FET College Reticulation	NO2*	<0.10	±2.4%	mg N/L
11-Aug-25	2450383	TKK012	Kokstad FET College Reticulation	NO3*	0.24	±2.9%	mg N/L
11-Aug-25	2450381	TKK012	Kokstad FET College Reticulation	Odour*	Mild Chlorinous	-	-
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Pb (AE)	<4.00	±6.7%	µg Pb/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Aug-25	2450376	TKK012	Kokstad FET College Reticulation	pH OS*	7.30	-	-
11-Aug-25	2450382	TKK012	Kokstad FET College Reticulation	Phenols*	<10.0	-	µg/L
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Sb (AE)*	<5.00	±7%	µg Sb/L
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Se (AE)*	<5.00	±7.7%	µg Se/L
11-Aug-25	2450383	TKK012	Kokstad FET College Reticulation	SO ₄ *	1.49	±1.8%	mg SO ₄ /L
11-Aug-25	2450381	TKK012	Kokstad FET College Reticulation	SS	<10.0	±3.7%	mg /L
11-Aug-25	2450381	TKK012	Kokstad FET College Reticulation	Taste*	Nil	-	-
11-Aug-25	2450381	TKK012	Kokstad FET College Reticulation	TDS	92.00	±2.5%	mg /L
11-Aug-25	2450376	TKK012	Kokstad FET College Reticulation	Temperature OS*	10.4	-	°C
11-Aug-25	2450381	TKK012	Kokstad FET College Reticulation	TOC	1.98	±5%	mg C/L
11-Aug-25	2450381	TKK012	Kokstad FET College Reticulation	Turbidity	0.2	±6.1%	NTU
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	U (AE)*	<10.0	±7.6%	µg U/L
11-Aug-25	2450384	TKK012	Kokstad FET College Reticulation	Zn (AE)	<0.03	±7.2%	mg Zn/L
11-Aug-25	2450415	TNJU002	KwaNjunga Final	Batch No.*	20250201	-	-
11-Aug-25	2450415	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	0.35	-	mg Cl ₂ /L
11-Aug-25	2450415	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	0.46	-	mg Cl ₂ /L
11-Aug-25	2450416	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
11-Aug-25	2450415	TNJU002	KwaNjunga Final	Coll Time OS*	9:11	-	-
11-Aug-25	2450419	TNJU002	KwaNjunga Final	Conductivity	20.5	±1.5%	mS/m
11-Aug-25	2450416	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
11-Aug-25	2450416	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	cfu/mL
11-Aug-25	2450415	TNJU002	KwaNjunga Final	pH OS*	7.00	-	-
11-Aug-25	2450415	TNJU002	KwaNjunga Final	Temperature OS*	16.2	-	°C
11-Aug-25	2450418	TNJU002	KwaNjunga Final	Turbidity	0.5	±6.1%	NTU
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Al (AE)	129	±7.6%	µg Al/L
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	As (AE)*	8.01	±7.5%	µg As/L
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	B (AE)	<25.0	±6.6%	µg B/L
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Ba (AE)	<10.0	±6.9%	µg Ba/L
11-Aug-25	2450420	TNJU003	KwaNjunga Reticulation	Batch No.*	20250201	-	-
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Cd (AE)	<1.00	±6%	µg Cd/L
11-Aug-25	2450429	TNJU003	KwaNjunga Reticulation	CHBr ₃	<10	±6.4%	µg/L
11-Aug-25	2450429	TNJU003	KwaNjunga Reticulation	CHCl ₂ Br	<10	±5.7%	µg/L
11-Aug-25	2450429	TNJU003	KwaNjunga Reticulation	CHCl ₃	<10	±6%	µg/L
11-Aug-25	2450429	TNJU003	KwaNjunga Reticulation	CHClBr ₂	<10	±5.3%	µg/L
11-Aug-25	2450427	TNJU003	KwaNjunga Reticulation	Cl*	3.66	±1.8%	mg Cl/L
11-Aug-25	2450420	TNJU003	KwaNjunga Reticulation	Cl ₂ (F) OS*	0.90	-	mg Cl ₂ /L
11-Aug-25	2450420	TNJU003	KwaNjunga Reticulation	Cl ₂ (T) OS*	0.98	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Aug-25	2450424	TNJU003	KwaNjunga Reticulation	CN (T)	<25.0	±8.6%	µg CN/L
11-Aug-25	2450421	TNJU003	KwaNjunga Reticulation	Coliforms*	0	±15%	MPN/100mL
11-Aug-25	2450421	TNJU003	KwaNjunga Reticulation	Coliphages*	0	±8%	PFU/10ml
11-Aug-25	2450420	TNJU003	KwaNjunga Reticulation	Coll Time OS*	9:24	-	-
11-Aug-25	2450425	TNJU003	KwaNjunga Reticulation	Colour	1.30	±6.5%	mg Pt-Co/L
11-Aug-25	2450427	TNJU003	KwaNjunga Reticulation	Combined NO3 + NO2 ratio*	0.17	-	-
11-Aug-25	2450429	TNJU003	KwaNjunga Reticulation	Combined THM Ratio*	<0.40	-	-
11-Aug-25	2450427	TNJU003	KwaNjunga Reticulation	Conductivity	18.2	±1.5%	mS/m
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Cr (T)*	<5.00	±5.3%	µg Cr/L
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Cu (AE)	<0.05	±4.1%	mg Cu/L
11-Aug-25	2450421	TNJU003	KwaNjunga Reticulation	E.coli*	0	±14%	MPN/100mL
11-Aug-25	2450427	TNJU003	KwaNjunga Reticulation	F	216	±5.3%	µg F/L
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Fe (AE)	<0.02	±5.4%	mg Fe/L
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Hg (AE)*	<1.00	±6.5%	µg Hg/L
11-Aug-25	2450421	TNJU003	KwaNjunga Reticulation	HPC 37*	0	±21%	cfu/mL
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Mn (AE)	<0.01	±6.2%	mg Mn/L
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Na (AE)	12.8	±7.5%	mg Na/L
11-Aug-25	2450427	TNJU003	KwaNjunga Reticulation	NH3*	<0.10	±5.5%	mg N/L
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Ni (AE)	<10.0	±5.9%	µg Ni/L
11-Aug-25	2450427	TNJU003	KwaNjunga Reticulation	NO2*	<0.10	±2.4%	mg N/L
11-Aug-25	2450427	TNJU003	KwaNjunga Reticulation	NO3*	0.70	±2.9%	mg N/L
11-Aug-25	2450425	TNJU003	KwaNjunga Reticulation	Odour*	Mild Chlorinous	-	-
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Pb (AE)	<4.00	±6.7%	µg Pb/L
11-Aug-25	2450420	TNJU003	KwaNjunga Reticulation	pH OS*	7.30	-	-
11-Aug-25	2450426	TNJU003	KwaNjunga Reticulation	Phenols*	<10.0	-	µg/L
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Sb (AE)*	<5.00	±7%	µg Sb/L
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Se (AE)*	<5.00	±7.7%	µg Se/L
11-Aug-25	2450427	TNJU003	KwaNjunga Reticulation	SO4*	1.98	±1.8%	mg SO4/L
11-Aug-25	2450425	TNJU003	KwaNjunga Reticulation	SS	<10.0	±3.7%	mg /L
11-Aug-25	2450425	TNJU003	KwaNjunga Reticulation	Taste*	Nil	-	-
11-Aug-25	2450425	TNJU003	KwaNjunga Reticulation	TDS	125.00	±2.5%	mg /L
11-Aug-25	2450420	TNJU003	KwaNjunga Reticulation	Temperature OS*	14.3	-	°C
11-Aug-25	2450425	TNJU003	KwaNjunga Reticulation	TOC	<1.00	±5%	mg C/L
11-Aug-25	2450425	TNJU003	KwaNjunga Reticulation	Turbidity	0.5	±6.1%	NTU
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	U (AE)*	<10.0	±7.6%	µg U/L
11-Aug-25	2450428	TNJU003	KwaNjunga Reticulation	Zn (AE)	<0.03	±7.2%	mg Zn/L
12-Aug-25	2450973	TQU002	Mnqumeni Final	Batch No.*	20250201	-	-
12-Aug-25	2450973	TQU002	Mnqumeni Final	Cl2 (F) OS*	0.90	-	mg Cl2/L
12-Aug-25	2450973	TQU002	Mnqumeni Final	Cl2 (T) OS*	1.05	-	mg Cl2/L
12-Aug-25	2450974	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
12-Aug-25	2450973	TQU002	Mnqumeni Final	Coll Time OS*	06:19	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

12-Aug-25	2450977	TQU002	Mnqumeni Final	Conductivity	19.1	±1.5%	mS/m
12-Aug-25	2450974	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
12-Aug-25	2450974	TQU002	Mnqumeni Final	HPC 37*	0	±21%	cfu/mL
12-Aug-25	2450973	TQU002	Mnqumeni Final	pH OS*	7.40	-	-
12-Aug-25	2450973	TQU002	Mnqumeni Final	Temperature OS*	14.0	-	°C
12-Aug-25	2450976	TQU002	Mnqumeni Final	Turbidity	0.9	±6.1%	NTU
12-Aug-25	2450988	TSQ002	Esiqanduleni Final	Al (AE)	157	±7.6%	µg Al/L
12-Aug-25	2450983	TSQ002	Esiqanduleni Final	Batch No.*	20250201	-	-
12-Aug-25	2450983	TSQ002	Esiqanduleni Final	Cl ₂ (F) OS*	1.40	-	mg Cl ₂ /L
12-Aug-25	2450983	TSQ002	Esiqanduleni Final	Cl ₂ (T) OS*	1.65	-	mg Cl ₂ /L
12-Aug-25	2450984	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
12-Aug-25	2450983	TSQ002	Esiqanduleni Final	Coll Time OS*	07:59	-	-
12-Aug-25	2450986	TSQ002	Esiqanduleni Final	Colour	1.50	±6.5%	mg Pt-Co/L
12-Aug-25	2450987	TSQ002	Esiqanduleni Final	Conductivity	19.1	±1.5%	mS/m
12-Aug-25	2450984	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
12-Aug-25	2450984	TSQ002	Esiqanduleni Final	HPC 37*	7	±21%	cfu/mL
12-Aug-25	2450986	TSQ002	Esiqanduleni Final	Odour*	Nil	-	-
12-Aug-25	2450983	TSQ002	Esiqanduleni Final	pH OS*	7.90	-	-
12-Aug-25	2450983	TSQ002	Esiqanduleni Final	Temperature OS*	11.3	-	°C
12-Aug-25	2450986	TSQ002	Esiqanduleni Final	Turbidity	1.3	±6.1%	NTU
12-Aug-25	2450989	TSQ003	Esiqanduleni Reticulation	Batch No.*	20250201	-	-
12-Aug-25	2450989	TSQ003	Esiqanduleni Reticulation	Cl ₂ (F) OS*	0.86	-	mg Cl ₂ /L
12-Aug-25	2450989	TSQ003	Esiqanduleni Reticulation	Cl ₂ (T) OS*	0.99	-	mg Cl ₂ /L
12-Aug-25	2450990	TSQ003	Esiqanduleni Reticulation	Coliforms*	0	±15%	MPN/100mL
12-Aug-25	2450989	TSQ003	Esiqanduleni Reticulation	Coll Time OS*	08:12	-	-
12-Aug-25	2450990	TSQ003	Esiqanduleni Reticulation	E.coli*	0	±14%	MPN/100mL
12-Aug-25	2450990	TSQ003	Esiqanduleni Reticulation	HPC 37*	2	±21%	cfu/mL
12-Aug-25	2450989	TSQ003	Esiqanduleni Reticulation	pH OS*	7.40	-	-
12-Aug-25	2450989	TSQ003	Esiqanduleni Reticulation	Temperature OS*	13.2	-	°C
12-Aug-25	2450992	TSQ003	Esiqanduleni Reticulation	Turbidity	1.4	±6.1%	NTU
13-Aug-25	2451576	TBU002	Bulwer Final	Batch No.*	20250201	-	-
13-Aug-25	2451576	TBU002	Bulwer Final	Cl ₂ (F) OS*	1.03	-	mg Cl ₂ /L
13-Aug-25	2451576	TBU002	Bulwer Final	Cl ₂ (T) OS*	1.09	-	mg Cl ₂ /L
13-Aug-25	2451577	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
13-Aug-25	2451576	TBU002	Bulwer Final	Coll Time OS*	10:15	-	-
13-Aug-25	2451579	TBU002	Bulwer Final	Colour	2.00	±6.5%	mg Pt-Co/L
13-Aug-25	2451580	TBU002	Bulwer Final	Conductivity	6.23	±1.5%	mS/m
13-Aug-25	2451577	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
13-Aug-25	2451577	TBU002	Bulwer Final	HPC 37*	6	±21%	cfu/mL
13-Aug-25	2451579	TBU002	Bulwer Final	Odour*	Mild Chlorinous	-	-
13-Aug-25	2451576	TBU002	Bulwer Final	pH OS*	7.40	-	-
13-Aug-25	2451579	TBU002	Bulwer Final	Taste*	Nil	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

13-Aug-25	2451576	TBU002	Bulwer Final	Temperature OS*	18.6	-	°C
13-Aug-25	2451579	TBU002	Bulwer Final	Turbidity	3.5	±6.1%	NTU
13-Aug-25	2451581	TBU005	Bulwer Mountain Park Hotel Retic	Batch No.*	20250201	-	-
13-Aug-25	2451581	TBU005	Bulwer Mountain Park Hotel Retic	Cl2 (F) OS*	0.38	-	mg Cl2/L
13-Aug-25	2451581	TBU005	Bulwer Mountain Park Hotel Retic	Cl2 (T) OS*	0.44	-	mg Cl2/L
13-Aug-25	2451582	TBU005	Bulwer Mountain Park Hotel Retic	Coliforms*	0	±15%	MPN/100mL
13-Aug-25	2451581	TBU005	Bulwer Mountain Park Hotel Retic	Coll Time OS*	10:38	-	-
13-Aug-25	2451582	TBU005	Bulwer Mountain Park Hotel Retic	E.coli*	0	±14%	MPN/100mL
13-Aug-25	2451582	TBU005	Bulwer Mountain Park Hotel Retic	HPC 37*	4	±21%	cfu/mL
13-Aug-25	2451581	TBU005	Bulwer Mountain Park Hotel Retic	pH OS*	7.30	-	-
13-Aug-25	2451581	TBU005	Bulwer Mountain Park Hotel Retic	Temperature OS*	17.4	-	°C
13-Aug-25	2451584	TBU005	Bulwer Mountain Park Hotel Retic	Turbidity	3.9	±6.1%	NTU
13-Aug-25	2451596	TCR002	Creighton Final	Al (AE)	168	±7.6%	µg Al/L
13-Aug-25	2451591	TCR002	Creighton Final	Batch No.*	20250201	-	-
13-Aug-25	2451591	TCR002	Creighton Final	Cl2 (F) OS*	1.15	-	mg Cl2/L
13-Aug-25	2451591	TCR002	Creighton Final	Cl2 (T) OS*	1.20	-	mg Cl2/L
13-Aug-25	2451592	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
13-Aug-25	2451591	TCR002	Creighton Final	Coll Time OS*	08:10	-	-
13-Aug-25	2451595	TCR002	Creighton Final	Conductivity	9.18	±1.5%	mS/m
13-Aug-25	2451592	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
13-Aug-25	2451592	TCR002	Creighton Final	HPC 37*	1	±21%	cfu/mL
13-Aug-25	2451591	TCR002	Creighton Final	pH OS*	7.30	-	-
13-Aug-25	2451591	TCR002	Creighton Final	Temperature OS*	15.7	-	°C
13-Aug-25	2451594	TCR002	Creighton Final	Turbidity	0.3	±6.1%	NTU
13-Aug-25	2451597	TCR004	Creighton Madondo Cottages	Batch No.*	20250201	-	-
13-Aug-25	2451597	TCR004	Creighton Madondo Cottages	Cl2 (F) OS*	0.74	-	mg Cl2/L
13-Aug-25	2451597	TCR004	Creighton Madondo Cottages	Cl2 (T) OS*	0.82	-	mg Cl2/L
13-Aug-25	2451598	TCR004	Creighton Madondo Cottages	Coliforms*	0	±15%	MPN/100mL
13-Aug-25	2451597	TCR004	Creighton Madondo Cottages	Coll Time OS*	08:00	-	-
13-Aug-25	2451600	TCR004	Creighton Madondo Cottages	Colour	<1.00	±6.5%	mg Pt-Co/L
13-Aug-25	2451601	TCR004	Creighton Madondo Cottages	Conductivity	8.90	±1.5%	mS/m
13-Aug-25	2451598	TCR004	Creighton Madondo Cottages	E.coli*	0	±14%	MPN/100mL
13-Aug-25	2451598	TCR004	Creighton Madondo Cottages	HPC 37*	0	±21%	cfu/mL
13-Aug-25	2451597	TCR004	Creighton Madondo Cottages	pH OS*	7.20	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

13-Aug-25	2451597	TCR004	Creighton Madondo Cottages	Temperature OS*	14.8	-	°C
13-Aug-25	2451600	TCR004	Creighton Madondo Cottages	Turbidity	0.3	±6.1%	NTU
13-Aug-25	2451616	THL003	Hlanganani Clinic Reticulation	Batch No.*	20250201	-	-
13-Aug-25	2451616	THL003	Hlanganani Clinic Reticulation	Cl2 (F) OS*	0.49	-	mg Cl2/L
13-Aug-25	2451616	THL003	Hlanganani Clinic Reticulation	Cl2 (T) OS*	0.60	-	mg Cl2/L
13-Aug-25	2451617	THL003	Hlanganani Clinic Reticulation	Coliforms*	0	±15%	MPN/100mL
13-Aug-25	2451616	THL003	Hlanganani Clinic Reticulation	Coll Time OS*	10:58	-	-
13-Aug-25	2451619	THL003	Hlanganani Clinic Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
13-Aug-25	2451620	THL003	Hlanganani Clinic Reticulation	Conductivity	10.8	±1.5%	mS/m
13-Aug-25	2451617	THL003	Hlanganani Clinic Reticulation	E.coli*	0	±14%	MPN/100mL
13-Aug-25	2451617	THL003	Hlanganani Clinic Reticulation	HPC 37*	10	±21%	cfu/mL
13-Aug-25	2451616	THL003	Hlanganani Clinic Reticulation	pH OS*	7.40	-	-
13-Aug-25	2451616	THL003	Hlanganani Clinic Reticulation	Temperature OS*	18.2	-	°C
13-Aug-25	2451619	THL003	Hlanganani Clinic Reticulation	Turbidity	0.3	±6.1%	NTU
13-Aug-25	2451636	TMAN002	Mangwaneni Final	Batch No.*	20250201	-	-
13-Aug-25	2451636	TMAN002	Mangwaneni Final	Cl2 (F) OS*	1.08	-	mg Cl2/L
13-Aug-25	2451636	TMAN002	Mangwaneni Final	Cl2 (T) OS*	1.15	-	mg Cl2/L
13-Aug-25	2451637	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
13-Aug-25	2451636	TMAN002	Mangwaneni Final	Coll Time OS*	11:25	-	-
13-Aug-25	2451639	TMAN002	Mangwaneni Final	Colour	1.90	±6.5%	mg Pt-Co/L
13-Aug-25	2451640	TMAN002	Mangwaneni Final	Conductivity	12.8	±1.5%	mS/m
13-Aug-25	2451637	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
13-Aug-25	2451637	TMAN002	Mangwaneni Final	HPC 37*	3	±21%	cfu/mL
13-Aug-25	2451639	TMAN002	Mangwaneni Final	Odour*	Mild Chlorinous	-	-
13-Aug-25	2451636	TMAN002	Mangwaneni Final	pH OS*	7.10	-	-
13-Aug-25	2451636	TMAN002	Mangwaneni Final	Temperature OS*	14.5	-	°C
13-Aug-25	2451639	TMAN002	Mangwaneni Final	Turbidity	1.8	±6.1%	NTU
13-Aug-25	2451649	TMQA002	Mqatsheni Final	Batch No.*	20250201	-	-
13-Aug-25	2451649	TMQA002	Mqatsheni Final	Cl2 (F) OS*	0.98	-	mg Cl2/L
13-Aug-25	2451649	TMQA002	Mqatsheni Final	Cl2 (T) OS*	1.02	-	mg Cl2/L
13-Aug-25	2451650	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
13-Aug-25	2451649	TMQA002	Mqatsheni Final	Coll Time OS*	09:00	-	-
13-Aug-25	2451652	TMQA002	Mqatsheni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
13-Aug-25	2451653	TMQA002	Mqatsheni Final	Conductivity	26.9	±1.5%	mS/m
13-Aug-25	2451650	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
13-Aug-25	2451650	TMQA002	Mqatsheni Final	HPC 37*	0	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

13-Aug-25	2451652	TMQA002	Mqatsheni Final	Odour*	Mild Chlorinous	-	-
13-Aug-25	2451649	TMQA002	Mqatsheni Final	pH OS*	9.00	-	-
13-Aug-25	2451652	TMQA002	Mqatsheni Final	Taste*	Nil	-	-
13-Aug-25	2451649	TMQA002	Mqatsheni Final	Temperature OS*	14.2	-	°C
13-Aug-25	2451652	TMQA002	Mqatsheni Final	Turbidity	0.8	±6.1%	NTU
13-Aug-25	2451654	TMQA003	Mqatsheni Reticulation	Batch No.*	20250201	-	-
13-Aug-25	2451654	TMQA003	Mqatsheni Reticulation	Cl ₂ (F) OS*	0.66	-	mg Cl ₂ /L
13-Aug-25	2451654	TMQA003	Mqatsheni Reticulation	Cl ₂ (T) OS*	0.75	-	mg Cl ₂ /L
13-Aug-25	2451655	TMQA003	Mqatsheni Reticulation	Coliforms*	0	±15%	MPN/100mL
13-Aug-25	2451654	TMQA003	Mqatsheni Reticulation	Coll Time OS*	08:45	-	-
13-Aug-25	2451655	TMQA003	Mqatsheni Reticulation	E.coli*	0	±14%	MPN/100mL
13-Aug-25	2451655	TMQA003	Mqatsheni Reticulation	HPC 37*	0	±21%	cfu/mL
13-Aug-25	2451654	TMQA003	Mqatsheni Reticulation	pH OS*	8.90	-	-
13-Aug-25	2451654	TMQA003	Mqatsheni Reticulation	Temperature OS*	12.5	-	°C
13-Aug-25	2451657	TMQA003	Mqatsheni Reticulation	Turbidity	0.7	±6.1%	NTU
13-Aug-25	2451704	TRV002	Riverside Final	Batch No.*	20250201	-	-
13-Aug-25	2451704	TRV002	Riverside Final	Cl ₂ (F) OS*	1.22	-	mg Cl ₂ /L
13-Aug-25	2451704	TRV002	Riverside Final	Cl ₂ (T) OS*	1.30	-	mg Cl ₂ /L
13-Aug-25	2451705	TRV002	Riverside Final	Coliforms*	130	±15%	MPN/100mL
13-Aug-25	2451704	TRV002	Riverside Final	Coll Time OS*	08:29	-	-
13-Aug-25	2451707	TRV002	Riverside Final	Colour	3.80	±6.5%	mg Pt-Co/L
13-Aug-25	2451708	TRV002	Riverside Final	Conductivity	8.27	±1.5%	mS/m
13-Aug-25	2451705	TRV002	Riverside Final	E.coli*	10	±14%	MPN/100mL
13-Aug-25	2451705	TRV002	Riverside Final	HPC 37*	250	±21%	cfu/mL
13-Aug-25	2451707	TRV002	Riverside Final	Odour*	Nil	-	-
13-Aug-25	2451704	TRV002	Riverside Final	pH OS*	7.30	-	-
13-Aug-25	2451704	TRV002	Riverside Final	Temperature OS*	16.6	-	°C
13-Aug-25	2451707	TRV002	Riverside Final	Turbidity	2.5	±6.1%	NTU
13-Aug-25	2451709	TRV003	Riverside Reticulation	Batch No.*	20250201	-	-
13-Aug-25	2451709	TRV003	Riverside Reticulation	Cl ₂ (F) OS*	0.66	-	mg Cl ₂ /L
13-Aug-25	2451709	TRV003	Riverside Reticulation	Cl ₂ (T) OS*	0.78	-	mg Cl ₂ /L
13-Aug-25	2451710	TRV003	Riverside Reticulation	Coliforms*	>201	±15%	MPN/100mL
13-Aug-25	2451709	TRV003	Riverside Reticulation	Coll Time OS*	08:25	-	-
13-Aug-25	2451712	TRV003	Riverside Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
13-Aug-25	2451710	TRV003	Riverside Reticulation	E.coli*	6	±14%	MPN/100mL
13-Aug-25	2451710	TRV003	Riverside Reticulation	HPC 37*	290	±21%	cfu/mL
13-Aug-25	2451712	TRV003	Riverside Reticulation	Odour*	Mild Chlorinous	-	-
13-Aug-25	2451709	TRV003	Riverside Reticulation	pH OS*	7.30	-	-
13-Aug-25	2451709	TRV003	Riverside Reticulation	Temperature OS*	16.1	-	°C
13-Aug-25	2451712	TRV003	Riverside Reticulation	Turbidity	2.8	±6.1%	NTU
13-Aug-25	2451719	TST002	St Appollinaris Final	Batch No.*	20250201	-	-
13-Aug-25	2451719	TST002	St Appollinaris Final	Cl ₂ (F) OS*	0.79	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

13-Aug-25	2451719	TST002	St Appollinaris Final	Cl ₂ (T) OS*	0.88	-	mg Cl ₂ /L
13-Aug-25	2451720	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
13-Aug-25	2451719	TST002	St Appollinaris Final	Coll Time OS*	09:36	-	-
13-Aug-25	2451722	TST002	St Appollinaris Final	Colour	1.80	±6.5%	mg Pt-Co/L
13-Aug-25	2451723	TST002	St Appollinaris Final	Conductivity	9.51	±1.5%	mS/m
13-Aug-25	2451720	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
13-Aug-25	2451720	TST002	St Appollinaris Final	HPC 37*	4	±21%	cfu/mL
13-Aug-25	2451722	TST002	St Appollinaris Final	Odour*	Mild Chlorinous	-	-
13-Aug-25	2451719	TST002	St Appollinaris Final	pH OS*	7.40	-	-
13-Aug-25	2451719	TST002	St Appollinaris Final	Temperature OS*	17.5	-	°C
13-Aug-25	2451722	TST002	St Appollinaris Final	Turbidity	2.6	±6.1%	NTU
13-Aug-25	2451736	TUN002	Underberg Final	Al (AE)	47.5	±7.6%	µg Al/L
13-Aug-25	2451730	TUN002	Underberg Final	Batch No.*	20250201	-	-
13-Aug-25	2451730	TUN002	Underberg Final	Cl ₂ (F) OS*	0.58	-	mg Cl ₂ /L
13-Aug-25	2451730	TUN002	Underberg Final	Cl ₂ (T) OS*	0.65	-	mg Cl ₂ /L
13-Aug-25	2451732	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
13-Aug-25	2451730	TUN002	Underberg Final	Coll Time OS*	10:35	-	-
13-Aug-25	2451734	TUN002	Underberg Final	Colour	<1.00	±6.5%	mg Pt-Co/L
13-Aug-25	2451735	TUN002	Underberg Final	Conductivity	7.51	±1.5%	mS/m
13-Aug-25	2451732	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
13-Aug-25	2451732	TUN002	Underberg Final	HPC 37*	6	±21%	cfu/mL
13-Aug-25	2451734	TUN002	Underberg Final	Odour*	Mild Chlorinous	-	-
13-Aug-25	2451730	TUN002	Underberg Final	pH OS*	7.40	-	-
13-Aug-25	2451734	TUN002	Underberg Final	Taste*	Nil	-	-
13-Aug-25	2451730	TUN002	Underberg Final	Temperature OS*	15.4	-	°C
13-Aug-25	2451734	TUN002	Underberg Final	Turbidity	0.9	±6.1%	NTU
14-Aug-25	2451669	TMZ002	Umzimkhulu Final	Al (AE)	132	±7.6%	µg Al/L
14-Aug-25	2451663	TMZ002	Umzimkhulu Final	Batch No.*	20250201	-	-
14-Aug-25	2451663	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	1.43	-	mg Cl ₂ /L
14-Aug-25	2451663	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	1.50	-	mg Cl ₂ /L
14-Aug-25	2451664	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
14-Aug-25	2451664	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
14-Aug-25	2451663	TMZ002	Umzimkhulu Final	Coll Time OS*	07:28	-	-
14-Aug-25	2451667	TMZ002	Umzimkhulu Final	Conductivity	11.9	±1.5%	mS/m
14-Aug-25	2451664	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
14-Aug-25	2451664	TMZ002	Umzimkhulu Final	HPC 37*	2	±21%	cfu/mL
14-Aug-25	2451663	TMZ002	Umzimkhulu Final	pH OS*	7.40	-	-
14-Aug-25	2451663	TMZ002	Umzimkhulu Final	Temperature OS*	17.1	-	°C
14-Aug-25	2451666	TMZ002	Umzimkhulu Final	Turbidity	1.2	±6.1%	NTU
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Al (AE)	115	±7.6%	µg Al/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	As (AE)*	<5.00	±7.5%	µg As/L
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	B (AE)	<25.0	±6.6%	µg B/L
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Ba (AE)	14.1	±6.9%	µg Ba/L
14-Aug-25	2451670	TMZ004	Umzikhulu Informal Settlement Retic	Batch No.*	20250201	-	-
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Cd (AE)	<1.00	±6%	µg Cd/L
14-Aug-25	2451679	TMZ004	Umzikhulu Informal Settlement Retic	CHBr3	<10	±6.4%	µg/L
14-Aug-25	2451679	TMZ004	Umzikhulu Informal Settlement Retic	CHCl2Br	<10	±5.7%	µg/L
14-Aug-25	2451679	TMZ004	Umzikhulu Informal Settlement Retic	CHCl3	11.1	±6%	µg/L
14-Aug-25	2451679	TMZ004	Umzikhulu Informal Settlement Retic	CHClBr2	<10	±5.3%	µg/L
14-Aug-25	2451677	TMZ004	Umzikhulu Informal Settlement Retic	Cl*	6.74	±1.8%	mg Cl/L
14-Aug-25	2451670	TMZ004	Umzikhulu Informal Settlement Retic	Cl2 (F) OS*	0.72	-	mg Cl2/L
14-Aug-25	2451670	TMZ004	Umzikhulu Informal Settlement Retic	Cl2 (T) OS*	0.83	-	mg Cl2/L
14-Aug-25	2451674	TMZ004	Umzikhulu Informal Settlement Retic	CN (T)	<25.0	±8.6%	µg CN/L
14-Aug-25	2451671	TMZ004	Umzikhulu Informal Settlement Retic	Coliforms*	0	±15%	MPN/100mL
14-Aug-25	2451671	TMZ004	Umzikhulu Informal Settlement Retic	Coliphages*	0	±8%	PFU/10ml
14-Aug-25	2451670	TMZ004	Umzikhulu Informal Settlement Retic	Coll Time OS*	09:25	-	-
14-Aug-25	2451675	TMZ004	Umzikhulu Informal Settlement Retic	Colour	1.00	±6.5%	mg Pt-Co/L
14-Aug-25	2451677	TMZ004	Umzikhulu Informal Settlement Retic	Combined NO3 + NO2 ratio*	0.14	-	-
14-Aug-25	2451679	TMZ004	Umzikhulu Informal Settlement Retic	Combined THM Ratio*	0.40	-	-
14-Aug-25	2451677	TMZ004	Umzikhulu Informal Settlement Retic	Conductivity	12.1	±1.5%	mS/m
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Cr (T)*	<5.00	±5.3%	µg Cr/L
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Cu (AE)	<0.05	±4.1%	mg Cu/L
14-Aug-25	2451671	TMZ004	Umzikhulu Informal Settlement Retic	E.coli*	0	±14%	MPN/100mL
14-Aug-25	2451677	TMZ004	Umzikhulu Informal Settlement Retic	F	<100	±5.3%	µg F/L
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Fe (AE)	0.02	±5.4%	mg Fe/L
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Hg (AE)*	<1.00	±6.5%	µg Hg/L
14-Aug-25	2451671	TMZ004	Umzikhulu Informal Settlement Retic	HPC 37*	3	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Mn (AE)	<0.01	±6.2%	mg Mn/L
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Na (AE)	9.40	±7.5%	mg Na/L
14-Aug-25	2451677	TMZ004	Umzikhulu Informal Settlement Retic	NH3*	0.22	±5.5%	mg N/L
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Ni (AE)	<10.0	±5.9%	µg Ni/L
14-Aug-25	2451677	TMZ004	Umzikhulu Informal Settlement Retic	NO2*	<0.10	±2.4%	mg N/L
14-Aug-25	2451677	TMZ004	Umzikhulu Informal Settlement Retic	NO3*	0.29	±2.9%	mg N/L
14-Aug-25	2451675	TMZ004	Umzikhulu Informal Settlement Retic	Odour*	Nil	-	-
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Pb (AE)	<4.00	±6.7%	µg Pb/L
14-Aug-25	2451670	TMZ004	Umzikhulu Informal Settlement Retic	pH OS*	7.50	-	-
14-Aug-25	2451676	TMZ004	Umzikhulu Informal Settlement Retic	Phenols*	<10.0	-	µg/L
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Sb (AE)*	<5.00	±7%	µg Sb/L
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Se (AE)*	<5.00	±7.7%	µg Se/L
14-Aug-25	2451677	TMZ004	Umzikhulu Informal Settlement Retic	SO4*	2.07	±1.8%	mg SO4/L
14-Aug-25	2451675	TMZ004	Umzikhulu Informal Settlement Retic	SS	<10.0	±3.7%	mg /L
14-Aug-25	2451675	TMZ004	Umzikhulu Informal Settlement Retic	TDS	89.00	±2.5%	mg /L
14-Aug-25	2451670	TMZ004	Umzikhulu Informal Settlement Retic	Temperature OS*	19.3	-	°C
14-Aug-25	2451675	TMZ004	Umzikhulu Informal Settlement Retic	TOC	<1.00	±5%	mg C/L
14-Aug-25	2451675	TMZ004	Umzikhulu Informal Settlement Retic	Turbidity	1.6	±6.1%	NTU
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	U (AE)*	<10.0	±7.6%	µg U/L
14-Aug-25	2451678	TMZ004	Umzikhulu Informal Settlement Retic	Zn (AE)	<0.03	±7.2%	mg Zn/L
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Al (AE)	120	±7.6%	µg Al/L
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	As (AE)*	<5.00	±7.5%	µg As/L
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	B (AE)	<25.0	±6.6%	µg B/L
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Ba (AE)	14.7	±6.9%	µg Ba/L
14-Aug-25	2451680	TMZ005	Umzimkhulu Local Municipality Offices	Batch No.*	20250201	-	-
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Cd (AE)	<1.00	±6%	µg Cd/L
14-Aug-25	2451689	TMZ005	Umzimkhulu Local Municipality Offices	CHBr3	<10	±6.4%	µg/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

14-Aug-25	2451689	TMZ005	Umzimkhulu Local Municipality Offices	CHCl ₂ Br	<10	±5.7%	µg/L
14-Aug-25	2451689	TMZ005	Umzimkhulu Local Municipality Offices	CHCl ₃	<10	±6%	µg/L
14-Aug-25	2451689	TMZ005	Umzimkhulu Local Municipality Offices	CHClBr ₂	<10	±5.3%	µg/L
14-Aug-25	2451687	TMZ005	Umzimkhulu Local Municipality Offices	Cl*	6.68	±1.8%	mg Cl/L
14-Aug-25	2451680	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (F) OS*	0.70	-	mg Cl ₂ /L
14-Aug-25	2451680	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (T) OS*	0.78	-	mg Cl ₂ /L
14-Aug-25	2451684	TMZ005	Umzimkhulu Local Municipality Offices	CN (T)	<25.0	±8.6%	µg CN/L
14-Aug-25	2451681	TMZ005	Umzimkhulu Local Municipality Offices	Coliforms*	0	±15%	MPN/100mL
14-Aug-25	2451681	TMZ005	Umzimkhulu Local Municipality Offices	Coliphages*	0	±8%	PFU/10ml
14-Aug-25	2451680	TMZ005	Umzimkhulu Local Municipality Offices	Coll Time OS*	08:52	-	-
14-Aug-25	2451687	TMZ005	Umzimkhulu Local Municipality Offices	Combined NO ₃ + NO ₂ ratio*	0.14	-	-
14-Aug-25	2451689	TMZ005	Umzimkhulu Local Municipality Offices	Combined THM Ratio*	<0.40	-	-
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Cr (T)*	<5.00	±5.3%	µg Cr/L
14-Aug-25	2451681	TMZ005	Umzimkhulu Local Municipality Offices	E.coli*	0	±14%	MPN/100mL
14-Aug-25	2451687	TMZ005	Umzimkhulu Local Municipality Offices	F	122	±5.3%	µg F/L
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Fe (AE)	0.03	±5.4%	mg Fe/L
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Hg (AE)*	<1.00	±6.5%	µg Hg/L
14-Aug-25	2451681	TMZ005	Umzimkhulu Local Municipality Offices	HPC 37*	0	±21%	cfu/mL
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Mn (AE)	<0.01	±6.2%	mg Mn/L
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Na (AE)	9.36	±7.5%	mg Na/L
14-Aug-25	2451687	TMZ005	Umzimkhulu Local Municipality Offices	NH ₃ *	0.85	±5.5%	mg N/L
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Ni (AE)	<10.0	±5.9%	µg Ni/L
14-Aug-25	2451687	TMZ005	Umzimkhulu Local Municipality Offices	NO ₂ *	<0.10	±2.4%	mg N/L
14-Aug-25	2451687	TMZ005	Umzimkhulu Local Municipality Offices	NO ₃ *	0.29	±2.9%	mg N/L
14-Aug-25	2451685	TMZ005	Umzimkhulu Local Municipality Offices	Odour*	Mild Chlorinous	-	-
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Pb (AE)	<4.00	±6.7%	µg Pb/L
14-Aug-25	2451680	TMZ005	Umzimkhulu Local Municipality Offices	pH OS*	7.40	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

14-Aug-25	2451686	TMZ005	Umzimkhulu Local Municipality Offices	Phenols*	<10.0	-	µg/L
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Sb (AE)*	<5.00	±7%	µg Sb/L
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Se (AE)*	<5.00	±7.7%	µg Se/L
14-Aug-25	2451687	TMZ005	Umzimkhulu Local Municipality Offices	SO ₄ *	1.98	±1.8%	mg SO ₄ /L
14-Aug-25	2451685	TMZ005	Umzimkhulu Local Municipality Offices	SS	<10.0	±3.7%	mg /L
14-Aug-25	2451685	TMZ005	Umzimkhulu Local Municipality Offices	TDS	82.00	±2.5%	mg /L
14-Aug-25	2451680	TMZ005	Umzimkhulu Local Municipality Offices	Temperature OS*	18.2	-	°C
14-Aug-25	2451685	TMZ005	Umzimkhulu Local Municipality Offices	TOC	<1.00	±5%	mg C/L
14-Aug-25	2451685	TMZ005	Umzimkhulu Local Municipality Offices	Turbidity	1.2	±6.1%	NTU
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	U (AE)*	<10.0	±7.6%	µg U/L
14-Aug-25	2451688	TMZ005	Umzimkhulu Local Municipality Offices	Zn (AE)	<0.03	±7.2%	mg Zn/L
14-Aug-25	2451690	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Batch No.*	20250201	-	-
14-Aug-25	2451690	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (F) OS*	0.46	-	mg Cl ₂ /L
14-Aug-25	2451690	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (T) OS*	0.58	-	mg Cl ₂ /L
14-Aug-25	2451691	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
14-Aug-25	2451690	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coll Time OS*	08:30	-	-
14-Aug-25	2451693	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
14-Aug-25	2451694	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Conductivity	12.3	±1.5%	mS/m
14-Aug-25	2451691	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
14-Aug-25	2451691	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	HPC 37*	2	±21%	cfu/mL
14-Aug-25	2451690	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	pH OS*	7.30	-	-
14-Aug-25	2451690	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Temperature OS*	17.3	-	°C
14-Aug-25	2451693	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Turbidity	0.6	±6.1%	NTU
14-Aug-25	2451695	TMZ007	Umzimkhulu Local FET College	Batch No.*	20250201	-	-
14-Aug-25	2451695	TMZ007	Umzimkhulu Local FET College	Cl ₂ (F) OS*	0.22	-	mg Cl ₂ /L
14-Aug-25	2451695	TMZ007	Umzimkhulu Local FET College	Cl ₂ (T) OS*	0.32	-	mg Cl ₂ /L
14-Aug-25	2451695	TMZ007	Umzimkhulu Local FET College	Coll Time OS*	07:45	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

14-Aug-25	2451696	TMZ007	Umzimkhulu Local FET College	HPC 37*	0	±21%	cfu/mL
14-Aug-25	2451695	TMZ007	Umzimkhulu Local FET College	Temperature OS*	15.5	-	°C
14-Aug-25	2451698	TMZ007	Umzimkhulu Local FET College	Turbidity	252.0	±6.1%	NTU
14-Aug-25	2452400	TNO002	Nokweja Final	Al (AE)	286	±7.6%	µg Al/L
14-Aug-25	2452395	TNO002	Nokweja Final	Batch No.*	20250201	-	-
14-Aug-25	2452395	TNO002	Nokweja Final	Cl ₂ (F) OS*	1.60	-	mg Cl ₂ /L
14-Aug-25	2452395	TNO002	Nokweja Final	Cl ₂ (T) OS*	1.72	-	mg Cl ₂ /L
14-Aug-25	2452396	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
14-Aug-25	2452396	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
14-Aug-25	2452395	TNO002	Nokweja Final	Coll Time OS*	06:58	-	-
14-Aug-25	2452398	TNO002	Nokweja Final	Colour	1.50	±6.5%	mg Pt-Co/L
14-Aug-25	2452399	TNO002	Nokweja Final	Conductivity	12.1	±1.5%	mS/m
14-Aug-25	2452396	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
14-Aug-25	2452396	TNO002	Nokweja Final	HPC 37*	8	±21%	cfu/mL
14-Aug-25	2452398	TNO002	Nokweja Final	Odour*	Mild Chlorinous	-	-
14-Aug-25	2452395	TNO002	Nokweja Final	pH OS*	7.30	-	-
14-Aug-25	2452395	TNO002	Nokweja Final	Temperature OS*	16.4	-	°C
14-Aug-25	2452398	TNO002	Nokweja Final	Turbidity	5.7	±6.1%	NTU
14-Aug-25	2452444	TWA002	Washbank Final	Al (AE)	263	±7.6%	µg Al/L
14-Aug-25	2452439	TWA002	Washbank Final	Batch No.*	20250201	-	-
14-Aug-25	2452439	TWA002	Washbank Final	Cl ₂ (F) OS*	0.77	-	mg Cl ₂ /L
14-Aug-25	2452439	TWA002	Washbank Final	Cl ₂ (T) OS*	0.89	-	mg Cl ₂ /L
14-Aug-25	2452440	TWA002	Washbank Final	Coliforms*	>201	±15%	MPN/100mL
14-Aug-25	2452439	TWA002	Washbank Final	Coll Time OS*	07:00	-	-
14-Aug-25	2452442	TWA002	Washbank Final	Colour	3.00	±6.5%	mg Pt-Co/L
14-Aug-25	2452443	TWA002	Washbank Final	Conductivity	7.63	±1.5%	mS/m
14-Aug-25	2452440	TWA002	Washbank Final	E.coli*	48	±14%	MPN/100mL
14-Aug-25	2452440	TWA002	Washbank Final	HPC 37*	40	±21%	cfu/mL
14-Aug-25	2452442	TWA002	Washbank Final	Odour*	Nil	-	-
14-Aug-25	2452439	TWA002	Washbank Final	pH OS*	7.30	-	-
14-Aug-25	2452439	TWA002	Washbank Final	Temperature OS*	16.5	-	°C
14-Aug-25	2452442	TWA002	Washbank Final	Turbidity	6.6	±6.1%	NTU
15-Aug-25	2452652	TIB002	Ibisi Final	Al (AE)	72.2	±7.6%	µg Al/L
15-Aug-25	2452647	TIB002	Ibisi Final	Batch No.*	20250201	-	-
15-Aug-25	2452647	TIB002	Ibisi Final	Cl ₂ (F) OS*	0.46	-	mg Cl ₂ /L
15-Aug-25	2452647	TIB002	Ibisi Final	Cl ₂ (T) OS*	0.78	-	mg Cl ₂ /L
15-Aug-25	2452648	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
15-Aug-25	2452648	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
15-Aug-25	2452647	TIB002	Ibisi Final	Coll Time OS*	6:25	-	-
15-Aug-25	2452650	TIB002	Ibisi Final	Colour	1.10	±6.5%	mg Pt-Co/L
15-Aug-25	2452651	TIB002	Ibisi Final	Conductivity	12.7	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

15-Aug-25	2452648	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
15-Aug-25	2452648	TIB002	Ibisi Final	HPC 37*	1	±21%	cfu/mL
15-Aug-25	2452650	TIB002	Ibisi Final	Odour*	Nil	-	-
15-Aug-25	2452647	TIB002	Ibisi Final	pH OS*	7.40	-	-
15-Aug-25	2452647	TIB002	Ibisi Final	Temperature OS*	16.2	-	°C
15-Aug-25	2452650	TIB002	Ibisi Final	Turbidity	1.1	±6.1%	NTU
15-Aug-25	2452653	TIB003	Ibisi Police Station Reticulation	Batch No.*	20250201	-	-
15-Aug-25	2452653	TIB003	Ibisi Police Station Reticulation	Cl ₂ (F) OS*	0.40	-	mg Cl ₂ /L
15-Aug-25	2452653	TIB003	Ibisi Police Station Reticulation	Cl ₂ (T) OS*	0.48	-	mg Cl ₂ /L
15-Aug-25	2452654	TIB003	Ibisi Police Station Reticulation	Coliforms*	0	±15%	MPN/100mL
15-Aug-25	2452653	TIB003	Ibisi Police Station Reticulation	Coll Time OS*	6:28	-	-
15-Aug-25	2452654	TIB003	Ibisi Police Station Reticulation	E.coli*	0	±14%	MPN/100mL
15-Aug-25	2452654	TIB003	Ibisi Police Station Reticulation	HPC 37*	0	±21%	cfu/mL
15-Aug-25	2452653	TIB003	Ibisi Police Station Reticulation	pH OS*	7.30	-	-
15-Aug-25	2452653	TIB003	Ibisi Police Station Reticulation	Temperature OS*	15.9	-	°C
15-Aug-25	2452656	TIB003	Ibisi Police Station Reticulation	Turbidity	0.9	±6.1%	NTU
15-Aug-25	2452666	TRT002	Rietvlei Final	Al (AE)	350	±7.6%	µg Al/L
15-Aug-25	2452661	TRT002	Rietvlei Final	Batch No.*	20250201	-	-
15-Aug-25	2452661	TRT002	Rietvlei Final	Cl ₂ (F) OS*	0.70	-	mg Cl ₂ /L
15-Aug-25	2452661	TRT002	Rietvlei Final	Cl ₂ (T) OS*	0.77	-	mg Cl ₂ /L
15-Aug-25	2452662	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
15-Aug-25	2452661	TRT002	Rietvlei Final	Coll Time OS*	5:10	-	-
15-Aug-25	2452665	TRT002	Rietvlei Final	Conductivity	21.1	±1.5%	mS/m
15-Aug-25	2452662	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
15-Aug-25	2452666	TRT002	Rietvlei Final	Fe (AE)	0.06	±5.4%	mg Fe/L
15-Aug-25	2452662	TRT002	Rietvlei Final	HPC 37*	5	±21%	cfu/mL
15-Aug-25	2452666	TRT002	Rietvlei Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
15-Aug-25	2452664	TRT002	Rietvlei Final	Odour*	Nil	-	-
15-Aug-25	2452661	TRT002	Rietvlei Final	pH OS*	7.40	-	-
15-Aug-25	2452661	TRT002	Rietvlei Final	Temperature OS*	13.9	-	°C
15-Aug-25	2452664	TRT002	Rietvlei Final	Turbidity	2.1	±6.1%	NTU
15-Aug-25	2452667	TRT004	Rietvlei Hospital Reticulation	Batch No.*	20250201	-	-
15-Aug-25	2452667	TRT004	Rietvlei Hospital Reticulation	Cl ₂ (F) OS*	0.65	-	mg Cl ₂ /L
15-Aug-25	2452667	TRT004	Rietvlei Hospital Reticulation	Cl ₂ (T) OS*	0.70	-	mg Cl ₂ /L
15-Aug-25	2452668	TRT004	Rietvlei Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
15-Aug-25	2452667	TRT004	Rietvlei Hospital Reticulation	Coll Time OS*	5:12	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

15-Aug-25	2452668	TRT004	Rietvlei Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
15-Aug-25	2452668	TRT004	Rietvlei Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
15-Aug-25	2452667	TRT004	Rietvlei Hospital Reticulation	pH OS*	7.60	-	-
15-Aug-25	2452667	TRT004	Rietvlei Hospital Reticulation	Temperature OS*	15.3	-	°C
15-Aug-25	2452670	TRT004	Rietvlei Hospital Reticulation	Turbidity	3.3	±6.1%	NTU
19-Aug-25	2455367	TJO001	Jolivet RRT frn Vulamehlo	Batch No.*	20250401	-	-
19-Aug-25	2455367	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (F) OS*	0.29	-	mg Cl2/L
19-Aug-25	2455367	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (T) OS*	0.37	-	mg Cl2/L
19-Aug-25	2455368	TJO001	Jolivet RRT frn Vulamehlo	Coliforms*	0	±15%	MPN/100mL
19-Aug-25	2455367	TJO001	Jolivet RRT frn Vulamehlo	Coll Time OS*	07:26	-	-
19-Aug-25	2455368	TJO001	Jolivet RRT frn Vulamehlo	E.coli*	0	±14%	MPN/100mL
19-Aug-25	2455368	TJO001	Jolivet RRT frn Vulamehlo	HPC 37*	0	±21%	cfu/mL
19-Aug-25	2455367	TJO001	Jolivet RRT frn Vulamehlo	pH OS*	8.05	-	-
19-Aug-25	2455367	TJO001	Jolivet RRT frn Vulamehlo	Temperature OS*	17.2	-	°C
19-Aug-25	2455370	TJO001	Jolivet RRT frn Vulamehlo	Turbidity	1.0	±6.1%	NTU
19-Aug-25	2455419	TQU002	Mnqumeni Final	Al (AE)	75.7	±7.6%	µg Al/L
19-Aug-25	2455414	TQU002	Mnqumeni Final	Batch No.*	20250201	-	-
19-Aug-25	2455414	TQU002	Mnqumeni Final	Cl2 (F) OS*	0.80	-	mg Cl2/L
19-Aug-25	2455414	TQU002	Mnqumeni Final	Cl2 (T) OS*	0.86	-	mg Cl2/L
19-Aug-25	2455415	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
19-Aug-25	2455414	TQU002	Mnqumeni Final	Coll Time OS*	6:29	-	-
19-Aug-25	2455418	TQU002	Mnqumeni Final	Conductivity	15.5	±1.5%	mS/m
19-Aug-25	2455415	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
19-Aug-25	2455419	TQU002	Mnqumeni Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
19-Aug-25	2455415	TQU002	Mnqumeni Final	HPC 37*	0	±21%	cfu/mL
19-Aug-25	2455419	TQU002	Mnqumeni Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
19-Aug-25	2455417	TQU002	Mnqumeni Final	Odour*	Mild Chlorinous	-	-
19-Aug-25	2455414	TQU002	Mnqumeni Final	pH OS*	7.40	-	-
19-Aug-25	2455417	TQU002	Mnqumeni Final	Taste*	Nil	-	-
19-Aug-25	2455414	TQU002	Mnqumeni Final	Temperature OS*	14.2	-	°C
19-Aug-25	2455417	TQU002	Mnqumeni Final	Turbidity	<0.2	±6.1%	NTU
19-Aug-25	2455430	TSQ002	Esiqanduleni Final	Al (AE)	244	±7.6%	µg Al/L
19-Aug-25	2455425	TSQ002	Esiqanduleni Final	Batch No.*	20250201	-	-
19-Aug-25	2455425	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	1.20	-	mg Cl2/L
19-Aug-25	2455425	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	1.36	-	mg Cl2/L
19-Aug-25	2455426	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

19-Aug-25	2455425	TSQ002	Esiqanduleni Final	Coll Time OS*	7:40	-	-
19-Aug-25	2455429	TSQ002	Esiqanduleni Final	Conductivity	21.4	±1.5%	mS/m
19-Aug-25	2455426	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
19-Aug-25	2455426	TSQ002	Esiqanduleni Final	HPC 37*	1	±21%	cfu/mL
19-Aug-25	2455425	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
19-Aug-25	2455425	TSQ002	Esiqanduleni Final	Temperature OS*	12.4	-	°C
19-Aug-25	2455428	TSQ002	Esiqanduleni Final	Turbidity	2.9	±6.1%	NTU
20-Aug-25	2455920	TBU002	Bulwer Final	Batch No.*	20250201	-	-
20-Aug-25	2455920	TBU002	Bulwer Final	Cl ₂ (F) OS*	1.32	-	mg Cl ₂ /L
20-Aug-25	2455920	TBU002	Bulwer Final	Cl ₂ (T) OS*	1.39	-	mg Cl ₂ /L
20-Aug-25	2455921	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
20-Aug-25	2455920	TBU002	Bulwer Final	Coll Time OS*	10:20	-	-
20-Aug-25	2455924	TBU002	Bulwer Final	Conductivity	6.25	±1.5%	mS/m
20-Aug-25	2455921	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
20-Aug-25	2455925	TBU002	Bulwer Final	Fe (AE)	0.33	±5.4%	mg Fe/L
20-Aug-25	2455921	TBU002	Bulwer Final	HPC 37*	5	±21%	cfu/mL
20-Aug-25	2455920	TBU002	Bulwer Final	pH OS*	7.40	-	-
20-Aug-25	2455920	TBU002	Bulwer Final	Temperature OS*	16.1	-	°C
20-Aug-25	2455923	TBU002	Bulwer Final	Turbidity	3.8	±6.1%	NTU
20-Aug-25	2455936	TCR002	Creighton Final	Al (AE)	118	±7.6%	µg Al/L
20-Aug-25	2455931	TCR002	Creighton Final	Batch No.*	20250201	-	-
20-Aug-25	2455931	TCR002	Creighton Final	Cl ₂ (F) OS*	0.55	-	mg Cl ₂ /L
20-Aug-25	2455931	TCR002	Creighton Final	Cl ₂ (T) OS*	0.66	-	mg Cl ₂ /L
20-Aug-25	2455932	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
20-Aug-25	2455931	TCR002	Creighton Final	Coll Time OS*	7.3	-	-
20-Aug-25	2455934	TCR002	Creighton Final	Colour	<1.00	±6.5%	mg Pt-Co/L
20-Aug-25	2455935	TCR002	Creighton Final	Conductivity	9.31	±1.5%	mS/m
20-Aug-25	2455932	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
20-Aug-25	2455936	TCR002	Creighton Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
20-Aug-25	2455932	TCR002	Creighton Final	HPC 37*	0	±21%	cfu/mL
20-Aug-25	2455936	TCR002	Creighton Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
20-Aug-25	2455934	TCR002	Creighton Final	Odour*	Nil	-	-
20-Aug-25	2455931	TCR002	Creighton Final	pH OS*	7.30	-	-
20-Aug-25	2455934	TCR002	Creighton Final	Taste*	Nil	-	-
20-Aug-25	2455931	TCR002	Creighton Final	Temperature OS*	14.6	-	°C
20-Aug-25	2455934	TCR002	Creighton Final	Turbidity	<0.2	±6.1%	NTU
20-Aug-25	2455956	TMAN002	Mangwaneni Final	Batch No.*	20250201	-	-
20-Aug-25	2455956	TMAN002	Mangwaneni Final	Cl ₂ (F) OS*	0.47	-	mg Cl ₂ /L
20-Aug-25	2455956	TMAN002	Mangwaneni Final	Cl ₂ (T) OS*	0.56	-	mg Cl ₂ /L
20-Aug-25	2455957	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
20-Aug-25	2455956	TMAN002	Mangwaneni Final	Coll Time OS*	10:49	-	-
20-Aug-25	2455960	TMAN002	Mangwaneni Final	Conductivity	12.8	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

20-Aug-25	2455957	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
20-Aug-25	2455961	TMAN002	Mangwaneni Final	Fe (AE)	0.08	±5.4%	mg Fe/L
20-Aug-25	2455957	TMAN002	Mangwaneni Final	HPC 37*	2	±21%	cfu/mL
20-Aug-25	2455956	TMAN002	Mangwaneni Final	pH OS*	7.40	-	-
20-Aug-25	2455956	TMAN002	Mangwaneni Final	Temperature OS*	14.2	-	°C
20-Aug-25	2455959	TMAN002	Mangwaneni Final	Turbidity	1.2	±6.1%	NTU
20-Aug-25	2455967	TMQA002	Mqatsheni Final	Batch No.*	20250201	-	-
20-Aug-25	2455967	TMQA002	Mqatsheni Final	Cl ₂ (F) OS*	1.42	-	mg Cl ₂ /L
20-Aug-25	2455967	TMQA002	Mqatsheni Final	Cl ₂ (T) OS*	1.60	-	mg Cl ₂ /L
20-Aug-25	2455968	TMQA002	Mqatsheni Final	Coliforms*	36	±15%	MPN/100mL
20-Aug-25	2455967	TMQA002	Mqatsheni Final	Coll Time OS*	08:28	-	-
20-Aug-25	2455971	TMQA002	Mqatsheni Final	Conductivity	27.7	±1.5%	mS/m
20-Aug-25	2455968	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
20-Aug-25	2455968	TMQA002	Mqatsheni Final	HPC 37*	1	±21%	cfu/mL
20-Aug-25	2455967	TMQA002	Mqatsheni Final	pH OS*	8.70	-	-
20-Aug-25	2455967	TMQA002	Mqatsheni Final	Temperature OS*	18.3	-	°C
20-Aug-25	2455970	TMQA002	Mqatsheni Final	Turbidity	0.9	±6.1%	NTU
20-Aug-25	2455977	TRV002	Riverside Final	Batch No.*	20250201	-	-
20-Aug-25	2455977	TRV002	Riverside Final	Cl ₂ (F) OS*	1.04	-	mg Cl ₂ /L
20-Aug-25	2455977	TRV002	Riverside Final	Cl ₂ (T) OS*	1.56	-	mg Cl ₂ /L
20-Aug-25	2455978	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
20-Aug-25	2455977	TRV002	Riverside Final	Coll Time OS*	07:59	-	-
20-Aug-25	2455981	TRV002	Riverside Final	Conductivity	11.2	±1.5%	mS/m
20-Aug-25	2455978	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
20-Aug-25	2455978	TRV002	Riverside Final	HPC 37*	0	±21%	cfu/mL
20-Aug-25	2455977	TRV002	Riverside Final	pH OS*	7.30	-	-
20-Aug-25	2455977	TRV002	Riverside Final	Temperature OS*	13.2	-	°C
20-Aug-25	2455980	TRV002	Riverside Final	Turbidity	1.6	±6.1%	NTU
20-Aug-25	2455987	TST002	St Appollinaris Final	Batch No.*	20250201	-	-
20-Aug-25	2455987	TST002	St Appollinaris Final	Cl ₂ (F) OS*	0.52	-	mg Cl ₂ /L
20-Aug-25	2455987	TST002	St Appollinaris Final	Cl ₂ (T) OS*	0.79	-	mg Cl ₂ /L
20-Aug-25	2455988	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
20-Aug-25	2455987	TST002	St Appollinaris Final	Coll Time OS*	09:34	-	-
20-Aug-25	2455991	TST002	St Appollinaris Final	Conductivity	9.43	±1.5%	mS/m
20-Aug-25	2455988	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
20-Aug-25	2455988	TST002	St Appollinaris Final	HPC 37*	0	±21%	cfu/mL
20-Aug-25	2455987	TST002	St Appollinaris Final	pH OS*	7.40	-	-
20-Aug-25	2455987	TST002	St Appollinaris Final	Temperature OS*	13.8	-	°C
20-Aug-25	2455990	TST002	St Appollinaris Final	Turbidity	2.0	±6.1%	NTU
20-Aug-25	2455992	TST003	St Appollinaris Hospital Reticulation	Batch No.*	20250201	-	-
20-Aug-25	2455992	TST003	St Appollinaris Hospital Reticulation	Cl ₂ (F) OS*	0.30	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

20-Aug-25	2455992	TST003	St Appollinaris Hospital Reticulation	Cl ₂ (T) OS*	0.37	-	mg Cl ₂ /L
20-Aug-25	2455993	TST003	St Appollinaris Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
20-Aug-25	2455992	TST003	St Appollinaris Hospital Reticulation	Coll Time OS*	09:00	-	-
20-Aug-25	2455995	TST003	St Appollinaris Hospital Reticulation	Colour	1.40	±6.5%	mg Pt-Co/L
20-Aug-25	2455996	TST003	St Appollinaris Hospital Reticulation	Conductivity	9.37	±1.5%	mS/m
20-Aug-25	2455993	TST003	St Appollinaris Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
20-Aug-25	2455993	TST003	St Appollinaris Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
20-Aug-25	2455995	TST003	St Appollinaris Hospital Reticulation	Odour*	Nil	-	-
20-Aug-25	2455992	TST003	St Appollinaris Hospital Reticulation	pH OS*	7.20	-	-
20-Aug-25	2455992	TST003	St Appollinaris Hospital Reticulation	Temperature OS*	13.4	-	°C
20-Aug-25	2455995	TST003	St Appollinaris Hospital Reticulation	Turbidity	2.0	±6.1%	NTU
20-Aug-25	2456007	TUN002	Underberg Final	Al (AE)	<25.0	±7.6%	µg Al/L
20-Aug-25	2456002	TUN002	Underberg Final	Batch No.*	20250201	-	-
20-Aug-25	2456002	TUN002	Underberg Final	Cl ₂ (F) OS*	0.34	-	mg Cl ₂ /L
20-Aug-25	2456002	TUN002	Underberg Final	Cl ₂ (T) OS*	0.42	-	mg Cl ₂ /L
20-Aug-25	2456003	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
20-Aug-25	2456002	TUN002	Underberg Final	Coll Time OS*	09:20	-	-
20-Aug-25	2456006	TUN002	Underberg Final	Conductivity	6.66	±1.5%	mS/m
20-Aug-25	2456003	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
20-Aug-25	2456003	TUN002	Underberg Final	HPC 37*	0	±21%	cfu/mL
20-Aug-25	2456002	TUN002	Underberg Final	pH OS*	7.20	-	-
20-Aug-25	2456002	TUN002	Underberg Final	Temperature OS*	13.0	-	°C
20-Aug-25	2456005	TUN002	Underberg Final	Turbidity	0.5	±6.1%	NTU
21-Aug-25	2454824	TFR002	Franklin Final	Al (AE)	210	±7.6%	µg Al/L
21-Aug-25	2454819	TFR002	Franklin Final	Batch No.*	20250201	-	-
21-Aug-25	2454819	TFR002	Franklin Final	Cl ₂ (F) OS*	1.09	-	mg Cl ₂ /L
21-Aug-25	2454819	TFR002	Franklin Final	Cl ₂ (T) OS*	1.15	-	mg Cl ₂ /L
21-Aug-25	2454820	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
21-Aug-25	2454820	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
21-Aug-25	2454819	TFR002	Franklin Final	Coll Time OS*	07:13	-	-
21-Aug-25	2454823	TFR002	Franklin Final	Conductivity	14.3	±1.5%	mS/m
21-Aug-25	2454820	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
21-Aug-25	2454820	TFR002	Franklin Final	HPC 37*	0	±21%	cfu/mL
21-Aug-25	2454822	TFR002	Franklin Final	Odour*	Mild Chlorinous	-	-
21-Aug-25	2454819	TFR002	Franklin Final	pH OS*	7.30	-	-
21-Aug-25	2454819	TFR002	Franklin Final	Temperature OS*	15.3	-	°C
21-Aug-25	2454822	TFR002	Franklin Final	Turbidity	1.4	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

21-Aug-25	2454835	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
21-Aug-25	2454830	TKK002	Kokstad Final	Batch No.*	20250201	-	-
21-Aug-25	2454830	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.58	-	mg Cl ₂ /L
21-Aug-25	2454830	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.72	-	mg Cl ₂ /L
21-Aug-25	2454831	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
21-Aug-25	2454831	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
21-Aug-25	2454830	TKK002	Kokstad Final	Coll Time OS*	08:05	-	-
21-Aug-25	2454834	TKK002	Kokstad Final	Conductivity	14.3	±1.5%	mS/m
21-Aug-25	2454831	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
21-Aug-25	2454835	TKK002	Kokstad Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
21-Aug-25	2454831	TKK002	Kokstad Final	HPC 37*	2	±21%	cfu/mL
21-Aug-25	2454830	TKK002	Kokstad Final	pH OS*	7.40	-	-
21-Aug-25	2454830	TKK002	Kokstad Final	Temperature OS*	14.9	-	°C
21-Aug-25	2454833	TKK002	Kokstad Final	Turbidity	0.3	±6.1%	NTU
21-Aug-25	2454841	TKK011	Kokstad Hospital Reticulation	Batch No.*	20250201	-	-
21-Aug-25	2454841	TKK011	Kokstad Hospital Reticulation	Cl ₂ (F) OS*	0.56	-	mg Cl ₂ /L
21-Aug-25	2454841	TKK011	Kokstad Hospital Reticulation	Cl ₂ (T) OS*	0.69	-	mg Cl ₂ /L
21-Aug-25	2454842	TKK011	Kokstad Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
21-Aug-25	2454841	TKK011	Kokstad Hospital Reticulation	Coll Time OS*	10:00	-	-
21-Aug-25	2454844	TKK011	Kokstad Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
21-Aug-25	2454845	TKK011	Kokstad Hospital Reticulation	Conductivity	14.5	±1.5%	mS/m
21-Aug-25	2454842	TKK011	Kokstad Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
21-Aug-25	2454842	TKK011	Kokstad Hospital Reticulation	HPC 37*	1	±21%	cfu/mL
21-Aug-25	2454841	TKK011	Kokstad Hospital Reticulation	pH OS*	7.40	-	-
21-Aug-25	2454841	TKK011	Kokstad Hospital Reticulation	Temperature OS*	19.7	-	°C
21-Aug-25	2454844	TKK011	Kokstad Hospital Reticulation	Turbidity	<0.2	±6.1%	NTU
21-Aug-25	2456529	TMZ002	Umzimkhulu Final	Al (AE)	83.8	±7.6%	µg Al/L
21-Aug-25	2456524	TMZ002	Umzimkhulu Final	Batch No.*	20250201	-	-
21-Aug-25	2456524	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	1.85	-	mg Cl ₂ /L
21-Aug-25	2456524	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	2.46	-	mg Cl ₂ /L
21-Aug-25	2456525	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
21-Aug-25	2456525	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
21-Aug-25	2456524	TMZ002	Umzimkhulu Final	Coll Time OS*	07:00	-	-
21-Aug-25	2456527	TMZ002	Umzimkhulu Final	Colour	<1.00	±6.5%	mg Pt-Co/L
21-Aug-25	2456528	TMZ002	Umzimkhulu Final	Conductivity	12.4	±1.5%	mS/m
21-Aug-25	2456525	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
21-Aug-25	2456525	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

21-Aug-25	2456527	TMZ002	Umzimkhulu Final	Odour*	Mild Chlorinous	-	-
21-Aug-25	2456524	TMZ002	Umzimkhulu Final	pH OS*	7.30	-	-
21-Aug-25	2456527	TMZ002	Umzimkhulu Final	Taste*	Nil	-	-
21-Aug-25	2456524	TMZ002	Umzimkhulu Final	Temperature OS*	17.1	-	°C
21-Aug-25	2456527	TMZ002	Umzimkhulu Final	Turbidity	1.0	±6.1%	NTU
21-Aug-25	2454868	TNJU002	KwaNjunga Final	Batch No.*	20250201	-	-
21-Aug-25	2454868	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	0.95	-	mg Cl ₂ /L
21-Aug-25	2454868	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	1.05	-	mg Cl ₂ /L
21-Aug-25	2454869	TNJU002	KwaNjunga Final	Coliforms*	2	±15%	MPN/100mL
21-Aug-25	2454868	TNJU002	KwaNjunga Final	Coll Time OS*	06:25	-	-
21-Aug-25	2454872	TNJU002	KwaNjunga Final	Conductivity	18.8	±1.5%	mS/m
21-Aug-25	2454869	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
21-Aug-25	2454873	TNJU002	KwaNjunga Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
21-Aug-25	2454869	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	cfu/mL
21-Aug-25	2454873	TNJU002	KwaNjunga Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
21-Aug-25	2454871	TNJU002	KwaNjunga Final	Odour*	Mild Chlorinous	-	-
21-Aug-25	2454868	TNJU002	KwaNjunga Final	pH OS*	7.20	-	-
21-Aug-25	2454871	TNJU002	KwaNjunga Final	Taste*	Nil	-	-
21-Aug-25	2454868	TNJU002	KwaNjunga Final	Temperature OS*	16.9	-	°C
21-Aug-25	2454871	TNJU002	KwaNjunga Final	Turbidity	0.4	±6.1%	NTU
21-Aug-25	2456540	TNO002	Nokweja Final	Al (AE)	155	±7.6%	µg Al/L
21-Aug-25	2456535	TNO002	Nokweja Final	Batch No.*	20250201	-	-
21-Aug-25	2456535	TNO002	Nokweja Final	Cl ₂ (F) OS*	1.67	-	mg Cl ₂ /L
21-Aug-25	2456535	TNO002	Nokweja Final	Cl ₂ (T) OS*	1.75	-	mg Cl ₂ /L
21-Aug-25	2456536	TNO002	Nokweja Final	Coliforms*	9	±15%	MPN/100mL
21-Aug-25	2456536	TNO002	Nokweja Final	Coliphages*	5	±8%	PFU/10ml
21-Aug-25	2456535	TNO002	Nokweja Final	Coll Time OS*	06:28	-	-
21-Aug-25	2456539	TNO002	Nokweja Final	Conductivity	12.9	±1.5%	mS/m
21-Aug-25	2456536	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
21-Aug-25	2456536	TNO002	Nokweja Final	HPC 37*	25	±21%	cfu/mL
21-Aug-25	2456535	TNO002	Nokweja Final	pH OS*	7.30	-	-
21-Aug-25	2456535	TNO002	Nokweja Final	Temperature OS*	14.8	-	°C
21-Aug-25	2456538	TNO002	Nokweja Final	Turbidity	3.4	±6.1%	NTU
21-Aug-25	2456584	TWA002	Washbank Final	Al (AE)	308	±7.6%	µg Al/L
21-Aug-25	2456579	TWA002	Washbank Final	Batch No.*	20250201	-	-
21-Aug-25	2456579	TWA002	Washbank Final	Cl ₂ (F) OS*	0.46	-	mg Cl ₂ /L
21-Aug-25	2456579	TWA002	Washbank Final	Cl ₂ (T) OS*	0.49	-	mg Cl ₂ /L
21-Aug-25	2456580	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
21-Aug-25	2456579	TWA002	Washbank Final	Coll Time OS*	07:35	-	-
21-Aug-25	2456583	TWA002	Washbank Final	Conductivity	8.32	±1.5%	mS/m
21-Aug-25	2456580	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
21-Aug-25	2456580	TWA002	Washbank Final	HPC 37*	3	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

21-Aug-25	2456579	TWA002	Washbank Final	pH OS*	7.40	-	-
21-Aug-25	2456579	TWA002	Washbank Final	Temperature OS*	18.3	-	°C
21-Aug-25	2456582	TWA002	Washbank Final	Turbidity	6.2	±6.1%	NTU
22-Aug-25	2456866	TIB002	Ibisi Final	Al (AE)	167	±7.6%	µg Al/L
22-Aug-25	2456861	TIB002	Ibisi Final	Batch No.*	20250201	-	-
22-Aug-25	2456861	TIB002	Ibisi Final	Cl2 (F) OS*	0.56	-	mg Cl2/L
22-Aug-25	2456861	TIB002	Ibisi Final	Cl2 (T) OS*	0.71	-	mg Cl2/L
22-Aug-25	2456862	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
22-Aug-25	2456862	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
22-Aug-25	2456861	TIB002	Ibisi Final	Coll Time OS*	06:28	-	-
22-Aug-25	2456865	TIB002	Ibisi Final	Conductivity	12.0	±1.5%	mS/m
22-Aug-25	2456862	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
22-Aug-25	2456862	TIB002	Ibisi Final	HPC 37*	1	±21%	cfu/mL
22-Aug-25	2456861	TIB002	Ibisi Final	pH OS*	7.30	-	-
22-Aug-25	2456861	TIB002	Ibisi Final	Temperature OS*	14.2	-	°C
22-Aug-25	2456864	TIB002	Ibisi Final	Turbidity	3.4	±6.1%	NTU
22-Aug-25	2456871	TRT002	Rietvlei Final	Batch No.*	20250201	-	-
22-Aug-25	2456871	TRT002	Rietvlei Final	Cl2 (F) OS*	0.63	-	mg Cl2/L
22-Aug-25	2456871	TRT002	Rietvlei Final	Cl2 (T) OS*	0.80	-	mg Cl2/L
22-Aug-25	2456872	TRT002	Rietvlei Final	Coliforms*	>201	±15%	MPN/100mL
22-Aug-25	2456871	TRT002	Rietvlei Final	Coll Time OS*	05:55	-	-
22-Aug-25	2456875	TRT002	Rietvlei Final	Conductivity	16.6	±1.5%	mS/m
22-Aug-25	2456872	TRT002	Rietvlei Final	E.coli*	43	±14%	MPN/100mL
22-Aug-25	2456872	TRT002	Rietvlei Final	HPC 37*	223	±21%	cfu/mL
22-Aug-25	2456871	TRT002	Rietvlei Final	pH OS*	7.20	-	-
22-Aug-25	2456871	TRT002	Rietvlei Final	Temperature OS*	13.1	-	°C
22-Aug-25	2456874	TRT002	Rietvlei Final	Turbidity	4.2	±6.1%	NTU
25-Aug-25	2458903	TFR002	Franklin Final	Al (AE)	214	±7.6%	µg Al/L
25-Aug-25	2458898	TFR002	Franklin Final	Batch No.*	20250201	-	-
25-Aug-25	2458898	TFR002	Franklin Final	Cl2 (F) OS*	0.60	-	mg Cl2/L
25-Aug-25	2458898	TFR002	Franklin Final	Cl2 (T) OS*	0.65	-	mg Cl2/L
25-Aug-25	2458899	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
25-Aug-25	2458899	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
25-Aug-25	2458898	TFR002	Franklin Final	Coll Time OS*	7:00	-	-
25-Aug-25	2458901	TFR002	Franklin Final	Colour	1.50	±6.5%	mg Pt-Co/L
25-Aug-25	2458902	TFR002	Franklin Final	Conductivity	14.3	±1.5%	mS/m
25-Aug-25	2458899	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
25-Aug-25	2458903	TFR002	Franklin Final	Fe (AE)	0.04	±5.4%	mg Fe/L
25-Aug-25	2458899	TFR002	Franklin Final	HPC 37*	0	±21%	cfu/mL
25-Aug-25	2458903	TFR002	Franklin Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
25-Aug-25	2458898	TFR002	Franklin Final	pH OS*	7.60	-	-
25-Aug-25	2458898	TFR002	Franklin Final	Temperature OS*	11.9	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

25-Aug-25	2458901	TFR002	Franklin Final	Turbidity	1.0	±6.1%	NTU
25-Aug-25	2458904	TFR003	Franklin Police Station Retic	Batch No.*	20250201	-	-
25-Aug-25	2458904	TFR003	Franklin Police Station Retic	Cl2 (F) OS*	0.40	-	mg Cl2/L
25-Aug-25	2458904	TFR003	Franklin Police Station Retic	Cl2 (T) OS*	0.45	-	mg Cl2/L
25-Aug-25	2458905	TFR003	Franklin Police Station Retic	Coliforms*	0	±15%	MPN/100mL
25-Aug-25	2458904	TFR003	Franklin Police Station Retic	Coll Time OS*	7:05	-	-
25-Aug-25	2458907	TFR003	Franklin Police Station Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Aug-25	2458908	TFR003	Franklin Police Station Retic	Conductivity	14.2	±1.5%	mS/m
25-Aug-25	2458905	TFR003	Franklin Police Station Retic	E.coli*	0	±14%	MPN/100mL
25-Aug-25	2458905	TFR003	Franklin Police Station Retic	HPC 37*	0	±21%	cfu/mL
25-Aug-25	2458907	TFR003	Franklin Police Station Retic	Odour*	Nil	-	-
25-Aug-25	2458904	TFR003	Franklin Police Station Retic	pH OS*	7.60	-	-
25-Aug-25	2458904	TFR003	Franklin Police Station Retic	Temperature OS*	12.9	-	°C
25-Aug-25	2458907	TFR003	Franklin Police Station Retic	Turbidity	1.2	±6.1%	NTU
25-Aug-25	2458919	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
25-Aug-25	2458914	TKK002	Kokstad Final	Batch No.*	20250201	-	-
25-Aug-25	2458914	TKK002	Kokstad Final	Cl2 (F) OS*	1.25	-	mg Cl2/L
25-Aug-25	2458914	TKK002	Kokstad Final	Cl2 (T) OS*	1.36	-	mg Cl2/L
25-Aug-25	2458915	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
25-Aug-25	2458915	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
25-Aug-25	2458914	TKK002	Kokstad Final	Coll Time OS*	8:00	-	-
25-Aug-25	2458917	TKK002	Kokstad Final	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Aug-25	2458918	TKK002	Kokstad Final	Conductivity	14.2	±1.5%	mS/m
25-Aug-25	2458915	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
25-Aug-25	2458915	TKK002	Kokstad Final	HPC 37*	0	±21%	cfu/mL
25-Aug-25	2458917	TKK002	Kokstad Final	Odour*	Nil	-	-
25-Aug-25	2458914	TKK002	Kokstad Final	pH OS*	7.50	-	-
25-Aug-25	2458917	TKK002	Kokstad Final	Taste*	Nil	-	-
25-Aug-25	2458914	TKK002	Kokstad Final	Temperature OS*	12.3	-	°C
25-Aug-25	2458917	TKK002	Kokstad Final	Turbidity	0.2	±6.1%	NTU
25-Aug-25	2458929	TKK006	Kokstad Bongweni Correctional Serv Retic	Batch No.*	20250201	-	-
25-Aug-25	2458929	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl2 (F) OS*	0.81	-	mg Cl2/L
25-Aug-25	2458929	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl2 (T) OS*	0.87	-	mg Cl2/L
25-Aug-25	2458930	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

25-Aug-25	2458929	TKK006	Kokstad Bongweni Correctional Serv Retic	Coll Time OS*	8:03	-	-
25-Aug-25	2458932	TKK006	Kokstad Bongweni Correctional Serv Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Aug-25	2458930	TKK006	Kokstad Bongweni Correctional Serv Retic	E.coli*	0	±14%	MPN/100mL
25-Aug-25	2458930	TKK006	Kokstad Bongweni Correctional Serv Retic	HPC 37*	0	±21%	cfu/mL
25-Aug-25	2458932	TKK006	Kokstad Bongweni Correctional Serv Retic	Odour*	Nil	-	-
25-Aug-25	2458929	TKK006	Kokstad Bongweni Correctional Serv Retic	pH OS*	7.10	-	-
25-Aug-25	2458932	TKK006	Kokstad Bongweni Correctional Serv Retic	Taste*	Nil	-	-
25-Aug-25	2458929	TKK006	Kokstad Bongweni Correctional Serv Retic	Temperature OS*	13.5	-	°C
25-Aug-25	2458932	TKK006	Kokstad Bongweni Correctional Serv Retic	Turbidity	0.2	±6.1%	NTU
25-Aug-25	2458933	TKK007	Kokstad Shayamoya Reticulation	Batch No.*	20250201	-	-
25-Aug-25	2458933	TKK007	Kokstad Shayamoya Reticulation	Cl2 (F) OS*	0.38	-	mg Cl2/L
25-Aug-25	2458933	TKK007	Kokstad Shayamoya Reticulation	Cl2 (T) OS*	0.49	-	mg Cl2/L
25-Aug-25	2458934	TKK007	Kokstad Shayamoya Reticulation	Coliforms*	0	±15%	MPN/100mL
25-Aug-25	2458933	TKK007	Kokstad Shayamoya Reticulation	Coll Time OS*	8:22	-	-
25-Aug-25	2458934	TKK007	Kokstad Shayamoya Reticulation	E.coli*	0	±14%	MPN/100mL
25-Aug-25	2458934	TKK007	Kokstad Shayamoya Reticulation	HPC 37*	0	±21%	cfu/mL
25-Aug-25	2458933	TKK007	Kokstad Shayamoya Reticulation	pH OS*	7.30	-	-
25-Aug-25	2458933	TKK007	Kokstad Shayamoya Reticulation	Temperature OS*	14.2	-	°C
25-Aug-25	2458936	TKK007	Kokstad Shayamoya Reticulation	Turbidity	<0.2	±6.1%	NTU
25-Aug-25	2458937	TKK009	Kokstad Farm Fresh Produce Market	Batch No.*	20250201	-	-
25-Aug-25	2458937	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (F) OS*	0.69	-	mg Cl2/L
25-Aug-25	2458937	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (T) OS*	0.77	-	mg Cl2/L
25-Aug-25	2458938	TKK009	Kokstad Farm Fresh Produce Market	Coliforms*	0	±15%	MPN/100mL
25-Aug-25	2458937	TKK009	Kokstad Farm Fresh Produce Market	Coll Time OS*	8:20	-	-
25-Aug-25	2458940	TKK009	Kokstad Farm Fresh Produce Market	Colour	1.10	±6.5%	mg Pt-Co/L
25-Aug-25	2458938	TKK009	Kokstad Farm Fresh Produce Market	E.coli*	0	±14%	MPN/100mL
25-Aug-25	2458938	TKK009	Kokstad Farm Fresh Produce Market	HPC 37*	0	±21%	cfu/mL
25-Aug-25	2458940	TKK009	Kokstad Farm Fresh Produce Market	Odour*	Nil	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

25-Aug-25	2458937	TKK009	Kokstad Farm Fresh Produce Market	pH OS*	7.00	-	-
25-Aug-25	2458940	TKK009	Kokstad Farm Fresh Produce Market	Taste*	Nil	-	-
25-Aug-25	2458937	TKK009	Kokstad Farm Fresh Produce Market	Temperature OS*	13.0	-	°C
25-Aug-25	2458940	TKK009	Kokstad Farm Fresh Produce Market	Turbidity	<0.2	±6.1%	NTU
25-Aug-25	2458941	TKK012	Kokstad FET College Reticulation	Batch No.*	20250201	-	-
25-Aug-25	2458941	TKK012	Kokstad FET College Reticulation	Cl2 (F) OS*	0.48	-	mg Cl2/L
25-Aug-25	2458941	TKK012	Kokstad FET College Reticulation	Cl2 (T) OS*	0.54	-	mg Cl2/L
25-Aug-25	2458942	TKK012	Kokstad FET College Reticulation	Coliforms*	0	±15%	MPN/100mL
25-Aug-25	2458941	TKK012	Kokstad FET College Reticulation	Coll Time OS*	7:54	-	-
25-Aug-25	2458942	TKK012	Kokstad FET College Reticulation	E.coli*	0	±14%	MPN/100mL
25-Aug-25	2458942	TKK012	Kokstad FET College Reticulation	HPC 37*	0	±21%	cfu/mL
25-Aug-25	2458941	TKK012	Kokstad FET College Reticulation	pH OS*	7.30	-	-
25-Aug-25	2458941	TKK012	Kokstad FET College Reticulation	Temperature OS*	11.1	-	°C
25-Aug-25	2458944	TKK012	Kokstad FET College Reticulation	Turbidity	0.2	±6.1%	NTU
25-Aug-25	2458967	TNJU002	KwaNjunga Final	Batch No.*	20250201	-	-
25-Aug-25	2458967	TNJU002	KwaNjunga Final	Cl2 (F) OS*	0.45	-	mg Cl2/L
25-Aug-25	2458967	TNJU002	KwaNjunga Final	Cl2 (T) OS*	0.51	-	mg Cl2/L
25-Aug-25	2458968	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
25-Aug-25	2458967	TNJU002	KwaNjunga Final	Coll Time OS*	6:22	-	-
25-Aug-25	2458971	TNJU002	KwaNjunga Final	Conductivity	18.9	±1.5%	mS/m
25-Aug-25	2458968	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
25-Aug-25	2458968	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	cfu/mL
25-Aug-25	2458967	TNJU002	KwaNjunga Final	pH OS*	7.20	-	-
25-Aug-25	2458967	TNJU002	KwaNjunga Final	Temperature OS*	16.4	-	°C
25-Aug-25	2458970	TNJU002	KwaNjunga Final	Turbidity	0.7	±6.1%	NTU
26-Aug-25	2459396	TQU002	Mnqumeni Final	Batch No.*	20250201	-	-
26-Aug-25	2459396	TQU002	Mnqumeni Final	Cl2 (F) OS*	1.36	-	mg Cl2/L
26-Aug-25	2459396	TQU002	Mnqumeni Final	Cl2 (T) OS*	1.58	-	mg Cl2/L
26-Aug-25	2459397	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
26-Aug-25	2459396	TQU002	Mnqumeni Final	Coll Time OS*	06:36	-	-
26-Aug-25	2459400	TQU002	Mnqumeni Final	Conductivity	15.6	±1.5%	mS/m
26-Aug-25	2459397	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
26-Aug-25	2459397	TQU002	Mnqumeni Final	HPC 37*	0	±21%	cfu/mL
26-Aug-25	2459396	TQU002	Mnqumeni Final	pH OS*	7.50	-	-
26-Aug-25	2459396	TQU002	Mnqumeni Final	Temperature OS*	14.2	-	°C
26-Aug-25	2459399	TQU002	Mnqumeni Final	Turbidity	0.9	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

26-Aug-25	2459401	TQU003	Mnqumeni Reticulation	Batch No.*	20250201	-	-
26-Aug-25	2459401	TQU003	Mnqumeni Reticulation	Cl2 (F) OS*	1.02	-	mg Cl2/L
26-Aug-25	2459401	TQU003	Mnqumeni Reticulation	Cl2 (T) OS*	1.09	-	mg Cl2/L
26-Aug-25	2459402	TQU003	Mnqumeni Reticulation	Coliforms*	0	±15%	MPN/100mL
26-Aug-25	2459401	TQU003	Mnqumeni Reticulation	Coll Time OS*	06:17	-	-
26-Aug-25	2459402	TQU003	Mnqumeni Reticulation	E.coli*	0	±14%	MPN/100mL
26-Aug-25	2459402	TQU003	Mnqumeni Reticulation	HPC 37*	0	±21%	cfu/mL
26-Aug-25	2459401	TQU003	Mnqumeni Reticulation	pH OS*	7.30	-	-
26-Aug-25	2459401	TQU003	Mnqumeni Reticulation	Temperature OS*	11.2	-	°C
26-Aug-25	2459404	TQU003	Mnqumeni Reticulation	Turbidity	1.2	±6.1%	NTU
26-Aug-25	2459415	TSQ002	Esiqanduleni Final	Al (AE)	31.2	±7.6%	µg Al/L
26-Aug-25	2459410	TSQ002	Esiqanduleni Final	Batch No.*	20250201	-	-
26-Aug-25	2459410	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	0.84	-	mg Cl2/L
26-Aug-25	2459410	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	0.99	-	mg Cl2/L
26-Aug-25	2459411	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
26-Aug-25	2459410	TSQ002	Esiqanduleni Final	Coll Time OS*	08:31	-	-
26-Aug-25	2459413	TSQ002	Esiqanduleni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Aug-25	2459414	TSQ002	Esiqanduleni Final	Conductivity	21.5	±1.5%	mS/m
26-Aug-25	2459411	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
26-Aug-25	2459411	TSQ002	Esiqanduleni Final	HPC 37*	0	±21%	cfu/mL
26-Aug-25	2459413	TSQ002	Esiqanduleni Final	Odour*	Mild Chlorinous	-	-
26-Aug-25	2459410	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
26-Aug-25	2459413	TSQ002	Esiqanduleni Final	Taste*	Nil	-	-
26-Aug-25	2459410	TSQ002	Esiqanduleni Final	Temperature OS*	14.3	-	°C
26-Aug-25	2459413	TSQ002	Esiqanduleni Final	Turbidity	0.4	±6.1%	NTU
26-Aug-25	2459416	TSQ003	Esiqanduleni Reticulation	Batch No.*	20250201	-	-
26-Aug-25	2459416	TSQ003	Esiqanduleni Reticulation	Cl2 (F) OS*	0.72	-	mg Cl2/L
26-Aug-25	2459416	TSQ003	Esiqanduleni Reticulation	Cl2 (T) OS*	0.74	-	mg Cl2/L
26-Aug-25	2459417	TSQ003	Esiqanduleni Reticulation	Coliforms*	0	±15%	MPN/100mL
26-Aug-25	2459416	TSQ003	Esiqanduleni Reticulation	Coll Time OS*	08:56	-	-
26-Aug-25	2459419	TSQ003	Esiqanduleni Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Aug-25	2459420	TSQ003	Esiqanduleni Reticulation	Conductivity	21.3	±1.5%	mS/m
26-Aug-25	2459417	TSQ003	Esiqanduleni Reticulation	E.coli*	0	±14%	MPN/100mL
26-Aug-25	2459417	TSQ003	Esiqanduleni Reticulation	HPC 37*	0	±21%	cfu/mL
26-Aug-25	2459419	TSQ003	Esiqanduleni Reticulation	Odour*	Nil	-	-
26-Aug-25	2459416	TSQ003	Esiqanduleni Reticulation	pH OS*	7.40	-	-
26-Aug-25	2459416	TSQ003	Esiqanduleni Reticulation	Temperature OS*	13.3	-	°C
26-Aug-25	2459419	TSQ003	Esiqanduleni Reticulation	Turbidity	1.9	±6.1%	NTU
27-Aug-25	2459960	TBU002	Bulwer Final	Batch No.*	20250201	-	-
27-Aug-25	2459960	TBU002	Bulwer Final	Cl2 (F) OS*	1.40	-	mg Cl2/L
27-Aug-25	2459960	TBU002	Bulwer Final	Cl2 (T) OS*	1.52	-	mg Cl2/L
27-Aug-25	2459961	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

27-Aug-25	2459960	TBU002	Bulwer Final	Coll Time OS*	10:17	-	-
27-Aug-25	2459963	TBU002	Bulwer Final	Colour	3.80	±6.5%	mg Pt-Co/L
27-Aug-25	2459965	TBU002	Bulwer Final	Conductivity	6.61	±1.5%	mS/m
27-Aug-25	2459961	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
27-Aug-25	2459961	TBU002	Bulwer Final	HPC 37*	12	±21%	cfu/mL
27-Aug-25	2459963	TBU002	Bulwer Final	Odour*	Mild Chlorinous	-	-
27-Aug-25	2459960	TBU002	Bulwer Final	pH OS*	7.40	-	-
27-Aug-25	2459960	TBU002	Bulwer Final	Temperature OS*	24.0	-	°C
27-Aug-25	2459963	TBU002	Bulwer Final	Turbidity	4.0	±6.1%	NTU
27-Aug-25	2459967	TBU005	Bulwer Mountain Park Hotel Retic	Batch No.*	20250201	-	-
27-Aug-25	2459967	TBU005	Bulwer Mountain Park Hotel Retic	Cl2 (F) OS*	0.83	-	mg Cl2/L
27-Aug-25	2459967	TBU005	Bulwer Mountain Park Hotel Retic	Cl2 (T) OS*	0.95	-	mg Cl2/L
27-Aug-25	2459968	TBU005	Bulwer Mountain Park Hotel Retic	Coliforms*	0	±15%	MPN/100mL
27-Aug-25	2459967	TBU005	Bulwer Mountain Park Hotel Retic	Coll Time OS*	10:38	-	-
27-Aug-25	2459970	TBU005	Bulwer Mountain Park Hotel Retic	Colour	2.90	±6.5%	mg Pt-Co/L
27-Aug-25	2459971	TBU005	Bulwer Mountain Park Hotel Retic	Conductivity	6.90	±1.5%	mS/m
27-Aug-25	2459968	TBU005	Bulwer Mountain Park Hotel Retic	E.coli*	0	±14%	MPN/100mL
27-Aug-25	2459968	TBU005	Bulwer Mountain Park Hotel Retic	HPC 37*	3	±21%	cfu/mL
27-Aug-25	2459967	TBU005	Bulwer Mountain Park Hotel Retic	pH OS*	7.40	-	-
27-Aug-25	2459967	TBU005	Bulwer Mountain Park Hotel Retic	Temperature OS*	27.1	-	°C
27-Aug-25	2459970	TBU005	Bulwer Mountain Park Hotel Retic	Turbidity	4.2	±6.1%	NTU
27-Aug-25	2459982	TCR002	Creighton Final	Al (AE)	325	±7.6%	µg Al/L
27-Aug-25	2459977	TCR002	Creighton Final	Batch No.*	20250201	-	-
27-Aug-25	2459977	TCR002	Creighton Final	Cl2 (F) OS*	1.28	-	mg Cl2/L
27-Aug-25	2459977	TCR002	Creighton Final	Cl2 (T) OS*	1.38	-	mg Cl2/L
27-Aug-25	2459978	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
27-Aug-25	2459977	TCR002	Creighton Final	Coll Time OS*	7:30	-	-
27-Aug-25	2459981	TCR002	Creighton Final	Conductivity	12.6	±1.5%	mS/m
27-Aug-25	2459978	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
27-Aug-25	2459978	TCR002	Creighton Final	HPC 37*	0	±21%	cfu/mL
27-Aug-25	2459977	TCR002	Creighton Final	pH OS*	7.30	-	-
27-Aug-25	2459977	TCR002	Creighton Final	Temperature OS*	13.2	-	°C
27-Aug-25	2459980	TCR002	Creighton Final	Turbidity	0.3	±6.1%	NTU
27-Aug-25	2459983	TCR004	Creighton Madondo Cottages	Batch No.*	20250201	-	-
27-Aug-25	2459983	TCR004	Creighton Madondo Cottages	Cl2 (F) OS*	0.71	-	mg Cl2/L
27-Aug-25	2459983	TCR004	Creighton Madondo Cottages	Cl2 (T) OS*	0.76	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

27-Aug-25	2459984	TCR004	Creighton Madondo Cottages	Coliforms*	0	±15%	MPN/100mL
27-Aug-25	2459983	TCR004	Creighton Madondo Cottages	Coll Time OS*	7:10	-	-
27-Aug-25	2459984	TCR004	Creighton Madondo Cottages	E.coli*	0	±14%	MPN/100mL
27-Aug-25	2459984	TCR004	Creighton Madondo Cottages	HPC 37*	0	±21%	cfu/mL
27-Aug-25	2459983	TCR004	Creighton Madondo Cottages	pH OS*	7.20	-	-
27-Aug-25	2459983	TCR004	Creighton Madondo Cottages	Temperature OS*	13.6	-	°C
27-Aug-25	2459986	TCR004	Creighton Madondo Cottages	Turbidity	0.4	±6.1%	NTU
27-Aug-25	2459997	THL002	Hlanganani Final	Batch No.*	20250201	-	-
27-Aug-25	2459997	THL002	Hlanganani Final	Cl2 (F) OS*	0.77	-	mg Cl2/L
27-Aug-25	2459997	THL002	Hlanganani Final	Cl2 (T) OS*	0.87	-	mg Cl2/L
27-Aug-25	2459998	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
27-Aug-25	2459997	THL002	Hlanganani Final	Coll Time OS*	11:00	-	-
27-Aug-25	2460000	THL002	Hlanganani Final	Colour	<1.00	±6.5%	mg Pt-Co/L
27-Aug-25	2460001	THL002	Hlanganani Final	Conductivity	11.5	±1.5%	mS/m
27-Aug-25	2459998	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
27-Aug-25	2459998	THL002	Hlanganani Final	HPC 37*	0	±21%	cfu/mL
27-Aug-25	2460000	THL002	Hlanganani Final	Odour*	Mild Chlorinous	-	-
27-Aug-25	2459997	THL002	Hlanganani Final	pH OS*	7.30	-	-
27-Aug-25	2460000	THL002	Hlanganani Final	Taste*	Nil	-	-
27-Aug-25	2459997	THL002	Hlanganani Final	Temperature OS*	27.5	-	°C
27-Aug-25	2460000	THL002	Hlanganani Final	Turbidity	<0.2	±6.1%	NTU
27-Aug-25	2460002	THL003	Hlanganani Clinic Reticulation	Batch No.*	20250201	-	-
27-Aug-25	2460002	THL003	Hlanganani Clinic Reticulation	Cl2 (F) OS*	0.34	-	mg Cl2/L
27-Aug-25	2460002	THL003	Hlanganani Clinic Reticulation	Cl2 (T) OS*	0.40	-	mg Cl2/L
27-Aug-25	2460003	THL003	Hlanganani Clinic Reticulation	Coliforms*	0	±15%	MPN/100mL
27-Aug-25	2460002	THL003	Hlanganani Clinic Reticulation	Coll Time OS*	11:16	-	-
27-Aug-25	2460003	THL003	Hlanganani Clinic Reticulation	E.coli*	0	±14%	MPN/100mL
27-Aug-25	2460003	THL003	Hlanganani Clinic Reticulation	HPC 37*	0	±21%	cfu/mL
27-Aug-25	2460002	THL003	Hlanganani Clinic Reticulation	pH OS*	7.40	-	-
27-Aug-25	2460002	THL003	Hlanganani Clinic Reticulation	Temperature OS*	28.2	-	°C
27-Aug-25	2460005	THL003	Hlanganani Clinic Reticulation	Turbidity	<0.2	±6.1%	NTU
27-Aug-25	2460033	TMQA002	Mqatsheni Final	Batch No.*	20250201	-	-
27-Aug-25	2460033	TMQA002	Mqatsheni Final	Cl2 (F) OS*	1.10	-	mg Cl2/L
27-Aug-25	2460033	TMQA002	Mqatsheni Final	Cl2 (T) OS*	1.25	-	mg Cl2/L
27-Aug-25	2460034	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

27-Aug-25	2460033	TMQA002	Mqatsheni Final	Coll Time OS*	8:15	-	-
27-Aug-25	2460036	TMQA002	Mqatsheni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
27-Aug-25	2460037	TMQA002	Mqatsheni Final	Conductivity	26.3	±1.5%	mS/m
27-Aug-25	2460034	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
27-Aug-25	2460034	TMQA002	Mqatsheni Final	HPC 37*	1	±21%	cfu/mL
27-Aug-25	2460036	TMQA002	Mqatsheni Final	Odour*	Mild Chlorinous	-	-
27-Aug-25	2460033	TMQA002	Mqatsheni Final	pH OS*	8.40	-	-
27-Aug-25	2460036	TMQA002	Mqatsheni Final	Taste*	Nil	-	-
27-Aug-25	2460033	TMQA002	Mqatsheni Final	Temperature OS*	14.9	-	°C
27-Aug-25	2460036	TMQA002	Mqatsheni Final	Turbidity	0.5	±6.1%	NTU
27-Aug-25	2460038	TMQA003	Mqatsheni Reticulation	Batch No.*	20250201	-	-
27-Aug-25	2460038	TMQA003	Mqatsheni Reticulation	Cl2 (F) OS*	0.87	-	mg Cl2/L
27-Aug-25	2460038	TMQA003	Mqatsheni Reticulation	Cl2 (T) OS*	0.98	-	mg Cl2/L
27-Aug-25	2460039	TMQA003	Mqatsheni Reticulation	Coliforms*	0	±15%	MPN/100mL
27-Aug-25	2460038	TMQA003	Mqatsheni Reticulation	Coll Time OS*	8:25	-	-
27-Aug-25	2460041	TMQA003	Mqatsheni Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
27-Aug-25	2460042	TMQA003	Mqatsheni Reticulation	Conductivity	25.9	±1.5%	mS/m
27-Aug-25	2460039	TMQA003	Mqatsheni Reticulation	E.coli*	0	±14%	MPN/100mL
27-Aug-25	2460039	TMQA003	Mqatsheni Reticulation	HPC 37*	0	±21%	cfu/mL
27-Aug-25	2460038	TMQA003	Mqatsheni Reticulation	pH OS*	8.60	-	-
27-Aug-25	2460038	TMQA003	Mqatsheni Reticulation	Temperature OS*	13.0	-	°C
27-Aug-25	2460041	TMQA003	Mqatsheni Reticulation	Turbidity	0.5	±6.1%	NTU
27-Aug-25	2460048	TRV002	Riverside Final	Batch No.*	20250201	-	-
27-Aug-25	2460048	TRV002	Riverside Final	Cl2 (F) OS*	1.50	-	mg Cl2/L
27-Aug-25	2460048	TRV002	Riverside Final	Cl2 (T) OS*	1.72	-	mg Cl2/L
27-Aug-25	2460049	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
27-Aug-25	2460048	TRV002	Riverside Final	Coll Time OS*	8:10	-	-
27-Aug-25	2460051	TRV002	Riverside Final	Colour	3.80	±6.5%	mg Pt-Co/L
27-Aug-25	2460052	TRV002	Riverside Final	Conductivity	11.8	±1.5%	mS/m
27-Aug-25	2460049	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
27-Aug-25	2460049	TRV002	Riverside Final	HPC 37*	0	±21%	cfu/mL
27-Aug-25	2460051	TRV002	Riverside Final	Odour*	Mild Chlorinous	-	-
27-Aug-25	2460048	TRV002	Riverside Final	pH OS*	7.30	-	-
27-Aug-25	2460048	TRV002	Riverside Final	Temperature OS*	15.1	-	°C
27-Aug-25	2460051	TRV002	Riverside Final	Turbidity	4.0	±6.1%	NTU
27-Aug-25	2460053	TRV003	Riverside Reticulation	Batch No.*	20250201	-	-
27-Aug-25	2460053	TRV003	Riverside Reticulation	Cl2 (F) OS*	1.14	-	mg Cl2/L
27-Aug-25	2460053	TRV003	Riverside Reticulation	Cl2 (T) OS*	1.27	-	mg Cl2/L
27-Aug-25	2460054	TRV003	Riverside Reticulation	Coliforms*	0	±15%	MPN/100mL
27-Aug-25	2460053	TRV003	Riverside Reticulation	Coll Time OS*	8:15	-	-
27-Aug-25	2460056	TRV003	Riverside Reticulation	Colour	3.60	±6.5%	mg Pt-Co/L
27-Aug-25	2460054	TRV003	Riverside Reticulation	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

27-Aug-25	2460054	TRV003	Riverside Reticulation	HPC 37*	0	±21%	cfu/mL
27-Aug-25	2460056	TRV003	Riverside Reticulation	Odour*	Mild Chlorinous	-	-
27-Aug-25	2460053	TRV003	Riverside Reticulation	pH OS*	7.20	-	-
27-Aug-25	2460053	TRV003	Riverside Reticulation	Temperature OS*	14.2	-	°C
27-Aug-25	2460056	TRV003	Riverside Reticulation	Turbidity	4.3	±6.1%	NTU
27-Aug-25	2460062	TST002	St Appollinaris Final	Batch No.*	20250201	-	-
27-Aug-25	2460062	TST002	St Appollinaris Final	Cl ₂ (F) OS*	0.63	-	mg Cl ₂ /L
27-Aug-25	2460062	TST002	St Appollinaris Final	Cl ₂ (T) OS*	0.70	-	mg Cl ₂ /L
27-Aug-25	2460063	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
27-Aug-25	2460062	TST002	St Appollinaris Final	Coll Time OS*	9:24	-	-
27-Aug-25	2460065	TST002	St Appollinaris Final	Colour	2.00	±6.5%	mg Pt-Co/L
27-Aug-25	2460066	TST002	St Appollinaris Final	Conductivity	10.4	±1.5%	mS/m
27-Aug-25	2460063	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
27-Aug-25	2460063	TST002	St Appollinaris Final	HPC 37*	1	±21%	cfu/mL
27-Aug-25	2460065	TST002	St Appollinaris Final	Odour*	Mild Chlorinous	-	-
27-Aug-25	2460062	TST002	St Appollinaris Final	pH OS*	7.40	-	-
27-Aug-25	2460062	TST002	St Appollinaris Final	Temperature OS*	16.7	-	°C
27-Aug-25	2460065	TST002	St Appollinaris Final	Turbidity	2.8	±6.1%	NTU
27-Aug-25	2460077	TUN002	Underberg Final	Al (AE)	<25.0	±7.6%	µg Al/L
27-Aug-25	2460072	TUN002	Underberg Final	Batch No.*	20250201	-	-
27-Aug-25	2460072	TUN002	Underberg Final	Cl ₂ (F) OS*	0.23	-	mg Cl ₂ /L
27-Aug-25	2460072	TUN002	Underberg Final	Cl ₂ (T) OS*	0.30	-	mg Cl ₂ /L
27-Aug-25	2460073	TUN002	Underberg Final	Coliforms*	15	±15%	MPN/100mL
27-Aug-25	2460072	TUN002	Underberg Final	Coll Time OS*	9:39	-	-
27-Aug-25	2460075	TUN002	Underberg Final	Colour	2.50	±6.5%	mg Pt-Co/L
27-Aug-25	2460076	TUN002	Underberg Final	Conductivity	7.27	±1.5%	mS/m
27-Aug-25	2460073	TUN002	Underberg Final	E.coli*	1	±14%	MPN/100mL
27-Aug-25	2460073	TUN002	Underberg Final	HPC 37*	19	±21%	cfu/mL
27-Aug-25	2460075	TUN002	Underberg Final	Odour*	Mild Chlorinous	-	-
27-Aug-25	2460072	TUN002	Underberg Final	pH OS*	7.40	-	-
27-Aug-25	2460075	TUN002	Underberg Final	Taste*	Nil	-	-
27-Aug-25	2460072	TUN002	Underberg Final	Temperature OS*	11.9	-	°C
27-Aug-25	2460075	TUN002	Underberg Final	Turbidity	0.5	±6.1%	NTU
28-Aug-25	2460638	TMZ002	Umzimkhulu Final	Al (AE)	142	±7.6%	µg Al/L
28-Aug-25	2460633	TMZ002	Umzimkhulu Final	Batch No.*	20250201	-	-
28-Aug-25	2460633	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	1.12	-	mg Cl ₂ /L
28-Aug-25	2460633	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	1.20	-	mg Cl ₂ /L
28-Aug-25	2460634	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
28-Aug-25	2460634	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
28-Aug-25	2460633	TMZ002	Umzimkhulu Final	Coll Time OS*	06:41	-	-
28-Aug-25	2460637	TMZ002	Umzimkhulu Final	Conductivity	13.9	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

28-Aug-25	2460634	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
28-Aug-25	2460638	TMZ002	Umzimkhulu Final	Fe (AE)	0.04	±5.4%	mg Fe/L
28-Aug-25	2460634	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	cfu/mL
28-Aug-25	2460633	TMZ002	Umzimkhulu Final	pH OS*	7.30	-	-
28-Aug-25	2460633	TMZ002	Umzimkhulu Final	Temperature OS*	14.1	-	°C
28-Aug-25	2460636	TMZ002	Umzimkhulu Final	Turbidity	1.5	±6.1%	NTU
28-Aug-25	2460639	TMZ004	Umzikhulu Informal Settlement Retic	Batch No.*	20250201	-	-
28-Aug-25	2460639	TMZ004	Umzikhulu Informal Settlement Retic	Cl2 (F) OS*	1.03	-	mg Cl2/L
28-Aug-25	2460639	TMZ004	Umzikhulu Informal Settlement Retic	Cl2 (T) OS*	1.11	-	mg Cl2/L
28-Aug-25	2460640	TMZ004	Umzikhulu Informal Settlement Retic	Coliforms*	0	±15%	MPN/100mL
28-Aug-25	2460639	TMZ004	Umzikhulu Informal Settlement Retic	Coll Time OS*	07:28	-	-
28-Aug-25	2460640	TMZ004	Umzikhulu Informal Settlement Retic	E.coli*	0	±14%	MPN/100mL
28-Aug-25	2460640	TMZ004	Umzikhulu Informal Settlement Retic	HPC 37*	0	±21%	cfu/mL
28-Aug-25	2460639	TMZ004	Umzikhulu Informal Settlement Retic	pH OS*	7.50	-	-
28-Aug-25	2460639	TMZ004	Umzikhulu Informal Settlement Retic	Temperature OS*	15.8	-	°C
28-Aug-25	2460642	TMZ004	Umzikhulu Informal Settlement Retic	Turbidity	1.6	±6.1%	NTU
28-Aug-25	2460643	TMZ005	Umzimkhulu Local Municipality Offices	Batch No.*	20250201	-	-
28-Aug-25	2460643	TMZ005	Umzimkhulu Local Municipality Offices	Cl2 (F) OS*	1.19	-	mg Cl2/L
28-Aug-25	2460643	TMZ005	Umzimkhulu Local Municipality Offices	Cl2 (T) OS*	1.28	-	mg Cl2/L
28-Aug-25	2460644	TMZ005	Umzimkhulu Local Municipality Offices	Coliforms*	0	±15%	MPN/100mL
28-Aug-25	2460643	TMZ005	Umzimkhulu Local Municipality Offices	Coll Time OS*	07:38	-	-
28-Aug-25	2460646	TMZ005	Umzimkhulu Local Municipality Offices	Colour	<1.00	±6.5%	mg Pt-Co/L
28-Aug-25	2460647	TMZ005	Umzimkhulu Local Municipality Offices	Conductivity	14.1	±1.5%	mS/m
28-Aug-25	2460644	TMZ005	Umzimkhulu Local Municipality Offices	E.coli*	0	±14%	MPN/100mL
28-Aug-25	2460644	TMZ005	Umzimkhulu Local Municipality Offices	HPC 37*	0	±21%	cfu/mL
28-Aug-25	2460643	TMZ005	Umzimkhulu Local Municipality Offices	pH OS*	7.40	-	-
28-Aug-25	2460643	TMZ005	Umzimkhulu Local Municipality Offices	Temperature OS*	14.4	-	°C
28-Aug-25	2460646	TMZ005	Umzimkhulu Local Municipality Offices	Turbidity	1.5	±6.1%	NTU
28-Aug-25	2460648	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Batch No.*	20250201	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

28-Aug-25	2460648	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (F) OS*	0.47	-	mg Cl ₂ /L
28-Aug-25	2460648	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (T) OS*	0.52	-	mg Cl ₂ /L
28-Aug-25	2460649	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
28-Aug-25	2460648	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coll Time OS*	07:17	-	-
28-Aug-25	2460649	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
28-Aug-25	2460649	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	HPC 37*	13	±21%	cfu/mL
28-Aug-25	2460648	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	pH OS*	7.40	-	-
28-Aug-25	2460648	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Temperature OS*	14.6	-	°C
28-Aug-25	2460651	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Turbidity	1.9	±6.1%	NTU
28-Aug-25	2460652	TMZ007	Umzimkhulu Local FET College	Batch No.*	20250201	-	-
28-Aug-25	2460652	TMZ007	Umzimkhulu Local FET College	Cl ₂ (F) OS*	<0.05	-	mg Cl ₂ /L
28-Aug-25	2460652	TMZ007	Umzimkhulu Local FET College	Cl ₂ (T) OS*	0.05	-	mg Cl ₂ /L
28-Aug-25	2460653	TMZ007	Umzimkhulu Local FET College	Coliforms*	0	±15%	MPN/100mL
28-Aug-25	2460652	TMZ007	Umzimkhulu Local FET College	Coll Time OS*	07:00	-	-
28-Aug-25	2460655	TMZ007	Umzimkhulu Local FET College	Colour	1.00	±6.5%	mg Pt-Co/L
28-Aug-25	2460656	TMZ007	Umzimkhulu Local FET College	Conductivity	13.1	±1.5%	mS/m
28-Aug-25	2460653	TMZ007	Umzimkhulu Local FET College	E.coli*	0	±14%	MPN/100mL
28-Aug-25	2460653	TMZ007	Umzimkhulu Local FET College	HPC 37*	12	±21%	cfu/mL
28-Aug-25	2460652	TMZ007	Umzimkhulu Local FET College	pH OS*	7.60	-	-
28-Aug-25	2460652	TMZ007	Umzimkhulu Local FET College	Temperature OS*	16.3	-	°C
28-Aug-25	2460655	TMZ007	Umzimkhulu Local FET College	Turbidity	11.9	±6.1%	NTU
28-Aug-25	2460667	TNO002	Nokweja Final	Al (AE)	219	±7.6%	µg Al/L
28-Aug-25	2460662	TNO002	Nokweja Final	Batch No.*	20250201	-	-
28-Aug-25	2460662	TNO002	Nokweja Final	Cl ₂ (F) OS*	1.20	-	mg Cl ₂ /L
28-Aug-25	2460662	TNO002	Nokweja Final	Cl ₂ (T) OS*	1.36	-	mg Cl ₂ /L
28-Aug-25	2460663	TNO002	Nokweja Final	Coliforms*	1	±15%	MPN/100mL
28-Aug-25	2460663	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
28-Aug-25	2460662	TNO002	Nokweja Final	Coll Time OS*	07:49	-	-
28-Aug-25	2460665	TNO002	Nokweja Final	Colour	3.40	±6.5%	mg Pt-Co/L
28-Aug-25	2460666	TNO002	Nokweja Final	Conductivity	14.3	±1.5%	mS/m
28-Aug-25	2460663	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
28-Aug-25	2460663	TNO002	Nokweja Final	HPC 37*	12	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

28-Aug-25	2460665	TNO002	Nokweja Final	Odour*	Mild Chlorinous	-	-
28-Aug-25	2460662	TNO002	Nokweja Final	pH OS*	7.40	-	-
28-Aug-25	2460662	TNO002	Nokweja Final	Temperature OS*	14.4	-	°C
28-Aug-25	2460665	TNO002	Nokweja Final	Turbidity	2.7	±6.1%	NTU
28-Aug-25	2460711	TWA002	Washbank Final	Al (AE)	278	±7.6%	µg Al/L
28-Aug-25	2460706	TWA002	Washbank Final	Batch No.*	20250201	-	-
28-Aug-25	2460706	TWA002	Washbank Final	Cl ₂ (F) OS*	0.47	-	mg Cl ₂ /L
28-Aug-25	2460706	TWA002	Washbank Final	Cl ₂ (T) OS*	0.52	-	mg Cl ₂ /L
28-Aug-25	2460707	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
28-Aug-25	2460706	TWA002	Washbank Final	Coll Time OS*	07:17	-	-
28-Aug-25	2460709	TWA002	Washbank Final	Colour	4.00	±6.5%	mg Pt-Co/L
28-Aug-25	2460710	TWA002	Washbank Final	Conductivity	8.94	±1.5%	mS/m
28-Aug-25	2460707	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
28-Aug-25	2460707	TWA002	Washbank Final	HPC 37*	0	±21%	cfu/mL
28-Aug-25	2460709	TWA002	Washbank Final	Odour*	Mild Chlorinous	-	-
28-Aug-25	2460706	TWA002	Washbank Final	pH OS*	7.40	-	-
28-Aug-25	2460706	TWA002	Washbank Final	Temperature OS*	14.6	-	°C
28-Aug-25	2460709	TWA002	Washbank Final	Turbidity	5.1	±6.1%	NTU
29-Aug-25	2460943	TIB002	Ibisi Final	Al (AE)	182	±7.6%	µg Al/L
29-Aug-25	2460938	TIB002	Ibisi Final	Batch No.*	20250201	-	-
29-Aug-25	2460938	TIB002	Ibisi Final	Cl ₂ (F) OS*	0.92	-	mg Cl ₂ /L
29-Aug-25	2460938	TIB002	Ibisi Final	Cl ₂ (T) OS*	0.99	-	mg Cl ₂ /L
29-Aug-25	2460939	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
29-Aug-25	2460939	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
29-Aug-25	2460938	TIB002	Ibisi Final	Coll Time OS*	6:00	-	-
29-Aug-25	2460941	TIB002	Ibisi Final	Colour	1.50	±6.5%	mg Pt-Co/L
29-Aug-25	2460942	TIB002	Ibisi Final	Conductivity	12.2	±1.5%	mS/m
29-Aug-25	2460939	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
29-Aug-25	2460939	TIB002	Ibisi Final	HPC 37*	154	±21%	cfu/mL
29-Aug-25	2460941	TIB002	Ibisi Final	Odour*	Mild Chlorinous	-	-
29-Aug-25	2460938	TIB002	Ibisi Final	pH OS*	7.30	-	-
29-Aug-25	2460938	TIB002	Ibisi Final	Temperature OS*	16.8	-	°C
29-Aug-25	2460941	TIB002	Ibisi Final	Turbidity	3.1	±6.1%	NTU
29-Aug-25	2460944	TIB003	Ibisi Police Station Reticulation	Batch No.*	20250201	-	-
29-Aug-25	2460944	TIB003	Ibisi Police Station Reticulation	Cl ₂ (F) OS*	0.41	-	mg Cl ₂ /L
29-Aug-25	2460944	TIB003	Ibisi Police Station Reticulation	Cl ₂ (T) OS*	0.50	-	mg Cl ₂ /L
29-Aug-25	2460945	TIB003	Ibisi Police Station Reticulation	Coliforms*	0	±15%	MPN/100mL
29-Aug-25	2460944	TIB003	Ibisi Police Station Reticulation	Coll Time OS*	6:10	-	-
29-Aug-25	2460947	TIB003	Ibisi Police Station Reticulation	Colour	3.00	±6.5%	mg Pt-Co/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

29-Aug-25	2460948	TIB003	Ibisi Police Station Reticulation	Conductivity	12.1	±1.5%	mS/m
29-Aug-25	2460945	TIB003	Ibisi Police Station Reticulation	E.coli*	0	±14%	MPN/100mL
29-Aug-25	2460945	TIB003	Ibisi Police Station Reticulation	HPC 37*	0	±21%	cfu/mL
29-Aug-25	2460944	TIB003	Ibisi Police Station Reticulation	pH OS*	7.30	-	-
29-Aug-25	2460944	TIB003	Ibisi Police Station Reticulation	Temperature OS*	15.7	-	°C
29-Aug-25	2460947	TIB003	Ibisi Police Station Reticulation	Turbidity	2.5	±6.1%	NTU
29-Aug-25	2460953	TRT002	Rietvlei Final	Batch No.*	20250201	-	-
29-Aug-25	2460953	TRT002	Rietvlei Final	Cl ₂ (F) OS*	0.69	-	mg Cl ₂ /L
29-Aug-25	2460953	TRT002	Rietvlei Final	Cl ₂ (T) OS*	0.81	-	mg Cl ₂ /L
29-Aug-25	2460954	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
29-Aug-25	2460953	TRT002	Rietvlei Final	Coll Time OS*	5:15	-	-
29-Aug-25	2460957	TRT002	Rietvlei Final	Conductivity	20.1	±1.5%	mS/m
29-Aug-25	2460954	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
29-Aug-25	2460954	TRT002	Rietvlei Final	HPC 37*	3	±21%	cfu/mL
29-Aug-25	2460953	TRT002	Rietvlei Final	pH OS*	7.30	-	-
29-Aug-25	2460953	TRT002	Rietvlei Final	Temperature OS*	14.2	-	°C
29-Aug-25	2460956	TRT002	Rietvlei Final	Turbidity	2.1	±6.1%	NTU
29-Aug-25	2460958	TRT004	Rietvlei Hospital Reticulation	Batch No.*	20250201	-	-
29-Aug-25	2460958	TRT004	Rietvlei Hospital Reticulation	Cl ₂ (F) OS*	0.57	-	mg Cl ₂ /L
29-Aug-25	2460958	TRT004	Rietvlei Hospital Reticulation	Cl ₂ (T) OS*	0.69	-	mg Cl ₂ /L
29-Aug-25	2460959	TRT004	Rietvlei Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
29-Aug-25	2460958	TRT004	Rietvlei Hospital Reticulation	Coll Time OS*	5:19	-	-
29-Aug-25	2460961	TRT004	Rietvlei Hospital Reticulation	Colour	1.00	±6.5%	mg Pt-Co/L
29-Aug-25	2460962	TRT004	Rietvlei Hospital Reticulation	Conductivity	20.0	±1.5%	mS/m
29-Aug-25	2460959	TRT004	Rietvlei Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
29-Aug-25	2460959	TRT004	Rietvlei Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
29-Aug-25	2460958	TRT004	Rietvlei Hospital Reticulation	pH OS*	7.50	-	-
29-Aug-25	2460958	TRT004	Rietvlei Hospital Reticulation	Temperature OS*	14.9	-	°C
29-Aug-25	2460961	TRT004	Rietvlei Hospital Reticulation	Turbidity	1.4	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)