

Date: 09 September 2025

The Executive Director: Water Services Department

Harry Gwala District Municipality

40 Main Street

Ixopo

3276

Attention: Basetsana Khathalib and Bheki Nene

AUGUST 2025 WASTEWATER RESULTS

Please find August 2025 Wastewater results tabulated below for samples received during August 2025. Determinands marked with an asterix are unaccredited and are not included in uMngeni-uThukela Water's schedule of accreditation.

Please contact us immediately should you have any queries.

Yours' Sincerely

Mr M Sewcharan

Client Services Manager

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Sample Date	Sample Number	Sampling Point	Description	Determinand	Result	UOM	Unit
04-Aug-25	2445953	RKOK001	River above Kokstad	COD*	<20.0	-	mg O2/L
04-Aug-25	2445949	RKOK001	River above Kokstad	Coll Time OS*	08:09	-	-
04-Aug-25	2445951	RKOK001	River above Kokstad	Colour	10.8	±6.5%	mg Pt-Co/L
04-Aug-25	2445953	RKOK001	River above Kokstad	Conductivity	19.4	±1.5%	mS/m
04-Aug-25	2445950	RKOK001	River above Kokstad	E.coli*	19863	±21%	MPN/100mL
04-Aug-25	2445953	RKOK001	River above Kokstad	NH3*	1.48	±5.5%	mg N/L
04-Aug-25	2445953	RKOK001	River above Kokstad	NO2*	<0.10	±2.4%	mg N/L
04-Aug-25	2445953	RKOK001	River above Kokstad	NO3*	0.49	±2.9%	mg N/L
04-Aug-25	2445952	RKOK001	River above Kokstad	OG*	<1.20	-	mg /L
04-Aug-25	2445949	RKOK001	River above Kokstad	pH OS*	7.20	-	-
04-Aug-25	2445953	RKOK001	River above Kokstad	SRP*	62.3	±7.7%	ug P/L
04-Aug-25	2445951	RKOK001	River above Kokstad	SS	<10.0	±3.7%	mg /L
04-Aug-25	2445949	RKOK001	River above Kokstad	Temperature OS*	10.0	-	°C
04-Aug-25	2445954	RKOK002	River below Kokstad	Cl2 (F) OS*	<0.05	-	mg Cl2/L
04-Aug-25	2445954	RKOK002	River below Kokstad	Cl2 (T) OS*	<0.05	-	mg Cl2/L
04-Aug-25	2445958	RKOK002	River below Kokstad	COD*	<20.0	-	mg O2/L
04-Aug-25	2445954	RKOK002	River below Kokstad	Coll Time OS*	08:20	-	-
04-Aug-25	2445956	RKOK002	River below Kokstad	Colour	11.4	±6.5%	mg Pt-Co/L
04-Aug-25	2445958	RKOK002	River below Kokstad	Conductivity	19.4	±1.5%	mS/m
04-Aug-25	2445955	RKOK002	River below Kokstad	E.coli*	>24196	±21%	MPN/100mL
04-Aug-25	2445958	RKOK002	River below Kokstad	NH3*	0.81	±5.5%	mg N/L
04-Aug-25	2445958	RKOK002	River below Kokstad	NO2*	<0.10	±2.4%	mg N/L
04-Aug-25	2445958	RKOK002	River below Kokstad	NO3*	0.60	±2.9%	mg N/L
04-Aug-25	2445957	RKOK002	River below Kokstad	OG*	<1.20	-	mg /L
04-Aug-25	2445954	RKOK002	River below Kokstad	pH OS*	7.20	-	-
04-Aug-25	2445958	RKOK002	River below Kokstad	SRP*	105	±7.7%	ug P/L
04-Aug-25	2445956	RKOK002	River below Kokstad	SS	<10.0	±3.7%	mg /L
04-Aug-25	2445954	RKOK002	River below Kokstad	Temperature OS*	11.7	-	°C
04-Aug-25	2446043	WKK001	KoKstad WWW Influent	COD*	895	-	mg O2/L
04-Aug-25	2446041	WKK001	KoKstad WWW Influent	Coll Time OS*	08:35	-	-
04-Aug-25	2446043	WKK001	KoKstad WWW Influent	Conductivity	80.1	±1.5%	mS/m
04-Aug-25	2446042	WKK001	KoKstad WWW Influent	E.coli*	>241960	±21%	MPN/100mL
04-Aug-25	2446043	WKK001	KoKstad WWW Influent	NH3*	20.9	-	mg N/L
04-Aug-25	2446043	WKK001	KoKstad WWW Influent	NO3*	<0.50	-	mg N/L
04-Aug-25	2446041	WKK001	KoKstad WWW Influent	pH OS*	7.70	-	-
04-Aug-25	2446043	WKK001	KoKstad WWW Influent	SRP*	3165	-	ug P/L
04-Aug-25	2446043	WKK001	KoKstad WWW Influent	SS	332	±8.2%	mg /L
04-Aug-25	2446041	WKK001	KoKstad WWW Influent	Temperature OS*	15.7	-	°C
04-Aug-25	2446044	WKK004	Kokstad WWW Final Effluent M	Cl2 (F) OS*	0.05	-	mg Cl2/L
04-Aug-25	2446044	WKK004	Kokstad WWW Final Effluent M	Cl2 (T) OS*	0.07	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

04-Aug-25	2446048	WKK004	Kokstad WWW Final Effluent M	COD*	54.5	-	mg O2/L
04-Aug-25	2446044	WKK004	Kokstad WWW Final Effluent M	Coll Time OS*	08:28	-	-
04-Aug-25	2446046	WKK004	Kokstad WWW Final Effluent M	Colour	23.4	±6.5%	mg Pt-Co/L
04-Aug-25	2446048	WKK004	Kokstad WWW Final Effluent M	Conductivity	69.8	±1.5%	mS/m
04-Aug-25	2446045	WKK004	Kokstad WWW Final Effluent M	E.coli*	22	±21%	MPN/100mL
04-Aug-25	2446048	WKK004	Kokstad WWW Final Effluent M	NH3*	15.8	-	mg N/L
04-Aug-25	2446048	WKK004	Kokstad WWW Final Effluent M	NO2*	<0.50	-	mg N/L
04-Aug-25	2446048	WKK004	Kokstad WWW Final Effluent M	NO3*	4.18	-	mg N/L
04-Aug-25	2446047	WKK004	Kokstad WWW Final Effluent M	OG*	<1.20	-	mg /L
04-Aug-25	2446044	WKK004	Kokstad WWW Final Effluent M	pH OS*	7.60	-	-
04-Aug-25	2446048	WKK004	Kokstad WWW Final Effluent M	SRP*	3677	-	ug P/L
04-Aug-25	2446048	WKK004	Kokstad WWW Final Effluent M	SS	20.0	±8.2%	mg /L
04-Aug-25	2446044	WKK004	Kokstad WWW Final Effluent M	Temperature OS*	13.8	-	°C
06-Aug-25	2447257	WBU001	Bulwer WWW Influent	COD*	153	-	mg O2/L
06-Aug-25	2447256	WBU001	Bulwer WWW Influent	Coll Time OS*	10:25	-	-
06-Aug-25	2447257	WBU001	Bulwer WWW Influent	Conductivity	24.8	±1.5%	mS/m
06-Aug-25	2447257	WBU001	Bulwer WWW Influent	NH3*	13.9	-	mg N/L
06-Aug-25	2447257	WBU001	Bulwer WWW Influent	NO3*	<0.50	-	mg N/L
06-Aug-25	2447256	WBU001	Bulwer WWW Influent	pH OS*	7.80	-	-
06-Aug-25	2447257	WBU001	Bulwer WWW Influent	SRP*	1604	-	ug P/L
06-Aug-25	2447257	WBU001	Bulwer WWW Influent	SS	56.0	±8.2%	mg /L
06-Aug-25	2447256	WBU001	Bulwer WWW Influent	Temperature OS*	16.8	-	°C
06-Aug-25	2447258	WBU004	Bulwer WWW Effluent	Cl2 (F) OS*	<0.05	-	mg Cl2/L
06-Aug-25	2447258	WBU004	Bulwer WWW Effluent	Cl2 (T) OS*	0.05	-	mg Cl2/L
06-Aug-25	2447260	WBU004	Bulwer WWW Effluent	COD*	194	-	mg O2/L
06-Aug-25	2447258	WBU004	Bulwer WWW Effluent	Coll Time OS*	10:15	-	-
06-Aug-25	2447260	WBU004	Bulwer WWW Effluent	Conductivity	42.1	±1.5%	mS/m
06-Aug-25	2447259	WBU004	Bulwer WWW Effluent	E.coli*	2419600	±21%	MPN/100mL
06-Aug-25	2447260	WBU004	Bulwer WWW Effluent	NH3*	25.5	-	mg N/L
06-Aug-25	2447260	WBU004	Bulwer WWW Effluent	NO3*	<0.50	-	mg N/L
06-Aug-25	2447258	WBU004	Bulwer WWW Effluent	pH OS*	7.60	-	-
06-Aug-25	2447260	WBU004	Bulwer WWW Effluent	SRP*	2827	-	ug P/L
06-Aug-25	2447260	WBU004	Bulwer WWW Effluent	SS	124	±8.2%	mg /L
06-Aug-25	2447258	WBU004	Bulwer WWW Effluent	Temperature OS*	15.6	-	°C
06-Aug-25	2447283	WRIV001	Riverside WWW Influent	COD*	284	-	mg O2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

06-Aug-25	2447282	WRIV001	Riverside WWW Influent	Coll Time OS*	08:46	-	-
06-Aug-25	2447283	WRIV001	Riverside WWW Influent	Conductivity	30.6	±1.5%	mS/m
06-Aug-25	2447283	WRIV001	Riverside WWW Influent	NH3*	2.64	-	mg N/L
06-Aug-25	2447283	WRIV001	Riverside WWW Influent	NO3*	<0.50	-	mg N/L
06-Aug-25	2447282	WRIV001	Riverside WWW Influent	pH OS*	7.60	-	-
06-Aug-25	2447283	WRIV001	Riverside WWW Influent	SRP*	230	-	ug P/L
06-Aug-25	2447283	WRIV001	Riverside WWW Influent	SS	<10	±8.2%	mg /L
06-Aug-25	2447282	WRIV001	Riverside WWW Influent	Temperature OS*	13.9	-	°C
06-Aug-25	2447284	WRIV004	Riverside WWW Final Effluent	Cl2 (F) OS*	<0.05	-	mg Cl2/L
06-Aug-25	2447284	WRIV004	Riverside WWW Final Effluent	Cl2 (T) OS*	<0.05	-	mg Cl2/L
06-Aug-25	2447286	WRIV004	Riverside WWW Final Effluent	COD*	80.7	-	mg O2/L
06-Aug-25	2447284	WRIV004	Riverside WWW Final Effluent	Coll Time OS*	08'40	-	-
06-Aug-25	2447286	WRIV004	Riverside WWW Final Effluent	Conductivity	39.7	±1.5%	mS/m
06-Aug-25	2447285	WRIV004	Riverside WWW Final Effluent	E.coli*	3	±21%	MPN/100mL
06-Aug-25	2447286	WRIV004	Riverside WWW Final Effluent	NH3*	14.0	-	mg N/L
06-Aug-25	2447286	WRIV004	Riverside WWW Final Effluent	NO3*	<0.50	-	mg N/L
06-Aug-25	2447284	WRIV004	Riverside WWW Final Effluent	pH OS*	7.50	-	-
06-Aug-25	2447286	WRIV004	Riverside WWW Final Effluent	SRP*	1586	-	ug P/L
06-Aug-25	2447286	WRIV004	Riverside WWW Final Effluent	SS	42.0	±8.2%	mg /L
06-Aug-25	2447284	WRIV004	Riverside WWW Final Effluent	Temperature OS*	13.7	-	°C
06-Aug-25	2447288	WSTA001	St Apollinaris WWW Influent	COD*	295	-	mg O2/L
06-Aug-25	2447287	WSTA001	St Apollinaris WWW Influent	Coll Time OS*	09:10	-	-
06-Aug-25	2447288	WSTA001	St Apollinaris WWW Influent	Conductivity	22.5	±1.5%	mS/m
06-Aug-25	2447288	WSTA001	St Apollinaris WWW Influent	NH3*	16.1	-	mg N/L
06-Aug-25	2447288	WSTA001	St Apollinaris WWW Influent	NO3*	<0.50	-	mg N/L
06-Aug-25	2447287	WSTA001	St Apollinaris WWW Influent	pH OS*	7.80	-	-
06-Aug-25	2447288	WSTA001	St Apollinaris WWW Influent	SRP*	2171	-	ug P/L
06-Aug-25	2447288	WSTA001	St Apollinaris WWW Influent	SS	84.0	±8.2%	mg /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

06-Aug-25	2447287	WSTA001	St Apollinaris WWW Influent	Temperature OS*	14.6	-	°C
06-Aug-25	2447289	WSTA004	St Apollinaris WWW Final Effluent M	Cl ₂ (F) OS*	0.05	-	mg Cl ₂ /L
06-Aug-25	2447289	WSTA004	St Apollinaris WWW Final Effluent M	Cl ₂ (T) OS*	0.09	-	mg Cl ₂ /L
06-Aug-25	2447291	WSTA004	St Apollinaris WWW Final Effluent M	COD*	102	-	mg O ₂ /L
06-Aug-25	2447289	WSTA004	St Apollinaris WWW Final Effluent M	Coll Time OS*	09:05	-	-
06-Aug-25	2447291	WSTA004	St Apollinaris WWW Final Effluent M	Conductivity	38.8	±1.5%	mS/m
06-Aug-25	2447290	WSTA004	St Apollinaris WWW Final Effluent M	E.coli*	108	±21%	MPN/100mL
06-Aug-25	2447291	WSTA004	St Apollinaris WWW Final Effluent M	NH ₃ *	13.7	-	mg N/L
06-Aug-25	2447291	WSTA004	St Apollinaris WWW Final Effluent M	NO ₃ *	<0.50	-	mg N/L
06-Aug-25	2447289	WSTA004	St Apollinaris WWW Final Effluent M	pH OS*	7.60	-	-
06-Aug-25	2447291	WSTA004	St Apollinaris WWW Final Effluent M	SRP*	1191	-	ug P/L
06-Aug-25	2447291	WSTA004	St Apollinaris WWW Final Effluent M	SS	30.0	±8.2%	mg /L
06-Aug-25	2447289	WSTA004	St Apollinaris WWW Final Effluent M	Temperature OS*	14.0	-	°C
08-Aug-25	2448100	RIBS001	Ibisi Downstram WWW	Cl ₂ (F) OS*	<0.05	-	mg Cl ₂ /L
08-Aug-25	2448100	RIBS001	Ibisi Downstram WWW	Cl ₂ (T) OS*	<0.05	-	mg Cl ₂ /L
08-Aug-25	2448104	RIBS001	Ibisi Downstram WWW	COD*	<20.0	-	mg O ₂ /L
08-Aug-25	2448100	RIBS001	Ibisi Downstram WWW	Coll Time OS*	08:00	-	-
08-Aug-25	2448102	RIBS001	Ibisi Downstram WWW	Colour	10.9	±6.5%	mg Pt-Co/L
08-Aug-25	2448104	RIBS001	Ibisi Downstram WWW	Conductivity	12.9	±1.5%	mS/m
08-Aug-25	2448101	RIBS001	Ibisi Downstram WWW	E.coli*	>2420	±21%	MPN/100mL
08-Aug-25	2448104	RIBS001	Ibisi Downstram WWW	NH ₃ *	1.47	±5.5%	mg N/L
08-Aug-25	2448104	RIBS001	Ibisi Downstram WWW	NO ₂ *	<0.10	±2.4%	mg N/L
08-Aug-25	2448104	RIBS001	Ibisi Downstram WWW	NO ₃ *	0.63	±2.9%	mg N/L
08-Aug-25	2448103	RIBS001	Ibisi Downstram WWW	OG*	<1.20	-	mg /L
08-Aug-25	2448100	RIBS001	Ibisi Downstram WWW	pH OS*	7.70	-	-
08-Aug-25	2448104	RIBS001	Ibisi Downstram WWW	SRP*	170	±7.7%	ug P/L
08-Aug-25	2448102	RIBS001	Ibisi Downstram WWW	SS	12.8	±3.7%	mg /L
08-Aug-25	2448100	RIBS001	Ibisi Downstram WWW	Temperature OS*	13.2	-	°C
08-Aug-25	2448144	WIB001	Ibisi WWW Influent	COD*	365	-	mg O ₂ /L
08-Aug-25	2448143	WIB001	Ibisi WWW Influent	Coll Time OS*	07:17	-	-
08-Aug-25	2448144	WIB001	Ibisi WWW Influent	Conductivity	42.9	±1.5%	mS/m
08-Aug-25	2448144	WIB001	Ibisi WWW Influent	NH ₃ *	38.5	-	mg N/L
08-Aug-25	2448144	WIB001	Ibisi WWW Influent	NO ₃ *	<0.50	-	mg N/L
08-Aug-25	2448143	WIB001	Ibisi WWW Influent	pH OS*	7.60	-	-
08-Aug-25	2448144	WIB001	Ibisi WWW Influent	SRP*	4777	-	ug P/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

08-Aug-25	2448144	WIB001	Ibisi WWW Influent	SS	199	±8.2%	mg /L
08-Aug-25	2448143	WIB001	Ibisi WWW Influent	Temperature OS*	12.3	-	°C
08-Aug-25	2448145	WIB002	Ibisi WWW Effluent	Cl2 (F) OS*	<0.05	-	mg Cl2/L
08-Aug-25	2448145	WIB002	Ibisi WWW Effluent	Cl2 (T) OS*	0.05	-	mg Cl2/L
08-Aug-25	2448147	WIB002	Ibisi WWW Effluent	COD*	70.9	-	mg O2/L
08-Aug-25	2448145	WIB002	Ibisi WWW Effluent	Coll Time OS*	07:00	-	-
08-Aug-25	2448147	WIB002	Ibisi WWW Effluent	Conductivity	43.2	±1.5%	mS/m
08-Aug-25	2448146	WIB002	Ibisi WWW Effluent	E.coli*	17329	±21%	MPN/100mL
08-Aug-25	2448147	WIB002	Ibisi WWW Effluent	NH3*	17.1	-	mg N/L
08-Aug-25	2448147	WIB002	Ibisi WWW Effluent	NO3*	2.38	-	mg N/L
08-Aug-25	2448145	WIB002	Ibisi WWW Effluent	pH OS*	7.60	-	-
08-Aug-25	2448147	WIB002	Ibisi WWW Effluent	SRP*	2513	-	ug P/L
08-Aug-25	2448147	WIB002	Ibisi WWW Effluent	SS	52.0	±8.2%	mg /L
08-Aug-25	2448145	WIB002	Ibisi WWW Effluent	Temperature OS*	14.1	-	°C
13-Aug-25	2451755	WPO001	Polela WWW Influent	COD*	235	-	mg O2/L
13-Aug-25	2451754	WPO001	Polela WWW Influent	Coll Time OS*	11:10	-	-
13-Aug-25	2451755	WPO001	Polela WWW Influent	Conductivity	55.9	±1.5%	mS/m
13-Aug-25	2451755	WPO001	Polela WWW Influent	NH3*	39.1	-	mg N/L
13-Aug-25	2451755	WPO001	Polela WWW Influent	NO3*	<0.50	-	mg N/L
13-Aug-25	2451754	WPO001	Polela WWW Influent	pH OS*	7.80	-	-
13-Aug-25	2451755	WPO001	Polela WWW Influent	SRP*	9676	-	ug P/L
13-Aug-25	2451755	WPO001	Polela WWW Influent	SS	585	±8.2%	mg /L
13-Aug-25	2451754	WPO001	Polela WWW Influent	Temperature OS*	20.3	-	°C
14-Aug-25	2452470	WUMZ001	Umzimkhulu WWW Influent	COD*	575	-	mg O2/L
14-Aug-25	2452469	WUMZ001	Umzimkhulu WWW Influent	Coll Time OS*	09:10	-	-
14-Aug-25	2452470	WUMZ001	Umzimkhulu WWW Influent	Conductivity	99.6	±1.5%	mS/m
14-Aug-25	2452470	WUMZ001	Umzimkhulu WWW Influent	NH3*	46.5	-	mg N/L
14-Aug-25	2452470	WUMZ001	Umzimkhulu WWW Influent	NO3*	<0.50	-	mg N/L
14-Aug-25	2452469	WUMZ001	Umzimkhulu WWW Influent	pH OS*	7.80	-	-
14-Aug-25	2452470	WUMZ001	Umzimkhulu WWW Influent	SRP*	5404	-	ug P/L
14-Aug-25	2452470	WUMZ001	Umzimkhulu WWW Influent	SS	201	±8.2%	mg /L
14-Aug-25	2452469	WUMZ001	Umzimkhulu WWW Influent	Temperature OS*	20.8	-	°C
14-Aug-25	2452471	WUMZ004	Umzimkhulu WWW Final Effluent M	Cl2 (F) OS*	<0.05	-	mg Cl2/L
14-Aug-25	2452471	WUMZ004	Umzimkhulu WWW Final Effluent M	Cl2 (T) OS*	0.06	-	mg Cl2/L
14-Aug-25	2452473	WUMZ004	Umzimkhulu WWW Final Effluent M	COD*	67.6	-	mg O2/L
14-Aug-25	2452471	WUMZ004	Umzimkhulu WWW Final Effluent M	Coll Time OS*	09:04	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

14-Aug-25	2452473	WUMZ004	Umzimkhulu WWW Final Effluent M	Conductivity	47.5	±1.5%	mS/m
14-Aug-25	2452472	WUMZ004	Umzimkhulu WWW Final Effluent M	E.coli*	>2420	±21%	MPN/100mL
14-Aug-25	2452473	WUMZ004	Umzimkhulu WWW Final Effluent M	NH3*	<0.50	-	mg N/L
14-Aug-25	2452473	WUMZ004	Umzimkhulu WWW Final Effluent M	NO3*	17.7	-	mg N/L
14-Aug-25	2452471	WUMZ004	Umzimkhulu WWW Final Effluent M	pH OS*	7.60	-	-
14-Aug-25	2452473	WUMZ004	Umzimkhulu WWW Final Effluent M	SRP*	2919	-	ug P/L
14-Aug-25	2452473	WUMZ004	Umzimkhulu WWW Final Effluent M	SS	29.0	±8.2%	mg /L
14-Aug-25	2452471	WUMZ004	Umzimkhulu WWW Final Effluent M	Temperature OS*	20.3	-	°C
21-Aug-25	2454791	RKOK001	River above Kokstad	COD*	<20.0	-	mg O2/L
21-Aug-25	2454787	RKOK001	River above Kokstad	Coll Time OS*	08:14	-	-
21-Aug-25	2454789	RKOK001	River above Kokstad	Colour	13.2	±6.5%	mg Pt-Co/L
21-Aug-25	2454791	RKOK001	River above Kokstad	Conductivity	18.6	±1.5%	mS/m
21-Aug-25	2454788	RKOK001	River above Kokstad	E.coli*	11199	±21%	MPN/100mL
21-Aug-25	2454791	RKOK001	River above Kokstad	NH3*	0.38	±5.5%	mg N/L
21-Aug-25	2454791	RKOK001	River above Kokstad	NO2*	<0.10	±2.4%	mg N/L
21-Aug-25	2454791	RKOK001	River above Kokstad	NO3*	0.48	±2.9%	mg N/L
21-Aug-25	2454790	RKOK001	River above Kokstad	OG*	5.60	-	mg /L
21-Aug-25	2454787	RKOK001	River above Kokstad	pH OS*	7.20	-	-
21-Aug-25	2454791	RKOK001	River above Kokstad	SRP*	68.1	±7.7%	ug P/L
21-Aug-25	2454789	RKOK001	River above Kokstad	SS	<10.0	±3.7%	mg /L
21-Aug-25	2454787	RKOK001	River above Kokstad	Temperature OS*	12.9	-	°C
21-Aug-25	2454792	RKOK002	River below Kokstad	Cl2 (F) OS*	0.05	-	mg Cl2/L
21-Aug-25	2454792	RKOK002	River below Kokstad	Cl2 (T) OS*	0.07	-	mg Cl2/L
21-Aug-25	2454796	RKOK002	River below Kokstad	COD*	<20.0	-	mg O2/L
21-Aug-25	2454792	RKOK002	River below Kokstad	Coll Time OS*	08:30	-	-
21-Aug-25	2454794	RKOK002	River below Kokstad	Colour	12.6	±6.5%	mg Pt-Co/L
21-Aug-25	2454796	RKOK002	River below Kokstad	Conductivity	19.0	±1.5%	mS/m
21-Aug-25	2454793	RKOK002	River below Kokstad	E.coli*	12033	±21%	MPN/100mL
21-Aug-25	2454796	RKOK002	River below Kokstad	NH3*	0.63	±5.5%	mg N/L
21-Aug-25	2454796	RKOK002	River below Kokstad	NO2*	<0.10	±2.4%	mg N/L
21-Aug-25	2454796	RKOK002	River below Kokstad	NO3*	0.70	±2.9%	mg N/L
21-Aug-25	2454795	RKOK002	River below Kokstad	OG*	8.40	-	mg /L
21-Aug-25	2454792	RKOK002	River below Kokstad	pH OS*	7.20	-	-
21-Aug-25	2454796	RKOK002	River below Kokstad	SRP*	110	±7.7%	ug P/L
21-Aug-25	2454794	RKOK002	River below Kokstad	SS	<10.0	±3.7%	mg /L
21-Aug-25	2454792	RKOK002	River below Kokstad	Temperature OS*	13.1	-	°C
21-Aug-25	2454882	WKK001	KoKstad WWW Influent	COD*	2135	-	mg O2/L
21-Aug-25	2454880	WKK001	KoKstad WWW Influent	Coll Time OS*	08:41	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

21-Aug-25	2454882	WKK001	KoKstad WWW Influent	Conductivity	93.6	±1.5%	mS/m
21-Aug-25	2454881	WKK001	KoKstad WWW Influent	E.coli*	>2419600	±21%	MPN/100mL
21-Aug-25	2454882	WKK001	KoKstad WWW Influent	NH3*	45.1	-	mg N/L
21-Aug-25	2454882	WKK001	KoKstad WWW Influent	NO3*	<0.50	-	mg N/L
21-Aug-25	2454880	WKK001	KoKstad WWW Influent	pH OS*	7.80	-	-
21-Aug-25	2454882	WKK001	KoKstad WWW Influent	SRP*	13117	-	ug P/L
21-Aug-25	2454882	WKK001	KoKstad WWW Influent	SS	2797	±8.2%	mg /L
21-Aug-25	2454880	WKK001	KoKstad WWW Influent	Temperature OS*	22.6	-	°C
21-Aug-25	2454883	WKK004	Kokstad WWW Final Effluent M	Cl2 (F) OS*	<0.05	-	mg Cl2/L
21-Aug-25	2454883	WKK004	Kokstad WWW Final Effluent M	Cl2 (T) OS*	<0.05	-	mg Cl2/L
21-Aug-25	2454887	WKK004	Kokstad WWW Final Effluent M	COD*	32.7	-	mg O2/L
21-Aug-25	2454883	WKK004	Kokstad WWW Final Effluent M	Coll Time OS*	08:28	-	-
21-Aug-25	2454885	WKK004	Kokstad WWW Final Effluent M	Colour	20.7	±6.5%	mg Pt-Co/L
21-Aug-25	2454887	WKK004	Kokstad WWW Final Effluent M	Conductivity	64.1	±1.5%	mS/m
21-Aug-25	2454884	WKK004	Kokstad WWW Final Effluent M	E.coli*	16	±21%	MPN/100mL
21-Aug-25	2454887	WKK004	Kokstad WWW Final Effluent M	NH3*	6.91	-	mg N/L
21-Aug-25	2454887	WKK004	Kokstad WWW Final Effluent M	NO2*	1.00	-	mg N/L
21-Aug-25	2454887	WKK004	Kokstad WWW Final Effluent M	NO3*	5.90	-	mg N/L
21-Aug-25	2454886	WKK004	Kokstad WWW Final Effluent M	OG*	9.00	-	mg /L
21-Aug-25	2454883	WKK004	Kokstad WWW Final Effluent M	pH OS*	7.70	-	-
21-Aug-25	2454887	WKK004	Kokstad WWW Final Effluent M	SRP*	2040	-	ug P/L
21-Aug-25	2454887	WKK004	Kokstad WWW Final Effluent M	SS	21.0	±8.2%	mg /L
21-Aug-25	2454883	WKK004	Kokstad WWW Final Effluent M	Temperature OS*	20.3	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)