

Date: 7th December 2025

The Executive Director: Water Services Department

Harry Gwala District Municipality

40 Main Street

Ixopo

3276

Attention: Basetsana Khathalib and Bheki Nene

NOVEMBER 2025 TREATED WATER (FINAL) RESULTS

Please find November 2025 Treated Water (Final) results tabulated below for samples received during November 2025. Determinands marked with an asterix are unaccredited and are not included in uMngeni-uThukela Water's schedule of accreditation.

Please contact us immediately should you have any queries.

Yours' Sincerely



Mr M Sewcharran

Client Services Manager

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Sample Date	Sample Number	Sampling Point	Description	Determinand	Result	UOM	Unit
03-Nov-25	2508136	TFR002	Franklin Final	Al (AE)	167	±7.6%	µg Al/L
03-Nov-25	2508131	TFR002	Franklin Final	Cl ₂ (F) OS*	0.40	-	mg Cl ₂ /L
03-Nov-25	2508131	TFR002	Franklin Final	Cl ₂ (T) OS*	0.52	-	mg Cl ₂ /L
03-Nov-25	2508132	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
03-Nov-25	2508132	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10mL
03-Nov-25	2508131	TFR002	Franklin Final	Coll Time OS*	07:10	-	-
03-Nov-25	2508135	TFR002	Franklin Final	Colour	<1.00	±6.5%	mg Pt-Co/L
03-Nov-25	2508134	TFR002	Franklin Final	Conductivity	11.3	±1.5%	mS/m
03-Nov-25	2508132	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
03-Nov-25	2508136	TFR002	Franklin Final	Fe (AE)	0.06	±5.4%	mg Fe/L
03-Nov-25	2508132	TFR002	Franklin Final	HPC 37*	0	±21%	CFU/mL
03-Nov-25	2508136	TFR002	Franklin Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
03-Nov-25	2508131	TFR002	Franklin Final	pH OS*	7.70	-	-
03-Nov-25	2508131	TFR002	Franklin Final	Temperature OS*	18.0	-	°C
03-Nov-25	2508135	TFR002	Franklin Final	Turbidity	1.5	±6.1%	NTU
03-Nov-25	2508137	TFR003	Franklin Police Station Retic	Cl ₂ (F) OS*	0.32	-	mg Cl ₂ /L
03-Nov-25	2508137	TFR003	Franklin Police Station Retic	Cl ₂ (T) OS*	0.44	-	mg Cl ₂ /L
03-Nov-25	2508138	TFR003	Franklin Police Station Retic	Coliforms*	0	±15%	MPN/100mL
03-Nov-25	2508137	TFR003	Franklin Police Station Retic	Coll Time OS*	07:30	-	-
03-Nov-25	2508138	TFR003	Franklin Police Station Retic	E.coli*	0	±14%	MPN/100mL
03-Nov-25	2508138	TFR003	Franklin Police Station Retic	HPC 37*	0	±21%	CFU/mL
03-Nov-25	2508137	TFR003	Franklin Police Station Retic	pH OS*	7.60	-	-
03-Nov-25	2508137	TFR003	Franklin Police Station Retic	Temperature OS*	17.8	-	°C
03-Nov-25	2508140	TFR003	Franklin Police Station Retic	Turbidity	0.9	±6.1%	NTU
03-Nov-25	2508151	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
03-Nov-25	2508146	TKK002	Kokstad Final	Cl ₂ (F) OS*	2.05	-	mg Cl ₂ /L
03-Nov-25	2508146	TKK002	Kokstad Final	Cl ₂ (T) OS*	2.15	-	mg Cl ₂ /L
03-Nov-25	2508147	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
03-Nov-25	2508147	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10mL
03-Nov-25	2508146	TKK002	Kokstad Final	Coll Time OS*	07:44	-	-
03-Nov-25	2508150	TKK002	Kokstad Final	Colour	<1.00	±6.5%	mg Pt-Co/L
03-Nov-25	2508149	TKK002	Kokstad Final	Conductivity	15.9	±1.5%	mS/m
03-Nov-25	2508147	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
03-Nov-25	2508147	TKK002	Kokstad Final	HPC 37*	1	±21%	CFU/mL
03-Nov-25	2508150	TKK002	Kokstad Final	Odour*	Nil	-	-
03-Nov-25	2508146	TKK002	Kokstad Final	pH OS*	7.30	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

03-Nov-25	2508150	TKK002	Kokstad Final	Taste*	Nil	-	-
03-Nov-25	2508146	TKK002	Kokstad Final	Temperature OS*	19.5	-	°C
03-Nov-25	2508150	TKK002	Kokstad Final	Turbidity	0.2	±6.1%	NTU
03-Nov-25	2508161	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl ₂ (F) OS*	1.30	-	mg Cl ₂ /L
03-Nov-25	2508161	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl ₂ (T) OS*	1.40	-	mg Cl ₂ /L
03-Nov-25	2508162	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliforms*	0	±15%	MPN/100mL
03-Nov-25	2508161	TKK006	Kokstad Bongweni Correctional Serv Retic	Coll Time OS*	07:33	-	-
03-Nov-25	2508164	TKK006	Kokstad Bongweni Correctional Serv Retic	Colour	1.40	±6.5%	mg Pt-Co/L
03-Nov-25	2508162	TKK006	Kokstad Bongweni Correctional Serv Retic	E.coli*	0	±14%	MPN/100mL
03-Nov-25	2508162	TKK006	Kokstad Bongweni Correctional Serv Retic	HPC 37*	0	±21%	CFU/mL
03-Nov-25	2508164	TKK006	Kokstad Bongweni Correctional Serv Retic	Odour*	Nil	-	-
03-Nov-25	2508161	TKK006	Kokstad Bongweni Correctional Serv Retic	pH OS*	7.50	-	-
03-Nov-25	2508164	TKK006	Kokstad Bongweni Correctional Serv Retic	Taste*	Nil	-	-
03-Nov-25	2508161	TKK006	Kokstad Bongweni Correctional Serv Retic	Temperature OS*	21.3	-	°C
03-Nov-25	2508164	TKK006	Kokstad Bongweni Correctional Serv Retic	Turbidity	<0.2	±6.1%	NTU
03-Nov-25	2508165	TKK007	Kokstad Shayamoya Reticulation	Cl ₂ (F) OS*	0.67	-	mg Cl ₂ /L
03-Nov-25	2508165	TKK007	Kokstad Shayamoya Reticulation	Cl ₂ (T) OS*	0.79	-	mg Cl ₂ /L
03-Nov-25	2508166	TKK007	Kokstad Shayamoya Reticulation	Coliforms*	0	±15%	MPN/100mL
03-Nov-25	2508165	TKK007	Kokstad Shayamoya Reticulation	Coll Time OS*	08:27	-	-
03-Nov-25	2508166	TKK007	Kokstad Shayamoya Reticulation	E.coli*	0	±14%	MPN/100mL
03-Nov-25	2508166	TKK007	Kokstad Shayamoya Reticulation	HPC 37*	0	±21%	CFU/mL
03-Nov-25	2508165	TKK007	Kokstad Shayamoya Reticulation	pH OS*	7.40	-	-
03-Nov-25	2508165	TKK007	Kokstad Shayamoya Reticulation	Temperature OS*	20.1	-	°C
03-Nov-25	2508168	TKK007	Kokstad Shayamoya Reticulation	Turbidity	0.3	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

03-Nov-25	2508169	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (F) OS*	1.03	-	mg Cl2/L
03-Nov-25	2508169	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (T) OS*	1.14	-	mg Cl2/L
03-Nov-25	2508170	TKK009	Kokstad Farm Fresh Produce Market	Coliforms*	0	±15%	MPN/100mL
03-Nov-25	2508169	TKK009	Kokstad Farm Fresh Produce Market	Coll Time OS*	08:50	-	-
03-Nov-25	2508170	TKK009	Kokstad Farm Fresh Produce Market	E.coli*	0	±14%	MPN/100mL
03-Nov-25	2508170	TKK009	Kokstad Farm Fresh Produce Market	HPC 37*	17	±21%	CFU/mL
03-Nov-25	2508169	TKK009	Kokstad Farm Fresh Produce Market	pH OS*	7.40	-	-
03-Nov-25	2508169	TKK009	Kokstad Farm Fresh Produce Market	Temperature OS*	20.8	-	°C
03-Nov-25	2508172	TKK009	Kokstad Farm Fresh Produce Market	Turbidity	0.4	±6.1%	NTU
03-Nov-25	2508205	TNJU003	KwaNjunga Reticulation	Cl2 (F) OS*	0.38	-	mg Cl2/L
03-Nov-25	2508205	TNJU003	KwaNjunga Reticulation	Cl2 (T) OS*	0.50	-	mg Cl2/L
03-Nov-25	2508206	TNJU003	KwaNjunga Reticulation	Coliforms*	0	±15%	MPN/100mL
03-Nov-25	2508205	TNJU003	KwaNjunga Reticulation	Coll Time OS*	06:10	-	-
03-Nov-25	2508206	TNJU003	KwaNjunga Reticulation	E.coli*	0	±14%	MPN/100mL
03-Nov-25	2508206	TNJU003	KwaNjunga Reticulation	HPC 37*	0	±21%	CFU/mL
03-Nov-25	2508205	TNJU003	KwaNjunga Reticulation	pH OS*	7.60	-	-
03-Nov-25	2508205	TNJU003	KwaNjunga Reticulation	Temperature OS*	18.7	-	°C
03-Nov-25	2508208	TNJU003	KwaNjunga Reticulation	Turbidity	0.5	±6.1%	NTU
04-Nov-25	2508173	TKK012	Kokstad FET College Reticulation	Cl2 (F) OS*	1.02	-	mg Cl2/L
04-Nov-25	2508173	TKK012	Kokstad FET College Reticulation	Cl2 (T) OS*	1.15	-	mg Cl2/L
04-Nov-25	2508174	TKK012	Kokstad FET College Reticulation	Coliforms*	0	±15%	MPN/100mL
04-Nov-25	2508173	TKK012	Kokstad FET College Reticulation	Coll Time OS*	08:20	-	-
04-Nov-25	2508177	TKK012	Kokstad FET College Reticulation	Colour	1.10	±6.5%	mg Pt-Co/L
04-Nov-25	2508176	TKK012	Kokstad FET College Reticulation	Conductivity	15.8	±1.5%	mS/m
04-Nov-25	2508174	TKK012	Kokstad FET College Reticulation	E.coli*	0	±14%	MPN/100mL
04-Nov-25	2508174	TKK012	Kokstad FET College Reticulation	HPC 37*	0	±21%	CFU/mL
04-Nov-25	2508173	TKK012	Kokstad FET College Reticulation	pH OS*	7.50	-	-
04-Nov-25	2508173	TKK012	Kokstad FET College Reticulation	Temperature OS*	20.2	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

04-Nov-25	2508177	TKK012	Kokstad FET College Reticulation	Turbidity	<0.2	±6.1%	NTU
04-Nov-25	2508758	TQU002	Mnqumeni Final	Cl ₂ (F) OS*	0.54	-	mg Cl ₂ /L
04-Nov-25	2508758	TQU002	Mnqumeni Final	Cl ₂ (T) OS*	0.65	-	mg Cl ₂ /L
04-Nov-25	2508759	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
04-Nov-25	2508758	TQU002	Mnqumeni Final	Coll Time OS*	07:36	-	-
04-Nov-25	2508761	TQU002	Mnqumeni Final	Conductivity	15.4	±1.5%	mS/m
04-Nov-25	2508759	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
04-Nov-25	2508759	TQU002	Mnqumeni Final	HPC 37*	0	±21%	CFU/mL
04-Nov-25	2508758	TQU002	Mnqumeni Final	pH OS*	7.40	-	-
04-Nov-25	2508758	TQU002	Mnqumeni Final	Temperature OS*	23.6	-	°C
04-Nov-25	2508762	TQU002	Mnqumeni Final	Turbidity	0.4	±6.1%	NTU
04-Nov-25	2508763	TQU003	Mnqumeni Reticulation	Cl ₂ (F) OS*	0.17	-	mg Cl ₂ /L
04-Nov-25	2508763	TQU003	Mnqumeni Reticulation	Cl ₂ (T) OS*	0.28	-	mg Cl ₂ /L
04-Nov-25	2508764	TQU003	Mnqumeni Reticulation	Coliforms*	0	±15%	MPN/100mL
04-Nov-25	2508763	TQU003	Mnqumeni Reticulation	Coll Time OS*	07:55	-	-
04-Nov-25	2508764	TQU003	Mnqumeni Reticulation	E.coli*	0	±14%	MPN/100mL
04-Nov-25	2508764	TQU003	Mnqumeni Reticulation	HPC 37*	0	±21%	CFU/mL
04-Nov-25	2508763	TQU003	Mnqumeni Reticulation	pH OS*	7.20	-	-
04-Nov-25	2508763	TQU003	Mnqumeni Reticulation	Temperature OS*	23.6	-	°C
04-Nov-25	2508766	TQU003	Mnqumeni Reticulation	Turbidity	0.3	±6.1%	NTU
04-Nov-25	2508777	TSQ002	Esiqanduleni Final	Al (AE)	90.7	±7.6%	µg Al/L
04-Nov-25	2508772	TSQ002	Esiqanduleni Final	Cl ₂ (F) OS*	1.17	-	mg Cl ₂ /L
04-Nov-25	2508772	TSQ002	Esiqanduleni Final	Cl ₂ (T) OS*	1.24	-	mg Cl ₂ /L
04-Nov-25	2508773	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
04-Nov-25	2508772	TSQ002	Esiqanduleni Final	Coll Time OS*	08:05	-	-
04-Nov-25	2508776	TSQ002	Esiqanduleni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
04-Nov-25	2508775	TSQ002	Esiqanduleni Final	Conductivity	11.4	±1.5%	mS/m
04-Nov-25	2508773	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
04-Nov-25	2508773	TSQ002	Esiqanduleni Final	HPC 37*	0	±21%	CFU/mL
04-Nov-25	2508776	TSQ002	Esiqanduleni Final	Odour*	Mild Chlorinous	-	-
04-Nov-25	2508772	TSQ002	Esiqanduleni Final	pH OS*	7.40	-	-
04-Nov-25	2508772	TSQ002	Esiqanduleni Final	Temperature OS*	22.4	-	°C
04-Nov-25	2508776	TSQ002	Esiqanduleni Final	Turbidity	2.3	±6.1%	NTU
04-Nov-25	2508778	TSQ003	Esiqanduleni Reticulation	Cl ₂ (F) OS*	0.84	-	mg Cl ₂ /L
04-Nov-25	2508778	TSQ003	Esiqanduleni Reticulation	Cl ₂ (T) OS*	0.99	-	mg Cl ₂ /L
04-Nov-25	2508779	TSQ003	Esiqanduleni Reticulation	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

04-Nov-25	2508778	TSQ003	Esiqanduleni Reticulation	Coll Time OS*	08:20	-	-
04-Nov-25	2508779	TSQ003	Esiqanduleni Reticulation	E.coli*	0	±14%	MPN/100mL
04-Nov-25	2508779	TSQ003	Esiqanduleni Reticulation	HPC 37*	0	±21%	CFU/mL
04-Nov-25	2508778	TSQ003	Esiqanduleni Reticulation	pH OS*	7.60	-	-
04-Nov-25	2508778	TSQ003	Esiqanduleni Reticulation	Temperature OS*	23.0	-	°C
04-Nov-25	2508781	TSQ003	Esiqanduleni Reticulation	Turbidity	2.8	±6.1%	NTU
05-Nov-25	2509450	TBU002	Bulwer Final	Cl2 (F) OS*	1.18	-	mg Cl2/L
05-Nov-25	2509450	TBU002	Bulwer Final	Cl2 (T) OS*	1.28	-	mg Cl2/L
05-Nov-25	2509451	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
05-Nov-25	2509450	TBU002	Bulwer Final	Coll Time OS*	09:58	-	-
05-Nov-25	2509454	TBU002	Bulwer Final	Colour	<1.00	±6.5%	mg Pt-Co/L
05-Nov-25	2509453	TBU002	Bulwer Final	Conductivity	5.73	±1.5%	mS/m
05-Nov-25	2509451	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
05-Nov-25	2509451	TBU002	Bulwer Final	HPC 37*	0	±21%	CFU/mL
05-Nov-25	2509454	TBU002	Bulwer Final	Odour*	Nil	-	-
05-Nov-25	2509450	TBU002	Bulwer Final	pH OS*	7.30	-	-
05-Nov-25	2509450	TBU002	Bulwer Final	Temperature OS*	19.2	-	°C
05-Nov-25	2509454	TBU002	Bulwer Final	Turbidity	4.6	±6.1%	NTU
05-Nov-25	2509455	TBU005	Bulwer Mountain Park Hotel Retic	Cl2 (F) OS*	1.10	-	mg Cl2/L
05-Nov-25	2509455	TBU005	Bulwer Mountain Park Hotel Retic	Cl2 (T) OS*	1.21	-	mg Cl2/L
05-Nov-25	2509456	TBU005	Bulwer Mountain Park Hotel Retic	Coliforms*	0	±15%	MPN/100mL
05-Nov-25	2509455	TBU005	Bulwer Mountain Park Hotel Retic	Coll Time OS*	10:27	-	-
05-Nov-25	2509456	TBU005	Bulwer Mountain Park Hotel Retic	E.coli*	0	±14%	MPN/100mL
05-Nov-25	2509456	TBU005	Bulwer Mountain Park Hotel Retic	HPC 37*	0	±21%	CFU/mL
05-Nov-25	2509455	TBU005	Bulwer Mountain Park Hotel Retic	pH OS*	7.40	-	-
05-Nov-25	2509455	TBU005	Bulwer Mountain Park Hotel Retic	Temperature OS*	20.1	-	°C
05-Nov-25	2509458	TBU005	Bulwer Mountain Park Hotel Retic	Turbidity	11.6	±6.1%	NTU
05-Nov-25	2509469	TCR002	Creighton Final	Al (AE)	252	±7.6%	µg Al/L
05-Nov-25	2509464	TCR002	Creighton Final	Cl2 (F) OS*	1.78	-	mg Cl2/L
05-Nov-25	2509464	TCR002	Creighton Final	Cl2 (T) OS*	1.89	-	mg Cl2/L
05-Nov-25	2509465	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
05-Nov-25	2509464	TCR002	Creighton Final	Coll Time OS*	07:30	-	-
05-Nov-25	2509467	TCR002	Creighton Final	Conductivity	11.5	±1.5%	mS/m
05-Nov-25	2509465	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
05-Nov-25	2509465	TCR002	Creighton Final	HPC 37*	0	±21%	CFU/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

05-Nov-25	2509464	TCR002	Creighton Final	pH OS*	7.30	-	-
05-Nov-25	2509464	TCR002	Creighton Final	Temperature OS*	18.4	-	°C
05-Nov-25	2509468	TCR002	Creighton Final	Turbidity	0.7	±6.1%	NTU
05-Nov-25	2509470	TCR004	Creighton Madondo Cottages	Cl ₂ (F) OS*	0.46	-	mg Cl ₂ /L
05-Nov-25	2509470	TCR004	Creighton Madondo Cottages	Cl ₂ (T) OS*	0.48	-	mg Cl ₂ /L
05-Nov-25	2509471	TCR004	Creighton Madondo Cottages	Coliforms*	0	±15%	MPN/100mL
05-Nov-25	2509470	TCR004	Creighton Madondo Cottages	Coll Time OS*	07:22	-	-
05-Nov-25	2509474	TCR004	Creighton Madondo Cottages	Colour	<1.00	±6.5%	mg Pt-Co/L
05-Nov-25	2509473	TCR004	Creighton Madondo Cottages	Conductivity	11.2	±1.5%	mS/m
05-Nov-25	2509471	TCR004	Creighton Madondo Cottages	E.coli*	0	±14%	MPN/100mL
05-Nov-25	2509471	TCR004	Creighton Madondo Cottages	HPC 37*	0	±21%	CFU/mL
05-Nov-25	2509470	TCR004	Creighton Madondo Cottages	pH OS*	7.30	-	-
05-Nov-25	2509470	TCR004	Creighton Madondo Cottages	Temperature OS*	18.3	-	°C
05-Nov-25	2509474	TCR004	Creighton Madondo Cottages	Turbidity	1.2	±6.1%	NTU
05-Nov-25	2509484	THL002	Hlanganani Final	Cl ₂ (F) OS*	0.52	-	mg Cl ₂ /L
05-Nov-25	2509484	THL002	Hlanganani Final	Cl ₂ (T) OS*	0.60	-	mg Cl ₂ /L
05-Nov-25	2509485	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
05-Nov-25	2509484	THL002	Hlanganani Final	Coll Time OS*	11:00	-	-
05-Nov-25	2509488	THL002	Hlanganani Final	Colour	<1.00	±6.5%	mg Pt-Co/L
05-Nov-25	2509487	THL002	Hlanganani Final	Conductivity	11.4	±1.5%	mS/m
05-Nov-25	2509485	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
05-Nov-25	2509485	THL002	Hlanganani Final	HPC 37*	0	±21%	CFU/mL
05-Nov-25	2509488	THL002	Hlanganani Final	Odour*	Mild Chlorinous	-	-
05-Nov-25	2509484	THL002	Hlanganani Final	pH OS*	7.40	-	-
05-Nov-25	2509488	THL002	Hlanganani Final	Taste*	Mild Chlorinous	-	-
05-Nov-25	2509484	THL002	Hlanganani Final	Temperature OS*	21.2	-	°C
05-Nov-25	2509488	THL002	Hlanganani Final	Turbidity	<0.2	±6.1%	NTU
05-Nov-25	2509489	THL003	Hlanganani Clinic Reticulation	Cl ₂ (F) OS*	0.50	-	mg Cl ₂ /L
05-Nov-25	2509489	THL003	Hlanganani Clinic Reticulation	Cl ₂ (T) OS*	0.66	-	mg Cl ₂ /L
05-Nov-25	2509490	THL003	Hlanganani Clinic Reticulation	Coliforms*	0	±15%	MPN/100mL
05-Nov-25	2509489	THL003	Hlanganani Clinic Reticulation	Coll Time OS*	11:15	-	-
05-Nov-25	2509490	THL003	Hlanganani Clinic Reticulation	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

05-Nov-25	2509490	THL003	Hlanganani Clinic Reticulation	HPC 37*	0	±21%	CFU/mL
05-Nov-25	2509489	THL003	Hlanganani Clinic Reticulation	pH OS*	7.40	-	-
05-Nov-25	2509489	THL003	Hlanganani Clinic Reticulation	Temperature OS*	20.8	-	°C
05-Nov-25	2509492	THL003	Hlanganani Clinic Reticulation	Turbidity	0.2	±6.1%	NTU
05-Nov-25	2509507	TMAN002	Mangwaneni Final	Cl2 (F) OS*	0.47	-	mg Cl2/L
05-Nov-25	2509507	TMAN002	Mangwaneni Final	Cl2 (T) OS*	0.59	-	mg Cl2/L
05-Nov-25	2509508	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
05-Nov-25	2509507	TMAN002	Mangwaneni Final	Coll Time OS*	10:37	-	-
05-Nov-25	2509511	TMAN002	Mangwaneni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
05-Nov-25	2509510	TMAN002	Mangwaneni Final	Conductivity	10.5	±1.5%	mS/m
05-Nov-25	2509508	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
05-Nov-25	2509508	TMAN002	Mangwaneni Final	HPC 37*	12	±21%	CFU/mL
05-Nov-25	2509511	TMAN002	Mangwaneni Final	Odour*	Mild Chlorinous	-	-
05-Nov-25	2509507	TMAN002	Mangwaneni Final	pH OS*	7.40	-	-
05-Nov-25	2509507	TMAN002	Mangwaneni Final	Temperature OS*	18.8	-	°C
05-Nov-25	2509511	TMAN002	Mangwaneni Final	Turbidity	5.7	±6.1%	NTU
05-Nov-25	2509512	TMAN003	Mangwaneni Reticulation	Cl2 (F) OS*	0.35	-	mg Cl2/L
05-Nov-25	2509512	TMAN003	Mangwaneni Reticulation	Cl2 (T) OS*	0.47	-	mg Cl2/L
05-Nov-25	2509513	TMAN003	Mangwaneni Reticulation	Coliforms*	0	±15%	MPN/100mL
05-Nov-25	2509512	TMAN003	Mangwaneni Reticulation	Coll Time OS*	10:48	-	-
05-Nov-25	2509516	TMAN003	Mangwaneni Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
05-Nov-25	2509515	TMAN003	Mangwaneni Reticulation	Conductivity	10.7	±1.5%	mS/m
05-Nov-25	2509513	TMAN003	Mangwaneni Reticulation	E.coli*	0	±14%	MPN/100mL
05-Nov-25	2509513	TMAN003	Mangwaneni Reticulation	HPC 37*	0	±21%	CFU/mL
05-Nov-25	2509512	TMAN003	Mangwaneni Reticulation	pH OS*	7.10	-	-
05-Nov-25	2509512	TMAN003	Mangwaneni Reticulation	Temperature OS*	18.9	-	°C
05-Nov-25	2509516	TMAN003	Mangwaneni Reticulation	Turbidity	0.4	±6.1%	NTU
05-Nov-25	2509521	TMQA002	Mqatsheni Final	Cl2 (F) OS*	0.32	-	mg Cl2/L
05-Nov-25	2509521	TMQA002	Mqatsheni Final	Cl2 (T) OS*	0.45	-	mg Cl2/L
05-Nov-25	2509522	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
05-Nov-25	2509521	TMQA002	Mqatsheni Final	Coll Time OS*	08:44	-	-
05-Nov-25	2509525	TMQA002	Mqatsheni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
05-Nov-25	2509524	TMQA002	Mqatsheni Final	Conductivity	25.1	±1.5%	mS/m
05-Nov-25	2509522	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
05-Nov-25	2509522	TMQA002	Mqatsheni Final	HPC 37*	0	±21%	CFU/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

05-Nov-25	2509525	TMQA002	Mqatsheni Final	Odour*	Nil	-	-
05-Nov-25	2509521	TMQA002	Mqatsheni Final	pH OS*	8.90	-	-
05-Nov-25	2509521	TMQA002	Mqatsheni Final	Temperature OS*	18.6	-	°C
05-Nov-25	2509525	TMQA002	Mqatsheni Final	Turbidity	2.0	±6.1%	NTU
05-Nov-25	2509540	TRV002	Riverside Final	Cl2 (F) OS*	1.48	-	mg Cl2/L
05-Nov-25	2509540	TRV002	Riverside Final	Cl2 (T) OS*	1.56	-	mg Cl2/L
05-Nov-25	2509541	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
05-Nov-25	2509540	TRV002	Riverside Final	Coll Time OS*	08:30	-	-
05-Nov-25	2509544	TRV002	Riverside Final	Colour	<1.00	±6.5%	mg Pt-Co/L
05-Nov-25	2509543	TRV002	Riverside Final	Conductivity	9.53	±1.5%	mS/m
05-Nov-25	2509541	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
05-Nov-25	2509545	TRV002	Riverside Final	Fe (AE)	0.26	±5.4%	mg Fe/L
05-Nov-25	2509541	TRV002	Riverside Final	HPC 37*	0	±21%	CFU/mL
05-Nov-25	2509544	TRV002	Riverside Final	Odour*	Nil	-	-
05-Nov-25	2509540	TRV002	Riverside Final	pH OS*	7.30	-	-
05-Nov-25	2509540	TRV002	Riverside Final	Temperature OS*	19.7	-	°C
05-Nov-25	2509544	TRV002	Riverside Final	Turbidity	4.5	±6.1%	NTU
05-Nov-25	2509546	TRV003	Riverside Reticulation	Cl2 (F) OS*	0.74	-	mg Cl2/L
05-Nov-25	2509546	TRV003	Riverside Reticulation	Cl2 (T) OS*	0.84	-	mg Cl2/L
05-Nov-25	2509547	TRV003	Riverside Reticulation	Coliforms*	0	±15%	MPN/100mL
05-Nov-25	2509546	TRV003	Riverside Reticulation	Coll Time OS*	08:40	-	-
05-Nov-25	2509549	TRV003	Riverside Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
05-Nov-25	2509547	TRV003	Riverside Reticulation	E.coli*	0	±14%	MPN/100mL
05-Nov-25	2509547	TRV003	Riverside Reticulation	HPC 37*	5	±21%	CFU/mL
05-Nov-25	2509549	TRV003	Riverside Reticulation	Odour*	Nil	-	-
05-Nov-25	2509546	TRV003	Riverside Reticulation	pH OS*	7.40	-	-
05-Nov-25	2509546	TRV003	Riverside Reticulation	Temperature OS*	20.0	-	°C
05-Nov-25	2509549	TRV003	Riverside Reticulation	Turbidity	5.2	±6.1%	NTU
05-Nov-25	2509570	TUN002	Underberg Final	Al (AE)	46.8	±7.6%	µg Al/L
05-Nov-25	2509565	TUN002	Underberg Final	Cl2 (F) OS*	1.08	-	mg Cl2/L
05-Nov-25	2509565	TUN002	Underberg Final	Cl2 (T) OS*	1.26	-	mg Cl2/L
05-Nov-25	2509566	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
05-Nov-25	2509565	TUN002	Underberg Final	Coll Time OS*	09:29	-	-
05-Nov-25	2509569	TUN002	Underberg Final	Colour	1.90	±6.5%	mg Pt-Co/L
05-Nov-25	2509568	TUN002	Underberg Final	Conductivity	5.39	±1.5%	mS/m
05-Nov-25	2509566	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
05-Nov-25	2509566	TUN002	Underberg Final	HPC 37*	0	±21%	CFU/mL
05-Nov-25	2509569	TUN002	Underberg Final	Odour*	Nil	-	-
05-Nov-25	2509565	TUN002	Underberg Final	pH OS*	7.10	-	-
05-Nov-25	2509569	TUN002	Underberg Final	Taste*	Mild Chlorinous	-	-
05-Nov-25	2509565	TUN002	Underberg Final	Temperature OS*	20.4	-	°C
05-Nov-25	2509569	TUN002	Underberg Final	Turbidity	0.7	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

06-Nov-25	2510215	TMZ002	Umzimkhulu Final	Al (AE)	308	±7.6%	µg Al/L
06-Nov-25	2510210	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	1.62	-	mg Cl ₂ /L
06-Nov-25	2510210	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	1.70	-	mg Cl ₂ /L
06-Nov-25	2510211	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
06-Nov-25	2510211	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10mL
06-Nov-25	2510210	TMZ002	Umzimkhulu Final	Coll Time OS*	06:00	-	-
06-Nov-25	2510213	TMZ002	Umzimkhulu Final	Conductivity	11.6	±1.5%	mS/m
06-Nov-25	2510211	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
06-Nov-25	2510211	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	CFU/mL
06-Nov-25	2510210	TMZ002	Umzimkhulu Final	pH OS*	7.40	-	-
06-Nov-25	2510210	TMZ002	Umzimkhulu Final	Temperature OS*	20.4	-	°C
06-Nov-25	2510214	TMZ002	Umzimkhulu Final	Turbidity	2.4	±6.1%	NTU
06-Nov-25	2510216	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (F) OS*	1.50	-	mg Cl ₂ /L
06-Nov-25	2510216	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (T) OS*	1.64	-	mg Cl ₂ /L
06-Nov-25	2510217	TMZ004	Umzikhulu Informal Settlement Retic	Coliforms*	0	±15%	MPN/100mL
06-Nov-25	2510216	TMZ004	Umzikhulu Informal Settlement Retic	Coll Time OS*	06:55	-	-
06-Nov-25	2510217	TMZ004	Umzikhulu Informal Settlement Retic	E.coli*	0	±14%	MPN/100mL
06-Nov-25	2510217	TMZ004	Umzikhulu Informal Settlement Retic	HPC 37*	0	±21%	CFU/mL
06-Nov-25	2510216	TMZ004	Umzikhulu Informal Settlement Retic	pH OS*	7.20	-	-
06-Nov-25	2510216	TMZ004	Umzikhulu Informal Settlement Retic	Temperature OS*	20.5	-	°C
06-Nov-25	2510219	TMZ004	Umzikhulu Informal Settlement Retic	Turbidity	2.1	±6.1%	NTU
06-Nov-25	2510220	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (F) OS*	1.60	-	mg Cl ₂ /L
06-Nov-25	2510220	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (T) OS*	1.74	-	mg Cl ₂ /L
06-Nov-25	2510221	TMZ005	Umzimkhulu Local Municipality Offices	Coliforms*	0	±15%	MPN/100mL
06-Nov-25	2510220	TMZ005	Umzimkhulu Local Municipality Offices	Coll Time OS*	06:43	-	-
06-Nov-25	2510221	TMZ005	Umzimkhulu Local Municipality Offices	E.coli*	0	±14%	MPN/100mL
06-Nov-25	2510221	TMZ005	Umzimkhulu Local Municipality Offices	HPC 37*	0	±21%	CFU/mL
06-Nov-25	2510220	TMZ005	Umzimkhulu Local Municipality Offices	pH OS*	7.20	-	-
06-Nov-25	2510220	TMZ005	Umzimkhulu Local Municipality Offices	Temperature OS*	20.1	-	°C
06-Nov-25	2510223	TMZ005	Umzimkhulu Local Municipality Offices	Turbidity	3.1	±6.1%	NTU
06-Nov-25	2510224	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (F) OS*	0.41	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

06-Nov-25	2510224	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (T) OS*	0.52	-	mg Cl ₂ /L
06-Nov-25	2510225	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
06-Nov-25	2510224	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coll Time OS*	06:30	-	-
06-Nov-25	2510228	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Colour	1.20	±6.5%	mg Pt-Co/L
06-Nov-25	2510227	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Conductivity	10.9	±1.5%	mS/m
06-Nov-25	2510225	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
06-Nov-25	2510225	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	HPC 37*	0	±21%	CFU/mL
06-Nov-25	2510224	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	pH OS*	7.10	-	-
06-Nov-25	2510224	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Temperature OS*	20.0	-	°C
06-Nov-25	2510228	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Turbidity	1.1	±6.1%	NTU
06-Nov-25	2510239	TNO002	Nokweja Final	Al (AE)	699	±7.6%	µg Al/L
06-Nov-25	2510234	TNO002	Nokweja Final	Cl ₂ (F) OS*	1.55	-	mg Cl ₂ /L
06-Nov-25	2510234	TNO002	Nokweja Final	Cl ₂ (T) OS*	1.68	-	mg Cl ₂ /L
06-Nov-25	2510235	TNO002	Nokweja Final	Coliforms*	2	±15%	MPN/100mL
06-Nov-25	2510235	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10mL
06-Nov-25	2510234	TNO002	Nokweja Final	Coll Time OS*	07:40	-	-
06-Nov-25	2510238	TNO002	Nokweja Final	Colour	<1.00	±6.5%	mg Pt-Co/L
06-Nov-25	2510237	TNO002	Nokweja Final	Conductivity	11.4	±1.5%	mS/m
06-Nov-25	2510235	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
06-Nov-25	2510235	TNO002	Nokweja Final	HPC 37*	13	±21%	CFU/mL
06-Nov-25	2510238	TNO002	Nokweja Final	Odour*	Nil	-	-
06-Nov-25	2510234	TNO002	Nokweja Final	pH OS*	7.40	-	-
06-Nov-25	2510234	TNO002	Nokweja Final	Temperature OS*	20.4	-	°C
06-Nov-25	2510238	TNO002	Nokweja Final	Turbidity	4.9	±6.1%	NTU
06-Nov-25	2510240	TNO003	Nokweja Standpipe A Reticulation	Cl ₂ (F) OS*	0.52	-	mg Cl ₂ /L
06-Nov-25	2510240	TNO003	Nokweja Standpipe A Reticulation	Cl ₂ (T) OS*	0.61	-	mg Cl ₂ /L
06-Nov-25	2510241	TNO003	Nokweja Standpipe A Reticulation	Coliforms*	>201	±15%	MPN/100mL
06-Nov-25	2510240	TNO003	Nokweja Standpipe A Reticulation	Coll Time OS*	07:07	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

06-Nov-25	2510241	TNO003	Nokweja Standpipe A Reticulation	E.coli*	4	±14%	MPN/100mL
06-Nov-25	2510241	TNO003	Nokweja Standpipe A Reticulation	HPC 37*	522	±21%	CFU/mL
06-Nov-25	2510240	TNO003	Nokweja Standpipe A Reticulation	pH OS*	7.30	-	-
06-Nov-25	2510240	TNO003	Nokweja Standpipe A Reticulation	Temperature OS*	19.4	-	°C
06-Nov-25	2510243	TNO003	Nokweja Standpipe A Reticulation	Turbidity	33.8	±6.1%	NTU
06-Nov-25	2510244	TNO004	Nokweja Standpipe B Reticulation	Cl ₂ (F) OS*	0.84	-	mg Cl ₂ /L
06-Nov-25	2510244	TNO004	Nokweja Standpipe B Reticulation	Cl ₂ (T) OS*	0.94	-	mg Cl ₂ /L
06-Nov-25	2510245	TNO004	Nokweja Standpipe B Reticulation	Coliforms*	>201	±15%	MPN/100mL
06-Nov-25	2510244	TNO004	Nokweja Standpipe B Reticulation	Coll Time OS*	07:17	-	-
06-Nov-25	2510245	TNO004	Nokweja Standpipe B Reticulation	E.coli*	4	±14%	MPN/100mL
06-Nov-25	2510245	TNO004	Nokweja Standpipe B Reticulation	HPC 37*	444	±21%	CFU/mL
06-Nov-25	2510244	TNO004	Nokweja Standpipe B Reticulation	pH OS*	7.50	-	-
06-Nov-25	2510244	TNO004	Nokweja Standpipe B Reticulation	Temperature OS*	20.8	-	°C
06-Nov-25	2510247	TNO004	Nokweja Standpipe B Reticulation	Turbidity	15.7	±6.1%	NTU
06-Nov-25	2510282	TWA002	Washbank Final	Al (AE)	846	±7.6%	µg Al/L
06-Nov-25	2510277	TWA002	Washbank Final	Cl ₂ (F) OS*	1.10	-	mg Cl ₂ /L
06-Nov-25	2510277	TWA002	Washbank Final	Cl ₂ (T) OS*	1.23	-	mg Cl ₂ /L
06-Nov-25	2510278	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
06-Nov-25	2510277	TWA002	Washbank Final	Coll Time OS*	05:35	-	-
06-Nov-25	2510281	TWA002	Washbank Final	Colour	1.80	±6.5%	mg Pt-Co/L
06-Nov-25	2510280	TWA002	Washbank Final	Conductivity	13.8	±1.5%	mS/m
06-Nov-25	2510278	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
06-Nov-25	2510278	TWA002	Washbank Final	HPC 37*	9	±21%	CFU/mL
06-Nov-25	2510281	TWA002	Washbank Final	Odour*	Nil	-	-
06-Nov-25	2510277	TWA002	Washbank Final	pH OS*	7.30	-	-
06-Nov-25	2510277	TWA002	Washbank Final	Temperature OS*	18.4	-	°C
06-Nov-25	2510281	TWA002	Washbank Final	Turbidity	12.0	±6.1%	NTU
07-Nov-25	2510460	TIB002	Ibisi Final	Al (AE)	794	±7.6%	µg Al/L
07-Nov-25	2510455	TIB002	Ibisi Final	Cl ₂ (F) OS*	1.49	-	mg Cl ₂ /L
07-Nov-25	2510455	TIB002	Ibisi Final	Cl ₂ (T) OS*	1.57	-	mg Cl ₂ /L
07-Nov-25	2510456	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
07-Nov-25	2510456	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10mL
07-Nov-25	2510455	TIB002	Ibisi Final	Coll Time OS*	07:00	-	-
07-Nov-25	2510459	TIB002	Ibisi Final	Colour	<1.00	±6.5%	mg Pt-Co/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

07-Nov-25	2510458	TIB002	Ibisi Final	Conductivity	13.6	±1.5%	mS/m
07-Nov-25	2510456	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
07-Nov-25	2510460	TIB002	Ibisi Final	Fe (AE)	0.30	±5.4%	mg Fe/L
07-Nov-25	2510456	TIB002	Ibisi Final	HPC 37*	10	±21%	CFU/mL
07-Nov-25	2510459	TIB002	Ibisi Final	Odour*	Mild Chlorinous	-	-
07-Nov-25	2510455	TIB002	Ibisi Final	pH OS*	7.20	-	-
07-Nov-25	2510455	TIB002	Ibisi Final	Temperature OS*	19.9	-	°C
07-Nov-25	2510459	TIB002	Ibisi Final	Turbidity	7.4	±6.1%	NTU
07-Nov-25	2510461	TIB003	Ibisi Police Station Reticulation	Cl ₂ (F) OS*	0.12	-	mg Cl ₂ /L
07-Nov-25	2510461	TIB003	Ibisi Police Station Reticulation	Cl ₂ (T) OS*	0.20	-	mg Cl ₂ /L
07-Nov-25	2510462	TIB003	Ibisi Police Station Reticulation	Coliforms*	0	±15%	MPN/100mL
07-Nov-25	2510461	TIB003	Ibisi Police Station Reticulation	Coll Time OS*	07:20	-	-
07-Nov-25	2510462	TIB003	Ibisi Police Station Reticulation	E.coli*	0	±14%	MPN/100mL
07-Nov-25	2510462	TIB003	Ibisi Police Station Reticulation	HPC 37*	3	±21%	CFU/mL
07-Nov-25	2510461	TIB003	Ibisi Police Station Reticulation	pH OS*	7.40	-	-
07-Nov-25	2510461	TIB003	Ibisi Police Station Reticulation	Temperature OS*	19.8	-	°C
07-Nov-25	2510464	TIB003	Ibisi Police Station Reticulation	Turbidity	1.9	±6.1%	NTU
07-Nov-25	2510469	TRT002	Rietvlei Final	Cl ₂ (F) OS*	0.86	-	mg Cl ₂ /L
07-Nov-25	2510469	TRT002	Rietvlei Final	Cl ₂ (T) OS*	0.95	-	mg Cl ₂ /L
07-Nov-25	2510470	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
07-Nov-25	2510469	TRT002	Rietvlei Final	Coll Time OS*	06:05	-	-
07-Nov-25	2510472	TRT002	Rietvlei Final	Conductivity	18.9	±1.5%	mS/m
07-Nov-25	2510470	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
07-Nov-25	2510470	TRT002	Rietvlei Final	HPC 37*	4	±21%	CFU/mL
07-Nov-25	2510469	TRT002	Rietvlei Final	pH OS*	7.40	-	-
07-Nov-25	2510469	TRT002	Rietvlei Final	Temperature OS*	19.1	-	°C
07-Nov-25	2510473	TRT002	Rietvlei Final	Turbidity	1.8	±6.1%	NTU
07-Nov-25	2510474	TRT004	Rietvlei Hospital Reticulation	Cl ₂ (F) OS*	0.49	-	mg Cl ₂ /L
07-Nov-25	2510474	TRT004	Rietvlei Hospital Reticulation	Cl ₂ (T) OS*	0.58	-	mg Cl ₂ /L
07-Nov-25	2510475	TRT004	Rietvlei Hospital Reticulation	Coliforms*	9	±15%	MPN/100mL
07-Nov-25	2510474	TRT004	Rietvlei Hospital Reticulation	Coll Time OS*	06:26	-	-
07-Nov-25	2510475	TRT004	Rietvlei Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
07-Nov-25	2510475	TRT004	Rietvlei Hospital Reticulation	HPC 37*	0	±21%	CFU/mL
07-Nov-25	2510474	TRT004	Rietvlei Hospital Reticulation	pH OS*	7.20	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

07-Nov-25	2510474	TRT004	Rietvlei Hospital Reticulation	Temperature OS*	18.9	-	°C
07-Nov-25	2510477	TRT004	Rietvlei Hospital Reticulation	Turbidity	4.7	±6.1%	NTU
10-Nov-25	2512189	TFR002	Franklin Final	AI (AE)	133	±7.6%	µg AI/L
10-Nov-25	2512184	TFR002	Franklin Final	Cl ₂ (F) OS*	0.46	-	mg Cl ₂ /L
10-Nov-25	2512184	TFR002	Franklin Final	Cl ₂ (T) OS*	0.58	-	mg Cl ₂ /L
10-Nov-25	2512185	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
10-Nov-25	2512185	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10mL
10-Nov-25	2512184	TFR002	Franklin Final	Coll Time OS*	07:38	-	-
10-Nov-25	2512187	TFR002	Franklin Final	Conductivity	11.9	±1.5%	mS/m
10-Nov-25	2512185	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
10-Nov-25	2512185	TFR002	Franklin Final	HPC 37*	0	±21%	CFU/mL
10-Nov-25	2512184	TFR002	Franklin Final	pH OS*	7.30	-	-
10-Nov-25	2512184	TFR002	Franklin Final	Temperature OS*	19.8	-	°C
10-Nov-25	2512188	TFR002	Franklin Final	Turbidity	1.1	±6.1%	NTU
10-Nov-25	2512200	TKK002	Kokstad Final	AI (AE)	<25.0	±7.6%	µg AI/L
10-Nov-25	2512195	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.89	-	mg Cl ₂ /L
10-Nov-25	2512195	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.98	-	mg Cl ₂ /L
10-Nov-25	2512196	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
10-Nov-25	2512196	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10mL
10-Nov-25	2512195	TKK002	Kokstad Final	Coll Time OS*	08:20	-	-
10-Nov-25	2512198	TKK002	Kokstad Final	Conductivity	14.8	±1.5%	mS/m
10-Nov-25	2512196	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
10-Nov-25	2512196	TKK002	Kokstad Final	HPC 37*	0	±21%	CFU/mL
10-Nov-25	2512195	TKK002	Kokstad Final	pH OS*	7.40	-	-
10-Nov-25	2512195	TKK002	Kokstad Final	Temperature OS*	20.1	-	°C
10-Nov-25	2512199	TKK002	Kokstad Final	Turbidity	0.6	±6.1%	NTU
10-Nov-25	2512206	TKK011	Kokstad Hospital Reticulation	Cl ₂ (F) OS*	1.12	-	mg Cl ₂ /L
10-Nov-25	2512206	TKK011	Kokstad Hospital Reticulation	Cl ₂ (T) OS*	1.22	-	mg Cl ₂ /L
10-Nov-25	2512207	TKK011	Kokstad Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
10-Nov-25	2512206	TKK011	Kokstad Hospital Reticulation	Coll Time OS*	08:34	-	-
10-Nov-25	2512207	TKK011	Kokstad Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
10-Nov-25	2512207	TKK011	Kokstad Hospital Reticulation	HPC 37*	0	±21%	CFU/mL
10-Nov-25	2512206	TKK011	Kokstad Hospital Reticulation	pH OS*	7.30	-	-
10-Nov-25	2512206	TKK011	Kokstad Hospital Reticulation	Temperature OS*	19.5	-	°C
10-Nov-25	2512209	TKK011	Kokstad Hospital Reticulation	Turbidity	<0.2	±6.1%	NTU
10-Nov-25	2512235	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	0.82	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

10-Nov-25	2512235	TNJU002	KwaNjunga Final	Cl2 (T) OS*	0.91	-	mg Cl2/L
10-Nov-25	2512236	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
10-Nov-25	2512235	TNJU002	KwaNjunga Final	Coll Time OS*	07:00	-	-
10-Nov-25	2512238	TNJU002	KwaNjunga Final	Conductivity	19.3	±1.5%	mS/m
10-Nov-25	2512236	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
10-Nov-25	2512236	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	CFU/mL
10-Nov-25	2512235	TNJU002	KwaNjunga Final	pH OS*	7.20	-	-
10-Nov-25	2512235	TNJU002	KwaNjunga Final	Temperature OS*	18.9	-	°C
10-Nov-25	2512239	TNJU002	KwaNjunga Final	Turbidity	0.6	±6.1%	NTU
11-Nov-25	2512791	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (F) OS*	0.30	-	mg Cl2/L
11-Nov-25	2512791	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (T) OS*	0.40	-	mg Cl2/L
11-Nov-25	2512792	TJO001	Jolivet RRT frn Vulamehlo	Coliforms*	0	±15%	MPN/100mL
11-Nov-25	2512791	TJO001	Jolivet RRT frn Vulamehlo	Coll Time OS*	09:04	-	-
11-Nov-25	2512792	TJO001	Jolivet RRT frn Vulamehlo	E.coli*	0	±14%	MPN/100mL
11-Nov-25	2512792	TJO001	Jolivet RRT frn Vulamehlo	HPC 37*	0	±21%	CFU/mL
11-Nov-25	2512791	TJO001	Jolivet RRT frn Vulamehlo	pH OS*	7.60	-	-
11-Nov-25	2512791	TJO001	Jolivet RRT frn Vulamehlo	Temperature OS*	21.5	-	°C
11-Nov-25	2512794	TJO001	Jolivet RRT frn Vulamehlo	Turbidity	1.3	±6.1%	NTU
11-Nov-25	2512844	TQU002	Mnqumeni Final	Cl2 (F) OS*	0.51	-	mg Cl2/L
11-Nov-25	2512844	TQU002	Mnqumeni Final	Cl2 (T) OS*	0.64	-	mg Cl2/L
11-Nov-25	2512845	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
11-Nov-25	2512844	TQU002	Mnqumeni Final	Coll Time OS*	7:30	-	-
11-Nov-25	2512847	TQU002	Mnqumeni Final	Conductivity	14.9	±1.5%	mS/m
11-Nov-25	2512845	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
11-Nov-25	2512845	TQU002	Mnqumeni Final	HPC 37*	0	±21%	CFU/mL
11-Nov-25	2512844	TQU002	Mnqumeni Final	pH OS*	7.40	-	-
11-Nov-25	2512844	TQU002	Mnqumeni Final	Temperature OS*	20.4	-	°C
11-Nov-25	2512848	TQU002	Mnqumeni Final	Turbidity	0.3	±6.1%	NTU
11-Nov-25	2512859	TSQ002	Esiqanduleni Final	Al (AE)	585	±7.6%	µg Al/L
11-Nov-25	2512854	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	1.20	-	mg Cl2/L
11-Nov-25	2512854	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	1.35	-	mg Cl2/L
11-Nov-25	2512855	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
11-Nov-25	2512854	TSQ002	Esiqanduleni Final	Coll Time OS*	8:12	-	-
11-Nov-25	2512857	TSQ002	Esiqanduleni Final	Conductivity	13.7	±1.5%	mS/m
11-Nov-25	2512855	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
11-Nov-25	2512855	TSQ002	Esiqanduleni Final	HPC 37*	1	±21%	CFU/mL
11-Nov-25	2512854	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
11-Nov-25	2512854	TSQ002	Esiqanduleni Final	Temperature OS*	21.5	-	°C
11-Nov-25	2512858	TSQ002	Esiqanduleni Final	Turbidity	7.6	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

12-Nov-25	2513497	TBU002	Bulwer Final	Cl2 (F) OS*	1.09	-	mg Cl2/L
12-Nov-25	2513497	TBU002	Bulwer Final	Cl2 (T) OS*	1.20	-	mg Cl2/L
12-Nov-25	2513498	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
12-Nov-25	2513497	TBU002	Bulwer Final	Coll Time OS*	09:35	-	-
12-Nov-25	2513500	TBU002	Bulwer Final	Conductivity	5.89	±1.5%	mS/m
12-Nov-25	2513498	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
12-Nov-25	2513498	TBU002	Bulwer Final	HPC 37*	2	±21%	CFU/mL
12-Nov-25	2513497	TBU002	Bulwer Final	pH OS*	7.40	-	-
12-Nov-25	2513497	TBU002	Bulwer Final	Temperature OS*	23.4	-	°C
12-Nov-25	2513501	TBU002	Bulwer Final	Turbidity	2.9	±6.1%	NTU
12-Nov-25	2513512	TCR002	Creighton Final	Al (AE)	180	±7.6%	µg Al/L
12-Nov-25	2513507	TCR002	Creighton Final	Cl2 (F) OS*	0.84	-	mg Cl2/L
12-Nov-25	2513507	TCR002	Creighton Final	Cl2 (T) OS*	0.94	-	mg Cl2/L
12-Nov-25	2513508	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
12-Nov-25	2513507	TCR002	Creighton Final	Coll Time OS*	07:09	-	-
12-Nov-25	2513510	TCR002	Creighton Final	Conductivity	11.7	±1.5%	mS/m
12-Nov-25	2513508	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
12-Nov-25	2513508	TCR002	Creighton Final	HPC 37*	0	±21%	CFU/mL
12-Nov-25	2513507	TCR002	Creighton Final	pH OS*	7.30	-	-
12-Nov-25	2513507	TCR002	Creighton Final	Temperature OS*	19.6	-	°C
12-Nov-25	2513511	TCR002	Creighton Final	Turbidity	0.4	±6.1%	NTU
12-Nov-25	2513532	TMAN002	Mangwaneni Final	Cl2 (F) OS*	0.60	-	mg Cl2/L
12-Nov-25	2513532	TMAN002	Mangwaneni Final	Cl2 (T) OS*	0.71	-	mg Cl2/L
12-Nov-25	2513533	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
12-Nov-25	2513532	TMAN002	Mangwaneni Final	Coll Time OS*	11:00	-	-
12-Nov-25	2513535	TMAN002	Mangwaneni Final	Conductivity	10.2	±1.5%	mS/m
12-Nov-25	2513533	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
12-Nov-25	2513533	TMAN002	Mangwaneni Final	HPC 37*	4	±21%	CFU/mL
12-Nov-25	2513532	TMAN002	Mangwaneni Final	pH OS*	7.50	-	-
12-Nov-25	2513532	TMAN002	Mangwaneni Final	Temperature OS*	22.6	-	°C
12-Nov-25	2513536	TMAN002	Mangwaneni Final	Turbidity	0.9	±6.1%	NTU
12-Nov-25	2513541	TMQA002	Mqatsheni Final	Cl2 (F) OS*	0.39	-	mg Cl2/L
12-Nov-25	2513541	TMQA002	Mqatsheni Final	Cl2 (T) OS*	0.50	-	mg Cl2/L
12-Nov-25	2513542	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
12-Nov-25	2513541	TMQA002	Mqatsheni Final	Coll Time OS*	08:00	-	-
12-Nov-25	2513544	TMQA002	Mqatsheni Final	Conductivity	24.2	±1.5%	mS/m
12-Nov-25	2513542	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
12-Nov-25	2513542	TMQA002	Mqatsheni Final	HPC 37*	2	±21%	CFU/mL
12-Nov-25	2513541	TMQA002	Mqatsheni Final	pH OS*	8.80	-	-
12-Nov-25	2513541	TMQA002	Mqatsheni Final	Temperature OS*	21.3	-	°C
12-Nov-25	2513545	TMQA002	Mqatsheni Final	Turbidity	0.6	±6.1%	NTU
12-Nov-25	2513561	TST002	St Appollinaris Final	Cl2 (F) OS*	0.99	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

12-Nov-25	2513561	TST002	St Appollinaris Final	Cl ₂ (T) OS*	1.13	-	mg Cl ₂ /L
12-Nov-25	2513562	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
12-Nov-25	2513561	TST002	St Appollinaris Final	Coll Time OS*	08:53	-	-
12-Nov-25	2513564	TST002	St Appollinaris Final	Conductivity	6.32	±1.5%	mS/m
12-Nov-25	2513562	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
12-Nov-25	2513562	TST002	St Appollinaris Final	HPC 37*	5	±21%	CFU/mL
12-Nov-25	2513561	TST002	St Appollinaris Final	pH OS*	7.50	-	-
12-Nov-25	2513561	TST002	St Appollinaris Final	Temperature OS*	22.6	-	°C
12-Nov-25	2513565	TST002	St Appollinaris Final	Turbidity	6.8	±6.1%	NTU
12-Nov-25	2513566	TST003	St Appollinaris Hospital Reticulation	Cl ₂ (F) OS*	0.63	-	mg Cl ₂ /L
12-Nov-25	2513566	TST003	St Appollinaris Hospital Reticulation	Cl ₂ (T) OS*	0.70	-	mg Cl ₂ /L
12-Nov-25	2513567	TST003	St Appollinaris Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
12-Nov-25	2513566	TST003	St Appollinaris Hospital Reticulation	Coll Time OS*	08:27	-	-
12-Nov-25	2513570	TST003	St Appollinaris Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
12-Nov-25	2513569	TST003	St Appollinaris Hospital Reticulation	Conductivity	7.81	±1.5%	mS/m
12-Nov-25	2513567	TST003	St Appollinaris Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
12-Nov-25	2513567	TST003	St Appollinaris Hospital Reticulation	HPC 37*	0	±21%	CFU/mL
12-Nov-25	2513570	TST003	St Appollinaris Hospital Reticulation	Odour*	Mild Chlorinous	-	-
12-Nov-25	2513566	TST003	St Appollinaris Hospital Reticulation	pH OS*	7.30	-	-
12-Nov-25	2513566	TST003	St Appollinaris Hospital Reticulation	Temperature OS*	21.2	-	°C
12-Nov-25	2513570	TST003	St Appollinaris Hospital Reticulation	Turbidity	2.0	±6.1%	NTU
12-Nov-25	2513581	TUN002	Underberg Final	Al (AE)	221	±7.6%	µg Al/L
12-Nov-25	2513576	TUN002	Underberg Final	Cl ₂ (F) OS*	0.60	-	mg Cl ₂ /L
12-Nov-25	2513576	TUN002	Underberg Final	Cl ₂ (T) OS*	0.75	-	mg Cl ₂ /L
12-Nov-25	2513577	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
12-Nov-25	2513576	TUN002	Underberg Final	Coll Time OS*	09:44	-	-
12-Nov-25	2513579	TUN002	Underberg Final	Conductivity	4.17	±1.5%	mS/m
12-Nov-25	2513577	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
12-Nov-25	2513577	TUN002	Underberg Final	HPC 37*	0	±21%	CFU/mL
12-Nov-25	2513576	TUN002	Underberg Final	pH OS*	7.40	-	-
12-Nov-25	2513576	TUN002	Underberg Final	Temperature OS*	22.5	-	°C
12-Nov-25	2513580	TUN002	Underberg Final	Turbidity	3.3	±6.1%	NTU
13-Nov-25	2514124	TMZ002	Umzimkhulu Final	Al (AE)	594	±7.6%	µg Al/L
13-Nov-25	2514119	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	0.52	-	mg Cl ₂ /L
13-Nov-25	2514119	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	0.63	-	mg Cl ₂ /L
13-Nov-25	2514120	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

13-Nov-25	2514120	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10mL
13-Nov-25	2514119	TMZ002	Umzimkhulu Final	Coll Time OS*	7:06	-	-
13-Nov-25	2514123	TMZ002	Umzimkhulu Final	Colour	<1.00	±6.5%	mg Pt-Co/L
13-Nov-25	2514122	TMZ002	Umzimkhulu Final	Conductivity	10.4	±1.5%	mS/m
13-Nov-25	2514120	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
13-Nov-25	2514120	TMZ002	Umzimkhulu Final	HPC 37*	2	±21%	CFU/mL
13-Nov-25	2514123	TMZ002	Umzimkhulu Final	Odour*	Mild Chlorinous	-	-
13-Nov-25	2514119	TMZ002	Umzimkhulu Final	pH OS*	7.60	-	-
13-Nov-25	2514119	TMZ002	Umzimkhulu Final	Temperature OS*	21.7	-	°C
13-Nov-25	2514123	TMZ002	Umzimkhulu Final	Turbidity	8.2	±6.1%	NTU
13-Nov-25	2514170	TWA002	Washbank Final	Al (AE)	438	±7.6%	µg Al/L
13-Nov-25	2514165	TWA002	Washbank Final	Cl2 (F) OS*	0.82	-	mg Cl2/L
13-Nov-25	2514165	TWA002	Washbank Final	Cl2 (T) OS*	0.90	-	mg Cl2/L
13-Nov-25	2514166	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
13-Nov-25	2514165	TWA002	Washbank Final	Coll Time OS*	6:40	-	-
13-Nov-25	2514168	TWA002	Washbank Final	Conductivity	15.9	±1.5%	mS/m
13-Nov-25	2514166	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
13-Nov-25	2514166	TWA002	Washbank Final	HPC 37*	2	±21%	CFU/mL
13-Nov-25	2514165	TWA002	Washbank Final	pH OS*	7.50	-	-
13-Nov-25	2514165	TWA002	Washbank Final	Temperature OS*	20.2	-	°C
13-Nov-25	2514169	TWA002	Washbank Final	Turbidity	4.4	±6.1%	NTU
14-Nov-25	2514501	TIB002	Ibisi Final	Al (AE)	276	±7.6%	µg Al/L
14-Nov-25	2514496	TIB002	Ibisi Final	Cl2 (F) OS*	1.17	-	mg Cl2/L
14-Nov-25	2514496	TIB002	Ibisi Final	Cl2 (T) OS*	1.23	-	mg Cl2/L
14-Nov-25	2514497	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
14-Nov-25	2514497	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10mL
14-Nov-25	2514496	TIB002	Ibisi Final	Coll Time OS*	07:39	-	-
14-Nov-25	2514499	TIB002	Ibisi Final	Conductivity	9.64	±1.5%	mS/m
14-Nov-25	2514497	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
14-Nov-25	2514497	TIB002	Ibisi Final	HPC 37*	3	±21%	CFU/mL
14-Nov-25	2514496	TIB002	Ibisi Final	pH OS*	7.40	-	-
14-Nov-25	2514496	TIB002	Ibisi Final	Temperature OS*	20.2	-	°C
14-Nov-25	2514500	TIB002	Ibisi Final	Turbidity	5.2	±6.1%	NTU
14-Nov-25	2514506	TRT002	Rietvlei Final	Cl2 (F) OS*	0.74	-	mg Cl2/L
14-Nov-25	2514506	TRT002	Rietvlei Final	Cl2 (T) OS*	0.86	-	mg Cl2/L
14-Nov-25	2514507	TRT002	Rietvlei Final	Coliforms*	>201	±15%	MPN/100mL
14-Nov-25	2514506	TRT002	Rietvlei Final	Coll Time OS*	06:56	-	-
14-Nov-25	2514509	TRT002	Rietvlei Final	Conductivity	17.5	±1.5%	mS/m
14-Nov-25	2514507	TRT002	Rietvlei Final	E.coli*	66	±14%	MPN/100mL
14-Nov-25	2514507	TRT002	Rietvlei Final	HPC 37*	>1000	±21%	CFU/mL
14-Nov-25	2514506	TRT002	Rietvlei Final	pH OS*	7.30	-	-
14-Nov-25	2514506	TRT002	Rietvlei Final	Temperature OS*	18.8	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

14-Nov-25	2514510	TRT002	Rietvlei Final	Turbidity	2.2	±6.1%	NTU
17-Nov-25	2516759	TFR002	Franklin Final	Al (AE)	213	±7.6%	µg Al/L
17-Nov-25	2516754	TFR002	Franklin Final	Cl ₂ (F) OS*	1.02	-	mg Cl ₂ /L
17-Nov-25	2516754	TFR002	Franklin Final	Cl ₂ (T) OS*	1.13	-	mg Cl ₂ /L
17-Nov-25	2516755	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
17-Nov-25	2516755	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10mL
17-Nov-25	2516754	TFR002	Franklin Final	Coll Time OS*	7:11	-	-
17-Nov-25	2516758	TFR002	Franklin Final	Colour	<1.00	±6.5%	mg Pt-Co/L
17-Nov-25	2516757	TFR002	Franklin Final	Conductivity	12.2	±1.5%	mS/m
17-Nov-25	2516755	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
17-Nov-25	2516759	TFR002	Franklin Final	Fe (AE)	0.10	±5.4%	mg Fe/L
17-Nov-25	2516755	TFR002	Franklin Final	HPC 37*	0	±21%	CFU/mL
17-Nov-25	2516759	TFR002	Franklin Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
17-Nov-25	2516754	TFR002	Franklin Final	pH OS*	7.50	-	-
17-Nov-25	2516754	TFR002	Franklin Final	Temperature OS*	21.0	-	°C
17-Nov-25	2516758	TFR002	Franklin Final	Turbidity	1.9	±6.1%	NTU
17-Nov-25	2516760	TFR003	Franklin Police Station Retic	Cl ₂ (F) OS*	0.97	-	mg Cl ₂ /L
17-Nov-25	2516760	TFR003	Franklin Police Station Retic	Cl ₂ (T) OS*	1.05	-	mg Cl ₂ /L
17-Nov-25	2516761	TFR003	Franklin Police Station Retic	Coliforms*	0	±15%	MPN/100mL
17-Nov-25	2516760	TFR003	Franklin Police Station Retic	Coll Time OS*	7:22	-	-
17-Nov-25	2516764	TFR003	Franklin Police Station Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
17-Nov-25	2516763	TFR003	Franklin Police Station Retic	Conductivity	14.6	±1.5%	mS/m
17-Nov-25	2516761	TFR003	Franklin Police Station Retic	E.coli*	0	±14%	MPN/100mL
17-Nov-25	2516761	TFR003	Franklin Police Station Retic	HPC 37*	0	±21%	CFU/mL
17-Nov-25	2516764	TFR003	Franklin Police Station Retic	Odour*	Mild Chlorinous	-	-
17-Nov-25	2516760	TFR003	Franklin Police Station Retic	pH OS*	7.40	-	-
17-Nov-25	2516760	TFR003	Franklin Police Station Retic	Temperature OS*	20.9	-	°C
17-Nov-25	2516764	TFR003	Franklin Police Station Retic	Turbidity	1.6	±6.1%	NTU
17-Nov-25	2516775	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
17-Nov-25	2516770	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.56	-	mg Cl ₂ /L
17-Nov-25	2516770	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.68	-	mg Cl ₂ /L
17-Nov-25	2516771	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
17-Nov-25	2516771	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10mL
17-Nov-25	2516770	TKK002	Kokstad Final	Coll Time OS*	9:00	-	-
17-Nov-25	2516774	TKK002	Kokstad Final	Colour	<1.00	±6.5%	mg Pt-Co/L
17-Nov-25	2516773	TKK002	Kokstad Final	Conductivity	13.9	±1.5%	mS/m
17-Nov-25	2516771	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

17-Nov-25	2516775	TKK002	Kokstad Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
17-Nov-25	2516771	TKK002	Kokstad Final	HPC 37*	0	±21%	CFU/mL
17-Nov-25	2516774	TKK002	Kokstad Final	Odour*	Mild Chlorinous	-	-
17-Nov-25	2516770	TKK002	Kokstad Final	pH OS*	7.30	-	-
17-Nov-25	2516774	TKK002	Kokstad Final	Taste*	Mild Chlorinous	-	-
17-Nov-25	2516770	TKK002	Kokstad Final	Temperature OS*	20.3	-	°C
17-Nov-25	2516774	TKK002	Kokstad Final	Turbidity	0.2	±6.1%	NTU
17-Nov-25	2516781	TKK005	Kokstad Khanyiselani Rectification	Cl ₂ (F) OS*	0.61	-	mg Cl ₂ /L
17-Nov-25	2516781	TKK005	Kokstad Khanyiselani Rectification	Cl ₂ (T) OS*	0.70	-	mg Cl ₂ /L
17-Nov-25	2516782	TKK005	Kokstad Khanyiselani Rectification	Coliforms*	0	±15%	MPN/100mL
17-Nov-25	2516781	TKK005	Kokstad Khanyiselani Rectification	Coll Time OS*	9:10	-	-
17-Nov-25	2516782	TKK005	Kokstad Khanyiselani Rectification	E.coli*	0	±14%	MPN/100mL
17-Nov-25	2516782	TKK005	Kokstad Khanyiselani Rectification	HPC 37*	0	±21%	CFU/mL
17-Nov-25	2516781	TKK005	Kokstad Khanyiselani Rectification	pH OS*	7.30	-	-
17-Nov-25	2516781	TKK005	Kokstad Khanyiselani Rectification	Temperature OS*	19.5	-	°C
17-Nov-25	2516784	TKK005	Kokstad Khanyiselani Rectification	Turbidity	0.3	±6.1%	NTU
17-Nov-25	2516785	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl ₂ (F) OS*	1.02	-	mg Cl ₂ /L
17-Nov-25	2516785	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl ₂ (T) OS*	1.10	-	mg Cl ₂ /L
17-Nov-25	2516786	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliforms*	0	±15%	MPN/100mL
17-Nov-25	2516785	TKK006	Kokstad Bongweni Correctional Serv Retic	Coll Time OS*	7:58	-	-
17-Nov-25	2516786	TKK006	Kokstad Bongweni Correctional Serv Retic	E.coli*	0	±14%	MPN/100mL
17-Nov-25	2516786	TKK006	Kokstad Bongweni Correctional Serv Retic	HPC 37*	0	±21%	CFU/mL
17-Nov-25	2516785	TKK006	Kokstad Bongweni Correctional Serv Retic	pH OS*	7.30	-	-
17-Nov-25	2516785	TKK006	Kokstad Bongweni Correctional Serv Retic	Temperature OS*	19.0	-	°C
17-Nov-25	2516788	TKK006	Kokstad Bongweni Correctional Serv Retic	Turbidity	0.3	±6.1%	NTU
17-Nov-25	2516789	TKK007	Kokstad Shayamoya Rectification	Cl ₂ (F) OS*	0.77	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

17-Nov-25	2516789	TKK007	Kokstad Shayamoya Reticulation	Cl2 (T) OS*	0.87	-	mg Cl2/L
17-Nov-25	2516790	TKK007	Kokstad Shayamoya Reticulation	Coliforms*	0	±15%	MPN/100mL
17-Nov-25	2516789	TKK007	Kokstad Shayamoya Reticulation	Coll Time OS*	8:11	-	-
17-Nov-25	2516792	TKK007	Kokstad Shayamoya Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
17-Nov-25	2516790	TKK007	Kokstad Shayamoya Reticulation	E.coli*	0	±14%	MPN/100mL
17-Nov-25	2516790	TKK007	Kokstad Shayamoya Reticulation	HPC 37*	0	±21%	CFU/mL
17-Nov-25	2516792	TKK007	Kokstad Shayamoya Reticulation	Odour*	Mild Chlorinous	-	-
17-Nov-25	2516789	TKK007	Kokstad Shayamoya Reticulation	pH OS*	7.50	-	-
17-Nov-25	2516792	TKK007	Kokstad Shayamoya Reticulation	Taste*	Mild Chlorinous	-	-
17-Nov-25	2516789	TKK007	Kokstad Shayamoya Reticulation	Temperature OS*	20.8	-	°C
17-Nov-25	2516792	TKK007	Kokstad Shayamoya Reticulation	Turbidity	0.3	±6.1%	NTU
17-Nov-25	2516793	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (F) OS*	1.11	-	mg Cl2/L
17-Nov-25	2516793	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (T) OS*	1.20	-	mg Cl2/L
17-Nov-25	2516794	TKK009	Kokstad Farm Fresh Produce Market	Coliforms*	1	±15%	MPN/100mL
17-Nov-25	2516793	TKK009	Kokstad Farm Fresh Produce Market	Coll Time OS*	8:55	-	-
17-Nov-25	2516796	TKK009	Kokstad Farm Fresh Produce Market	Colour	1.00	±6.5%	mg Pt-Co/L
17-Nov-25	2516794	TKK009	Kokstad Farm Fresh Produce Market	E.coli*	0	±14%	MPN/100mL
17-Nov-25	2516794	TKK009	Kokstad Farm Fresh Produce Market	HPC 37*	0	±21%	CFU/mL
17-Nov-25	2516796	TKK009	Kokstad Farm Fresh Produce Market	Odour*	Mild Chlorinous	-	-
17-Nov-25	2516793	TKK009	Kokstad Farm Fresh Produce Market	pH OS*	7.40	-	-
17-Nov-25	2516796	TKK009	Kokstad Farm Fresh Produce Market	Taste*	Mild Chlorinous	-	-
17-Nov-25	2516793	TKK009	Kokstad Farm Fresh Produce Market	Temperature OS*	20.7	-	°C
17-Nov-25	2516796	TKK009	Kokstad Farm Fresh Produce Market	Turbidity	0.2	±6.1%	NTU
17-Nov-25	2516797	TKK012	Kokstad FET College Reticulation	Cl2 (F) OS*	0.85	-	mg Cl2/L
17-Nov-25	2516797	TKK012	Kokstad FET College Reticulation	Cl2 (T) OS*	0.94	-	mg Cl2/L
17-Nov-25	2516798	TKK012	Kokstad FET College Reticulation	Coliforms*	0	±15%	MPN/100mL
17-Nov-25	2516797	TKK012	Kokstad FET College Reticulation	Coll Time OS*	8:29	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

17-Nov-25	2516798	TKK012	Kokstad FET College Reticulation	E.coli*	0	±14%	MPN/100mL
17-Nov-25	2516798	TKK012	Kokstad FET College Reticulation	HPC 37*	0	±21%	CFU/mL
17-Nov-25	2516797	TKK012	Kokstad FET College Reticulation	pH OS*	7.30	-	-
17-Nov-25	2516797	TKK012	Kokstad FET College Reticulation	Temperature OS*	19.1	-	°C
17-Nov-25	2516800	TKK012	Kokstad FET College Reticulation	Turbidity	<0.2	±6.1%	NTU
17-Nov-25	2516823	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	1.40	-	mg Cl ₂ /L
17-Nov-25	2516823	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	1.57	-	mg Cl ₂ /L
17-Nov-25	2516824	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
17-Nov-25	2516823	TNJU002	KwaNjunga Final	Coll Time OS*	6:29	-	-
17-Nov-25	2516826	TNJU002	KwaNjunga Final	Conductivity	19.8	±1.5%	mS/m
17-Nov-25	2516824	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
17-Nov-25	2516828	TNJU002	KwaNjunga Final	Fe (AE)	0.09	±5.4%	mg Fe/L
17-Nov-25	2516824	TNJU002	KwaNjunga Final	HPC 37*	4	±21%	CFU/mL
17-Nov-25	2516827	TNJU002	KwaNjunga Final	Odour*	Mild Chlorinous	-	-
17-Nov-25	2516823	TNJU002	KwaNjunga Final	pH OS*	7.30	-	-
17-Nov-25	2516823	TNJU002	KwaNjunga Final	Temperature OS*	19.7	-	°C
17-Nov-25	2516827	TNJU002	KwaNjunga Final	Turbidity	1.3	±6.1%	NTU
18-Nov-25	2517340	TQU002	Mnqumeni Final	Al (AE)	31.4	±7.6%	µg Al/L
18-Nov-25	2517335	TQU002	Mnqumeni Final	Cl ₂ (F) OS*	1.14	-	mg Cl ₂ /L
18-Nov-25	2517335	TQU002	Mnqumeni Final	Cl ₂ (T) OS*	1.20	-	mg Cl ₂ /L
18-Nov-25	2517336	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
18-Nov-25	2517335	TQU002	Mnqumeni Final	Coll Time OS*	05:40	-	-
18-Nov-25	2517338	TQU002	Mnqumeni Final	Conductivity	12.7	±1.5%	mS/m
18-Nov-25	2517336	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
18-Nov-25	2517340	TQU002	Mnqumeni Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
18-Nov-25	2517336	TQU002	Mnqumeni Final	HPC 37*	0	±21%	CFU/mL
18-Nov-25	2517340	TQU002	Mnqumeni Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
18-Nov-25	2517339	TQU002	Mnqumeni Final	Odour*	Mild Chlorinous	-	-
18-Nov-25	2517335	TQU002	Mnqumeni Final	pH OS*	7.20	-	-
18-Nov-25	2517339	TQU002	Mnqumeni Final	Taste*	Mild Chlorinous	-	-
18-Nov-25	2517335	TQU002	Mnqumeni Final	Temperature OS*	18.1	-	°C
18-Nov-25	2517339	TQU002	Mnqumeni Final	Turbidity	0.5	±6.1%	NTU
18-Nov-25	2517341	TQU003	Mnqumeni Reticulation	Cl ₂ (F) OS*	0.72	-	mg Cl ₂ /L
18-Nov-25	2517341	TQU003	Mnqumeni Reticulation	Cl ₂ (T) OS*	0.80	-	mg Cl ₂ /L
18-Nov-25	2517342	TQU003	Mnqumeni Reticulation	Coliforms*	1	±15%	MPN/100mL
18-Nov-25	2517341	TQU003	Mnqumeni Reticulation	Coll Time OS*	06:00	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

18-Nov-25	2517345	TQU003	Mnqumeni Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
18-Nov-25	2517344	TQU003	Mnqumeni Reticulation	Conductivity	11.0	±1.5%	mS/m
18-Nov-25	2517342	TQU003	Mnqumeni Reticulation	E.coli*	0	±14%	MPN/100mL
18-Nov-25	2517342	TQU003	Mnqumeni Reticulation	HPC 37*	0	±21%	CFU/mL
18-Nov-25	2517345	TQU003	Mnqumeni Reticulation	Odour*	Mild Chlorinous	-	-
18-Nov-25	2517341	TQU003	Mnqumeni Reticulation	pH OS*	7.40	-	-
18-Nov-25	2517341	TQU003	Mnqumeni Reticulation	Temperature OS*	21.2	-	°C
18-Nov-25	2517345	TQU003	Mnqumeni Reticulation	Turbidity	0.4	±6.1%	NTU
18-Nov-25	2517356	TSQ002	Esiqanduleni Final	Al (AE)	<25.0	±7.6%	µg Al/L
18-Nov-25	2517351	TSQ002	Esiqanduleni Final	Cl ₂ (F) OS*	1.38	-	mg Cl ₂ /L
18-Nov-25	2517351	TSQ002	Esiqanduleni Final	Cl ₂ (T) OS*	1.47	-	mg Cl ₂ /L
18-Nov-25	2517352	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
18-Nov-25	2517351	TSQ002	Esiqanduleni Final	Coll Time OS*	06:11	-	-
18-Nov-25	2517355	TSQ002	Esiqanduleni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
18-Nov-25	2517354	TSQ002	Esiqanduleni Final	Conductivity	21.8	±1.5%	mS/m
18-Nov-25	2517352	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
18-Nov-25	2517352	TSQ002	Esiqanduleni Final	HPC 37*	0	±21%	CFU/mL
18-Nov-25	2517355	TSQ002	Esiqanduleni Final	Odour*	Mild Chlorinous	-	-
18-Nov-25	2517351	TSQ002	Esiqanduleni Final	pH OS*	7.30	-	-
18-Nov-25	2517355	TSQ002	Esiqanduleni Final	Taste*	Mild Chlorinous	-	-
18-Nov-25	2517351	TSQ002	Esiqanduleni Final	Temperature OS*	20.2	-	°C
18-Nov-25	2517355	TSQ002	Esiqanduleni Final	Turbidity	0.2	±6.1%	NTU
18-Nov-25	2517357	TSQ003	Esiqanduleni Reticulation	Cl ₂ (F) OS*	1.02	-	mg Cl ₂ /L
18-Nov-25	2517357	TSQ003	Esiqanduleni Reticulation	Cl ₂ (T) OS*	1.12	-	mg Cl ₂ /L
18-Nov-25	2517358	TSQ003	Esiqanduleni Reticulation	Coliforms*	0	±15%	MPN/100mL
18-Nov-25	2517357	TSQ003	Esiqanduleni Reticulation	Coll Time OS*	06:30	-	-
18-Nov-25	2517361	TSQ003	Esiqanduleni Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
18-Nov-25	2517360	TSQ003	Esiqanduleni Reticulation	Conductivity	9.56	±1.5%	mS/m
18-Nov-25	2517358	TSQ003	Esiqanduleni Reticulation	E.coli*	0	±14%	MPN/100mL
18-Nov-25	2517358	TSQ003	Esiqanduleni Reticulation	HPC 37*	0	±21%	CFU/mL
18-Nov-25	2517361	TSQ003	Esiqanduleni Reticulation	Odour*	Mild Chlorinous	-	-
18-Nov-25	2517357	TSQ003	Esiqanduleni Reticulation	pH OS*	7.30	-	-
18-Nov-25	2517357	TSQ003	Esiqanduleni Reticulation	Temperature OS*	20.1	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

18-Nov-25	2517361	TSQ003	Esiqanduleni Reticulation	Turbidity	2.3	±6.1%	NTU
19-Nov-25	2517969	TBU002	Bulwer Final	Cl ₂ (F) OS*	1.07	-	mg Cl ₂ /L
19-Nov-25	2517969	TBU002	Bulwer Final	Cl ₂ (T) OS*	1.18	-	mg Cl ₂ /L
19-Nov-25	2517970	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
19-Nov-25	2517969	TBU002	Bulwer Final	Coll Time OS*	09:58	-	-
19-Nov-25	2517973	TBU002	Bulwer Final	Colour	<1.00	±6.5%	mg Pt-Co/L
19-Nov-25	2517972	TBU002	Bulwer Final	Conductivity	4.36	±1.5%	mS/m
19-Nov-25	2517970	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
19-Nov-25	2517974	TBU002	Bulwer Final	Fe (AE)	0.20	±5.4%	mg Fe/L
19-Nov-25	2517970	TBU002	Bulwer Final	HPC 37*	0	±21%	CFU/mL
19-Nov-25	2517973	TBU002	Bulwer Final	Odour*	Nil	-	-
19-Nov-25	2517969	TBU002	Bulwer Final	pH OS*	7.30	-	-
19-Nov-25	2517969	TBU002	Bulwer Final	Temperature OS*	19.5	-	°C
19-Nov-25	2517973	TBU002	Bulwer Final	Turbidity	4.9	±6.1%	NTU
19-Nov-25	2517975	TBU005	Bulwer Mountain Park Hotel Retic	Cl ₂ (F) OS*	0.52	-	mg Cl ₂ /L
19-Nov-25	2517975	TBU005	Bulwer Mountain Park Hotel Retic	Cl ₂ (T) OS*	0.64	-	mg Cl ₂ /L
19-Nov-25	2517976	TBU005	Bulwer Mountain Park Hotel Retic	Coliforms*	0	±15%	MPN/100mL
19-Nov-25	2517975	TBU005	Bulwer Mountain Park Hotel Retic	Coll Time OS*	10::30	-	-
19-Nov-25	2517979	TBU005	Bulwer Mountain Park Hotel Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
19-Nov-25	2517978	TBU005	Bulwer Mountain Park Hotel Retic	Conductivity	5.28	±1.5%	mS/m
19-Nov-25	2517976	TBU005	Bulwer Mountain Park Hotel Retic	E.coli*	0	±14%	MPN/100mL
19-Nov-25	2517976	TBU005	Bulwer Mountain Park Hotel Retic	HPC 37*	9	±21%	CFU/mL
19-Nov-25	2517975	TBU005	Bulwer Mountain Park Hotel Retic	pH OS*	7.50	-	-
19-Nov-25	2517975	TBU005	Bulwer Mountain Park Hotel Retic	Temperature OS*	21.3	-	°C
19-Nov-25	2517979	TBU005	Bulwer Mountain Park Hotel Retic	Turbidity	8.9	±6.1%	NTU
19-Nov-25	2517991	TCR004	Creighton Madondo Cottages	Cl ₂ (F) OS*	0.62	-	mg Cl ₂ /L
19-Nov-25	2517991	TCR004	Creighton Madondo Cottages	Cl ₂ (T) OS*	0.70	-	mg Cl ₂ /L
19-Nov-25	2517992	TCR004	Creighton Madondo Cottages	Coliforms*	118	±15%	MPN/100mL
19-Nov-25	2517991	TCR004	Creighton Madondo Cottages	Coll Time OS*	07:00	-	-
19-Nov-25	2517992	TCR004	Creighton Madondo Cottages	E.coli*	0	±14%	MPN/100mL
19-Nov-25	2517992	TCR004	Creighton Madondo Cottages	HPC 37*	38	±21%	CFU/mL
19-Nov-25	2517991	TCR004	Creighton Madondo Cottages	pH OS*	7.30	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

19-Nov-25	2517991	TCR004	Creighton Madondo Cottages	Temperature OS*	19.7	-	°C
19-Nov-25	2517994	TCR004	Creighton Madondo Cottages	Turbidity	4.2	±6.1%	NTU
19-Nov-25	2518004	THL002	Hlanganani Final	Cl2 (F) OS*	1.22	-	mg Cl2/L
19-Nov-25	2518004	THL002	Hlanganani Final	Cl2 (T) OS*	1.33	-	mg Cl2/L
19-Nov-25	2518005	THL002	Hlanganani Final	Coliforms*	4	±15%	MPN/100mL
19-Nov-25	2518004	THL002	Hlanganani Final	Coll Time OS*	10:50	-	-
19-Nov-25	2518008	THL002	Hlanganani Final	Colour	<1.00	±6.5%	mg Pt-Co/L
19-Nov-25	2518007	THL002	Hlanganani Final	Conductivity	9.89	±1.5%	mS/m
19-Nov-25	2518005	THL002	Hlanganani Final	E.coli*	3	±14%	MPN/100mL
19-Nov-25	2518005	THL002	Hlanganani Final	HPC 37*	3	±21%	CFU/mL
19-Nov-25	2518008	THL002	Hlanganani Final	Odour*	Nil	-	-
19-Nov-25	2518004	THL002	Hlanganani Final	pH OS*	7.30	-	-
19-Nov-25	2518008	THL002	Hlanganani Final	Taste*	Nil	-	-
19-Nov-25	2518004	THL002	Hlanganani Final	Temperature OS*	24.4	-	°C
19-Nov-25	2518008	THL002	Hlanganani Final	Turbidity	<0.2	±6.1%	NTU
19-Nov-25	2518009	THL003	Hlanganani Clinic Reticulation	Cl2 (F) OS*	0.42	-	mg Cl2/L
19-Nov-25	2518009	THL003	Hlanganani Clinic Reticulation	Cl2 (T) OS*	0.54	-	mg Cl2/L
19-Nov-25	2518010	THL003	Hlanganani Clinic Reticulation	Coliforms*	0	±15%	MPN/100mL
19-Nov-25	2518009	THL003	Hlanganani Clinic Reticulation	Coll Time OS*	11:10	-	-
19-Nov-25	2518013	THL003	Hlanganani Clinic Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
19-Nov-25	2518012	THL003	Hlanganani Clinic Reticulation	Conductivity	10.3	±1.5%	mS/m
19-Nov-25	2518010	THL003	Hlanganani Clinic Reticulation	E.coli*	0	±14%	MPN/100mL
19-Nov-25	2518010	THL003	Hlanganani Clinic Reticulation	HPC 37*	0	±21%	CFU/mL
19-Nov-25	2518009	THL003	Hlanganani Clinic Reticulation	pH OS*	7.30	-	-
19-Nov-25	2518009	THL003	Hlanganani Clinic Reticulation	Temperature OS*	23.7	-	°C
19-Nov-25	2518013	THL003	Hlanganani Clinic Reticulation	Turbidity	0.4	±6.1%	NTU
19-Nov-25	2518043	TMQA002	Mqatsheni Final	Cl2 (F) OS*	1.11	-	mg Cl2/L
19-Nov-25	2518043	TMQA002	Mqatsheni Final	Cl2 (T) OS*	1.21	-	mg Cl2/L
19-Nov-25	2518044	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
19-Nov-25	2518043	TMQA002	Mqatsheni Final	Coll Time OS*	08:49	-	-
19-Nov-25	2518047	TMQA002	Mqatsheni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
19-Nov-25	2518046	TMQA002	Mqatsheni Final	Conductivity	24.5	±1.5%	mS/m
19-Nov-25	2518044	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
19-Nov-25	2518044	TMQA002	Mqatsheni Final	HPC 37*	0	±21%	CFU/mL
19-Nov-25	2518047	TMQA002	Mqatsheni Final	Odour*	Nil	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

19-Nov-25	2518043	TMQA002	Mqatsheni Final	pH OS*	8.40	-	-
19-Nov-25	2518043	TMQA002	Mqatsheni Final	Temperature OS*	18.0	-	°C
19-Nov-25	2518047	TMQA002	Mqatsheni Final	Turbidity	0.7	±6.1%	NTU
19-Nov-25	2518048	TMQA003	Mqatsheni Reticulation	Cl ₂ (F) OS*	0.70	-	mg Cl ₂ /L
19-Nov-25	2518048	TMQA003	Mqatsheni Reticulation	Cl ₂ (T) OS*	0.82	-	mg Cl ₂ /L
19-Nov-25	2518049	TMQA003	Mqatsheni Reticulation	Coliforms*	0	±15%	MPN/100mL
19-Nov-25	2518048	TMQA003	Mqatsheni Reticulation	Coll Time OS*	08:58	-	-
19-Nov-25	2518052	TMQA003	Mqatsheni Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
19-Nov-25	2518051	TMQA003	Mqatsheni Reticulation	Conductivity	24.6	±1.5%	mS/m
19-Nov-25	2518049	TMQA003	Mqatsheni Reticulation	E.coli*	0	±14%	MPN/100mL
19-Nov-25	2518049	TMQA003	Mqatsheni Reticulation	HPC 37*	1	±21%	CFU/mL
19-Nov-25	2518048	TMQA003	Mqatsheni Reticulation	pH OS*	8.20	-	-
19-Nov-25	2518048	TMQA003	Mqatsheni Reticulation	Temperature OS*	18.6	-	°C
19-Nov-25	2518052	TMQA003	Mqatsheni Reticulation	Turbidity	0.9	±6.1%	NTU
19-Nov-25	2518068	TRV002	Riverside Final	Cl ₂ (F) OS*	0.87	-	mg Cl ₂ /L
19-Nov-25	2518068	TRV002	Riverside Final	Cl ₂ (T) OS*	1.02	-	mg Cl ₂ /L
19-Nov-25	2518069	TRV002	Riverside Final	Coliforms*	1	±15%	MPN/100mL
19-Nov-25	2518068	TRV002	Riverside Final	Coll Time OS*	08:21	-	-
19-Nov-25	2518072	TRV002	Riverside Final	Colour	8.00	±6.5%	mg Pt-Co/L
19-Nov-25	2518071	TRV002	Riverside Final	Conductivity	7.61	±1.5%	mS/m
19-Nov-25	2518069	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
19-Nov-25	2518069	TRV002	Riverside Final	HPC 37*	22	±21%	CFU/mL
19-Nov-25	2518072	TRV002	Riverside Final	Odour*	Mild Earthy	-	-
19-Nov-25	2518068	TRV002	Riverside Final	pH OS*	7.30	-	-
19-Nov-25	2518068	TRV002	Riverside Final	Temperature OS*	18.6	-	°C
19-Nov-25	2518072	TRV002	Riverside Final	Turbidity	12.4	±6.1%	NTU
19-Nov-25	2518073	TRV003	Riverside Reticulation	Cl ₂ (F) OS*	0.40	-	mg Cl ₂ /L
19-Nov-25	2518073	TRV003	Riverside Reticulation	Cl ₂ (T) OS*	0.48	-	mg Cl ₂ /L
19-Nov-25	2518074	TRV003	Riverside Reticulation	Coliforms*	0	±15%	MPN/100mL
19-Nov-25	2518073	TRV003	Riverside Reticulation	Coll Time OS*	08:09	-	-
19-Nov-25	2518076	TRV003	Riverside Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
19-Nov-25	2518074	TRV003	Riverside Reticulation	E.coli*	0	±14%	MPN/100mL
19-Nov-25	2518074	TRV003	Riverside Reticulation	HPC 37*	16	±21%	CFU/mL
19-Nov-25	2518076	TRV003	Riverside Reticulation	Odour*	Nil	-	-
19-Nov-25	2518073	TRV003	Riverside Reticulation	pH OS*	7.20	-	-
19-Nov-25	2518073	TRV003	Riverside Reticulation	Temperature OS*	18.1	-	°C
19-Nov-25	2518076	TRV003	Riverside Reticulation	Turbidity	9.8	±6.1%	NTU
19-Nov-25	2518082	TST002	St Appollinaris Final	Cl ₂ (F) OS*	0.70	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

19-Nov-25	2518082	TST002	St Appollinaris Final	Cl ₂ (T) OS*	0.80	-	mg Cl ₂ /L
19-Nov-25	2518083	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
19-Nov-25	2518082	TST002	St Appollinaris Final	Coll Time OS*	09:10	-	-
19-Nov-25	2518086	TST002	St Appollinaris Final	Colour	<1.00	±6.5%	mg Pt-Co/L
19-Nov-25	2518085	TST002	St Appollinaris Final	Conductivity	6.81	±1.5%	mS/m
19-Nov-25	2518083	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
19-Nov-25	2518083	TST002	St Appollinaris Final	HPC 37*	0	±21%	CFU/mL
19-Nov-25	2518086	TST002	St Appollinaris Final	Odour*	Mild Chlorinous	-	-
19-Nov-25	2518082	TST002	St Appollinaris Final	pH OS*	7.40	-	-
19-Nov-25	2518082	TST002	St Appollinaris Final	Temperature OS*	22.6	-	°C
19-Nov-25	2518086	TST002	St Appollinaris Final	Turbidity	0.9	±6.1%	NTU
19-Nov-25	2518097	TUN002	Underberg Final	Al (AE)	54.2	±7.6%	µg Al/L
19-Nov-25	2518092	TUN002	Underberg Final	Cl ₂ (F) OS*	0.42	-	mg Cl ₂ /L
19-Nov-25	2518092	TUN002	Underberg Final	Cl ₂ (T) OS*	0.58	-	mg Cl ₂ /L
19-Nov-25	2518093	TUN002	Underberg Final	Coliforms*	29	±15%	MPN/100mL
19-Nov-25	2518092	TUN002	Underberg Final	Coll Time OS*	09:58	-	-
19-Nov-25	2518096	TUN002	Underberg Final	Colour	<1.00	±6.5%	mg Pt-Co/L
19-Nov-25	2518095	TUN002	Underberg Final	Conductivity	3.79	±1.5%	mS/m
19-Nov-25	2518093	TUN002	Underberg Final	E.coli*	4	±14%	MPN/100mL
19-Nov-25	2518093	TUN002	Underberg Final	HPC 37*	9	±21%	CFU/mL
19-Nov-25	2518096	TUN002	Underberg Final	Odour*	Nil	-	-
19-Nov-25	2518092	TUN002	Underberg Final	pH OS*	7.50	-	-
19-Nov-25	2518092	TUN002	Underberg Final	Temperature OS*	20.1	-	°C
19-Nov-25	2518096	TUN002	Underberg Final	Turbidity	0.7	±6.1%	NTU
20-Nov-25	2518723	TMZ002	Umzimkhulu Final	Al (AE)	343	±7.6%	µg Al/L
20-Nov-25	2518718	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	1.10	-	mg Cl ₂ /L
20-Nov-25	2518718	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	1.21	-	mg Cl ₂ /L
20-Nov-25	2518719	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
20-Nov-25	2518719	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10mL
20-Nov-25	2518718	TMZ002	Umzimkhulu Final	Coll Time OS*	09:20	-	-
20-Nov-25	2518721	TMZ002	Umzimkhulu Final	Conductivity	7.98	±1.5%	mS/m
20-Nov-25	2518719	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
20-Nov-25	2518719	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	CFU/mL
20-Nov-25	2518718	TMZ002	Umzimkhulu Final	pH OS*	7.50	-	-
20-Nov-25	2518718	TMZ002	Umzimkhulu Final	Temperature OS*	22.3	-	°C
20-Nov-25	2518722	TMZ002	Umzimkhulu Final	Turbidity	4.7	±6.1%	NTU
20-Nov-25	2518724	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (F) OS*	1.05	-	mg Cl ₂ /L
20-Nov-25	2518724	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (T) OS*	1.12	-	mg Cl ₂ /L
20-Nov-25	2518725	TMZ004	Umzikhulu Informal Settlement Retic	Coliforms*	2	±15%	MPN/100mL
20-Nov-25	2518724	TMZ004	Umzikhulu Informal Settlement Retic	Coll Time OS*	08:40	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

20-Nov-25	2518728	TMZ004	Umzikhulu Informal Settlement Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
20-Nov-25	2518727	TMZ004	Umzikhulu Informal Settlement Retic	Conductivity	9.32	±1.5%	mS/m
20-Nov-25	2518725	TMZ004	Umzikhulu Informal Settlement Retic	E.coli*	0	±14%	MPN/100mL
20-Nov-25	2518725	TMZ004	Umzikhulu Informal Settlement Retic	HPC 37*	132	±21%	CFU/mL
20-Nov-25	2518728	TMZ004	Umzikhulu Informal Settlement Retic	Odour*	Nil	-	-
20-Nov-25	2518724	TMZ004	Umzikhulu Informal Settlement Retic	pH OS*	7.40	-	-
20-Nov-25	2518724	TMZ004	Umzikhulu Informal Settlement Retic	Temperature OS*	22.1	-	°C
20-Nov-25	2518728	TMZ004	Umzikhulu Informal Settlement Retic	Turbidity	10.8	±6.1%	NTU
20-Nov-25	2518729	TMZ005	Umzikhulu Local Municipality Offices	Cl ₂ (F) OS*	1.70	-	mg Cl ₂ /L
20-Nov-25	2518729	TMZ005	Umzikhulu Local Municipality Offices	Cl ₂ (T) OS*	1.82	-	mg Cl ₂ /L
20-Nov-25	2518730	TMZ005	Umzikhulu Local Municipality Offices	Coliforms*	0	±15%	MPN/100mL
20-Nov-25	2518729	TMZ005	Umzikhulu Local Municipality Offices	Coll Time OS*	09:26	-	-
20-Nov-25	2518733	TMZ005	Umzikhulu Local Municipality Offices	Colour	<1.00	±6.5%	mg Pt-Co/L
20-Nov-25	2518732	TMZ005	Umzikhulu Local Municipality Offices	Conductivity	10.5	±1.5%	mS/m
20-Nov-25	2518730	TMZ005	Umzikhulu Local Municipality Offices	E.coli*	0	±14%	MPN/100mL
20-Nov-25	2518730	TMZ005	Umzikhulu Local Municipality Offices	HPC 37*	3	±21%	CFU/mL
20-Nov-25	2518729	TMZ005	Umzikhulu Local Municipality Offices	pH OS*	7.40	-	-
20-Nov-25	2518729	TMZ005	Umzikhulu Local Municipality Offices	Temperature OS*	22.5	-	°C
20-Nov-25	2518733	TMZ005	Umzikhulu Local Municipality Offices	Turbidity	5.8	±6.1%	NTU
20-Nov-25	2518734	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Cl ₂ (F) OS*	0.89	-	mg Cl ₂ /L
20-Nov-25	2518734	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Cl ₂ (T) OS*	0.99	-	mg Cl ₂ /L
20-Nov-25	2518735	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
20-Nov-25	2518734	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Coll Time OS*	08:59	-	-
20-Nov-25	2518735	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
20-Nov-25	2518735	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	HPC 37*	0	±21%	CFU/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

20-Nov-25	2518734	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	pH OS*	7.30	-	-
20-Nov-25	2518734	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Temperature OS*	22.3	-	°C
20-Nov-25	2518737	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Turbidity	3.9	±6.1%	NTU
20-Nov-25	2518749	TNO003	Nokweja Standpipe A Reticulation	Cl ₂ (F) OS*	0.56	-	mg Cl ₂ /L
20-Nov-25	2518749	TNO003	Nokweja Standpipe A Reticulation	Cl ₂ (T) OS*	0.75	-	mg Cl ₂ /L
20-Nov-25	2518750	TNO003	Nokweja Standpipe A Reticulation	Coliforms*	0	±15%	MPN/100mL
20-Nov-25	2518749	TNO003	Nokweja Standpipe A Reticulation	Coll Time OS*	07:20	-	-
20-Nov-25	2518753	TNO003	Nokweja Standpipe A Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
20-Nov-25	2518752	TNO003	Nokweja Standpipe A Reticulation	Conductivity	7.93	±1.5%	mS/m
20-Nov-25	2518750	TNO003	Nokweja Standpipe A Reticulation	E.coli*	0	±14%	MPN/100mL
20-Nov-25	2518750	TNO003	Nokweja Standpipe A Reticulation	HPC 37*	3	±21%	CFU/mL
20-Nov-25	2518753	TNO003	Nokweja Standpipe A Reticulation	Odour*	Nil	-	-
20-Nov-25	2518749	TNO003	Nokweja Standpipe A Reticulation	pH OS*	7.50	-	-
20-Nov-25	2518749	TNO003	Nokweja Standpipe A Reticulation	Temperature OS*	20.3	-	°C
20-Nov-25	2518753	TNO003	Nokweja Standpipe A Reticulation	Turbidity	14.9	±6.1%	NTU
20-Nov-25	2518754	TNO004	Nokweja Standpipe B Reticulation	Cl ₂ (F) OS*	0.60	-	mg Cl ₂ /L
20-Nov-25	2518754	TNO004	Nokweja Standpipe B Reticulation	Cl ₂ (T) OS*	0.84	-	mg Cl ₂ /L
20-Nov-25	2518755	TNO004	Nokweja Standpipe B Reticulation	Coliforms*	0	±15%	MPN/100mL
20-Nov-25	2518754	TNO004	Nokweja Standpipe B Reticulation	Coll Time OS*	07:29	-	-
20-Nov-25	2518758	TNO004	Nokweja Standpipe B Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
20-Nov-25	2518757	TNO004	Nokweja Standpipe B Reticulation	Conductivity	7.94	±1.5%	mS/m
20-Nov-25	2518755	TNO004	Nokweja Standpipe B Reticulation	E.coli*	0	±14%	MPN/100mL
20-Nov-25	2518755	TNO004	Nokweja Standpipe B Reticulation	HPC 37*	7	±21%	CFU/mL
20-Nov-25	2518758	TNO004	Nokweja Standpipe B Reticulation	Odour*	Nil	-	-
20-Nov-25	2518754	TNO004	Nokweja Standpipe B Reticulation	pH OS*	7.50	-	-
20-Nov-25	2518754	TNO004	Nokweja Standpipe B Reticulation	Temperature OS*	21.2	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

20-Nov-25	2518758	TNO004	Nokweja Standpipe B Reticulation	Turbidity	16.5	±6.1%	NTU
20-Nov-25	2518802	TWA002	Washbank Final	Al (AE)	405	±7.6%	µg Al/L
20-Nov-25	2518797	TWA002	Washbank Final	Cl2 (F) OS*	0.56	-	mg Cl2/L
20-Nov-25	2518797	TWA002	Washbank Final	Cl2 (T) OS*	0.65	-	mg Cl2/L
20-Nov-25	2518798	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
20-Nov-25	2518797	TWA002	Washbank Final	Coll Time OS*	08:35	-	-
20-Nov-25	2518801	TWA002	Washbank Final	Colour	<1.00	±6.5%	mg Pt-Co/L
20-Nov-25	2518800	TWA002	Washbank Final	Conductivity	9.69	±1.5%	mS/m
20-Nov-25	2518798	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
20-Nov-25	2518798	TWA002	Washbank Final	HPC 37*	0	±21%	CFU/mL
20-Nov-25	2518801	TWA002	Washbank Final	Odour*	Mild Chlorinous	-	-
20-Nov-25	2518797	TWA002	Washbank Final	pH OS*	7.30	-	-
20-Nov-25	2518797	TWA002	Washbank Final	Temperature OS*	18.9	-	°C
20-Nov-25	2518801	TWA002	Washbank Final	Turbidity	2.3	±6.1%	NTU
21-Nov-25	2519067	TIB002	Ibisi Final	Al (AE)	1236	±7.6%	µg Al/L
21-Nov-25	2519062	TIB002	Ibisi Final	Cl2 (F) OS*	<0.05	-	mg Cl2/L
21-Nov-25	2519062	TIB002	Ibisi Final	Cl2 (T) OS*	<0.05	-	mg Cl2/L
21-Nov-25	2519063	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
21-Nov-25	2519063	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10mL
21-Nov-25	2519062	TIB002	Ibisi Final	Coll Time OS*	06:50	-	-
21-Nov-25	2519066	TIB002	Ibisi Final	Colour	1.10	±6.5%	mg Pt-Co/L
21-Nov-25	2519065	TIB002	Ibisi Final	Conductivity	9.86	±1.5%	mS/m
21-Nov-25	2519063	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
21-Nov-25	2519063	TIB002	Ibisi Final	HPC 37*	56	±21%	CFU/mL
21-Nov-25	2519066	TIB002	Ibisi Final	Odour*	Nil	-	-
21-Nov-25	2519062	TIB002	Ibisi Final	pH OS*	7.40	-	-
21-Nov-25	2519062	TIB002	Ibisi Final	Temperature OS*	18.9	-	°C
21-Nov-25	2519066	TIB002	Ibisi Final	Turbidity	15.1	±6.1%	NTU
21-Nov-25	2519082	TRT002	Rietvlei Final	Al (AE)	410	±7.6%	µg Al/L
21-Nov-25	2519077	TRT002	Rietvlei Final	Cl2 (F) OS*	0.42	-	mg Cl2/L
21-Nov-25	2519077	TRT002	Rietvlei Final	Cl2 (T) OS*	0.54	-	mg Cl2/L
21-Nov-25	2519078	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
21-Nov-25	2519077	TRT002	Rietvlei Final	Coll Time OS*	05:59	-	-
21-Nov-25	2519080	TRT002	Rietvlei Final	Conductivity	18.1	±1.5%	mS/m
21-Nov-25	2519078	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
21-Nov-25	2519082	TRT002	Rietvlei Final	Fe (AE)	0.06	±5.4%	mg Fe/L
21-Nov-25	2519078	TRT002	Rietvlei Final	HPC 37*	7	±21%	CFU/mL
21-Nov-25	2519082	TRT002	Rietvlei Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
21-Nov-25	2519081	TRT002	Rietvlei Final	Odour*	Mild Chlorinous	-	-
21-Nov-25	2519077	TRT002	Rietvlei Final	pH OS*	7.50	-	-
21-Nov-25	2519077	TRT002	Rietvlei Final	Temperature OS*	18.1	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

21-Nov-25	2519081	TRT002	Rietvlei Final	Turbidity	2.2	±6.1%	NTU
24-Nov-25	2521934	TFR002	Franklin Final	Al (AE)	80.5	±7.6%	µg Al/L
24-Nov-25	2521929	TFR002	Franklin Final	Cl ₂ (F) OS*	1.09	-	mg Cl ₂ /L
24-Nov-25	2521929	TFR002	Franklin Final	Cl ₂ (T) OS*	1.21	-	mg Cl ₂ /L
24-Nov-25	2521930	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
24-Nov-25	2521930	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10mL
24-Nov-25	2521929	TFR002	Franklin Final	Coll Time OS*	08:30	-	-
24-Nov-25	2521932	TFR002	Franklin Final	Conductivity	14.9	±1.5%	mS/m
24-Nov-25	2521930	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
24-Nov-25	2521930	TFR002	Franklin Final	HPC 37*	0	±21%	CFU/mL
24-Nov-25	2521933	TFR002	Franklin Final	Odour*	Mild Chlorinous	-	-
24-Nov-25	2521929	TFR002	Franklin Final	pH OS*	7.60	-	-
24-Nov-25	2521929	TFR002	Franklin Final	Temperature OS*	18.3	-	°C
24-Nov-25	2521933	TFR002	Franklin Final	Turbidity	0.8	±6.1%	NTU
24-Nov-25	2521957	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
24-Nov-25	2521952	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.14	-	mg Cl ₂ /L
24-Nov-25	2521952	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.19	-	mg Cl ₂ /L
24-Nov-25	2521953	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
24-Nov-25	2521953	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10mL
24-Nov-25	2521952	TKK002	Kokstad Final	Coll Time OS*	10:12	-	-
24-Nov-25	2521955	TKK002	Kokstad Final	Conductivity	11.5	±1.5%	mS/m
24-Nov-25	2521953	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
24-Nov-25	2521953	TKK002	Kokstad Final	HPC 37*	0	±21%	CFU/mL
24-Nov-25	2521952	TKK002	Kokstad Final	pH OS*	7.40	-	-
24-Nov-25	2521952	TKK002	Kokstad Final	Temperature OS*	19.2	-	°C
24-Nov-25	2521956	TKK002	Kokstad Final	Turbidity	0.3	±6.1%	NTU
24-Nov-25	2521963	TKK011	Kokstad Hospital Reticulation	Cl ₂ (F) OS*	0.65	-	mg Cl ₂ /L
24-Nov-25	2521963	TKK011	Kokstad Hospital Reticulation	Cl ₂ (T) OS*	0.82	-	mg Cl ₂ /L
24-Nov-25	2521964	TKK011	Kokstad Hospital Reticulation	Coliforms*	4	±15%	MPN/100mL
24-Nov-25	2521963	TKK011	Kokstad Hospital Reticulation	Coll Time OS*	09:12	-	-
24-Nov-25	2521967	TKK011	Kokstad Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
24-Nov-25	2521966	TKK011	Kokstad Hospital Reticulation	Conductivity	13.2	±1.5%	mS/m
24-Nov-25	2521964	TKK011	Kokstad Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
24-Nov-25	2521964	TKK011	Kokstad Hospital Reticulation	HPC 37*	3	±21%	CFU/mL
24-Nov-25	2521963	TKK011	Kokstad Hospital Reticulation	pH OS*	7.50	-	-
24-Nov-25	2521963	TKK011	Kokstad Hospital Reticulation	Temperature OS*	17.2	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

24-Nov-25	2521967	TKK011	Kokstad Hospital Reticulation	Turbidity	0.3	±6.1%	NTU
24-Nov-25	2521990	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	0.76	-	mg Cl ₂ /L
24-Nov-25	2521990	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	0.89	-	mg Cl ₂ /L
24-Nov-25	2521991	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
24-Nov-25	2521990	TNJU002	KwaNjunga Final	Coll Time OS*	06:27	-	-
24-Nov-25	2521993	TNJU002	KwaNjunga Final	Conductivity	18.3	±1.5%	mS/m
24-Nov-25	2521991	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
24-Nov-25	2521991	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	CFU/mL
24-Nov-25	2521990	TNJU002	KwaNjunga Final	pH OS*	7.50	-	-
24-Nov-25	2521990	TNJU002	KwaNjunga Final	Temperature OS*	20.1	-	°C
24-Nov-25	2521994	TNJU002	KwaNjunga Final	Turbidity	1.6	±6.1%	NTU
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Al (AE)	56.3	±7.6%	µg Al/L
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	As (AE)*	<5.00	±7.5%	µg As/L
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	B (AE)	<25.0	±6.6%	µg B/L
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Ba (AE)	25.0	±6.9%	µg Ba/L
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Cd (AE)	<1.00	±6%	µg Cd/L
25-Nov-25	2522411	TJO001	Jolivet RRT frn Vulamehlo	CHBr ₃	<10	±6.4%	µg/L
25-Nov-25	2522411	TJO001	Jolivet RRT frn Vulamehlo	CHCl ₂ Br	<10	±5.7%	µg/L
25-Nov-25	2522411	TJO001	Jolivet RRT frn Vulamehlo	CHCl ₃	13.5	±6%	µg/L
25-Nov-25	2522411	TJO001	Jolivet RRT frn Vulamehlo	CHClBr ₂	<10	±5.3%	µg/L
25-Nov-25	2522408	TJO001	Jolivet RRT frn Vulamehlo	Cl*	15.6	±1.8%	mg Cl/L
25-Nov-25	2522402	TJO001	Jolivet RRT frn Vulamehlo	Cl ₂ (F) OS*	0.45	-	mg Cl ₂ /L
25-Nov-25	2522402	TJO001	Jolivet RRT frn Vulamehlo	Cl ₂ (T) OS*	0.56	-	mg Cl ₂ /L
25-Nov-25	2522406	TJO001	Jolivet RRT frn Vulamehlo	CN (T)	<25.0	±8.6%	µg CN/L
25-Nov-25	2522403	TJO001	Jolivet RRT frn Vulamehlo	Coliforms*	0	±15%	MPN/100mL
25-Nov-25	2522403	TJO001	Jolivet RRT frn Vulamehlo	Coliphages*	0	±8%	PFU/10mL
25-Nov-25	2522402	TJO001	Jolivet RRT frn Vulamehlo	Coll Time OS*	08:37	-	-
25-Nov-25	2522409	TJO001	Jolivet RRT frn Vulamehlo	Colour	1.00	±6.5%	mg Pt-Co/L
25-Nov-25	2522408	TJO001	Jolivet RRT frn Vulamehlo	Combined NO ₃ + NO ₂ ratio*	0.15	-	-
25-Nov-25	2522411	TJO001	Jolivet RRT frn Vulamehlo	Combined THM Ratio*	0.41	-	-
25-Nov-25	2522408	TJO001	Jolivet RRT frn Vulamehlo	Conductivity	11.9	±1.5%	mS/m
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Cr (T)*	<5.00	±5.3%	µg Cr/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Cu (AE)	<0.05	±4.1%	mg Cu/L
25-Nov-25	2522403	TJO001	Jolivet RRT frn Vulamehlo	E.coli*	0	±14%	MPN/100mL
25-Nov-25	2522408	TJO001	Jolivet RRT frn Vulamehlo	F	<100	±5.3%	µg F/L
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Fe (AE)	0.04	±5.4%	mg Fe/L
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Hg (AE)*	<1.00	±6.5%	µg Hg/L
25-Nov-25	2522403	TJO001	Jolivet RRT frn Vulamehlo	HPC 37*	0	±21%	CFU/mL
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Mn (AE)	<0.01	±6.2%	mg Mn/L
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Na (AE)	40.2	±7.5%	mg Na/L
25-Nov-25	2522408	TJO001	Jolivet RRT frn Vulamehlo	NH3*	0.14	±5.5%	mg N/L
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Ni (AE)	<10.0	±5.9%	µg Ni/L
25-Nov-25	2522408	TJO001	Jolivet RRT frn Vulamehlo	NO2*	<0.10	±2.4%	mg N/L
25-Nov-25	2522408	TJO001	Jolivet RRT frn Vulamehlo	NO3*	0.39	±2.9%	mg N/L
25-Nov-25	2522409	TJO001	Jolivet RRT frn Vulamehlo	Odour*	Mild Chlorinous	-	-
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Pb (AE)	<4.00	±6.7%	µg Pb/L
25-Nov-25	2522402	TJO001	Jolivet RRT frn Vulamehlo	pH OS*	7.82	-	-
25-Nov-25	2522407	TJO001	Jolivet RRT frn Vulamehlo	Phenols*	<10.0	-	µg/L
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Sb (AE)*	<5.00	±7%	µg Sb/L
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Se (AE)*	<5.00	±7.7%	µg Se/L
25-Nov-25	2522408	TJO001	Jolivet RRT frn Vulamehlo	SO4*	1.20	±1.8%	mg SO4/L
25-Nov-25	2522409	TJO001	Jolivet RRT frn Vulamehlo	SS	<10.0	±3.7%	mg/L
25-Nov-25	2522409	TJO001	Jolivet RRT frn Vulamehlo	TDS	88.00	±2.5%	mg/L
25-Nov-25	2522402	TJO001	Jolivet RRT frn Vulamehlo	Temperature OS*	19.9	-	°C
25-Nov-25	2522409	TJO001	Jolivet RRT frn Vulamehlo	TOC	1.89	±5%	mg C/L
25-Nov-25	2522409	TJO001	Jolivet RRT frn Vulamehlo	Turbidity	0.9	±6.1%	NTU
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	U (AE)*	<10.0	±7.6%	µg U/L
25-Nov-25	2522410	TJO001	Jolivet RRT frn Vulamehlo	Zn (AE)	<0.03	±7.2%	mg Zn/L
26-Nov-25	2523049	TBU002	Bulwer Final	Cl2 (F) OS*	1.42	-	mg Cl2/L
26-Nov-25	2523049	TBU002	Bulwer Final	Cl2 (T) OS*	1.50	-	mg Cl2/L
26-Nov-25	2523050	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
26-Nov-25	2523049	TBU002	Bulwer Final	Coll Time OS*	08:56	-	-
26-Nov-25	2523052	TBU002	Bulwer Final	Conductivity	4.71	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

26-Nov-25	2523050	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
26-Nov-25	2523050	TBU002	Bulwer Final	HPC 37*	8	±21%	CFU/mL
26-Nov-25	2523049	TBU002	Bulwer Final	pH OS*	7.30	-	-
26-Nov-25	2523049	TBU002	Bulwer Final	Temperature OS*	25.8	-	°C
26-Nov-25	2523053	TBU002	Bulwer Final	Turbidity	6.4	±6.1%	NTU
26-Nov-25	2523064	TCR002	Creighton Final	AI (AE)	244	±7.6%	µg AI/L
26-Nov-25	2523059	TCR002	Creighton Final	Cl2 (F) OS*	1.11	-	mg Cl2/L
26-Nov-25	2523059	TCR002	Creighton Final	Cl2 (T) OS*	1.20	-	mg Cl2/L
26-Nov-25	2523060	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
26-Nov-25	2523059	TCR002	Creighton Final	Coll Time OS*	06:20	-	-
26-Nov-25	2523062	TCR002	Creighton Final	Conductivity	11.9	±1.5%	mS/m
26-Nov-25	2523060	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
26-Nov-25	2523060	TCR002	Creighton Final	HPC 37*	0	±21%	CFU/mL
26-Nov-25	2523059	TCR002	Creighton Final	pH OS*	7.20	-	-
26-Nov-25	2523059	TCR002	Creighton Final	Temperature OS*	18.2	-	°C
26-Nov-25	2523063	TCR002	Creighton Final	Turbidity	1.2	±6.1%	NTU
26-Nov-25	2523083	TMAN002	Mangwaneni Final	Cl2 (F) OS*	0.31	-	mg Cl2/L
26-Nov-25	2523083	TMAN002	Mangwaneni Final	Cl2 (T) OS*	0.40	-	mg Cl2/L
26-Nov-25	2523084	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
26-Nov-25	2523083	TMAN002	Mangwaneni Final	Coll Time OS*	09:51	-	-
26-Nov-25	2523086	TMAN002	Mangwaneni Final	Conductivity	8.62	±1.5%	mS/m
26-Nov-25	2523084	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
26-Nov-25	2523084	TMAN002	Mangwaneni Final	HPC 37*	11	±21%	CFU/mL
26-Nov-25	2523083	TMAN002	Mangwaneni Final	pH OS*	7.50	-	-
26-Nov-25	2523083	TMAN002	Mangwaneni Final	Temperature OS*	23.2	-	°C
26-Nov-25	2523087	TMAN002	Mangwaneni Final	Turbidity	16.0	±6.1%	NTU
26-Nov-25	2523092	TMQA002	Mqatsheni Final	Cl2 (F) OS*	1.90	-	mg Cl2/L
26-Nov-25	2523092	TMQA002	Mqatsheni Final	Cl2 (T) OS*	2.10	-	mg Cl2/L
26-Nov-25	2523093	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
26-Nov-25	2523092	TMQA002	Mqatsheni Final	Coll Time OS*	07:45	-	-
26-Nov-25	2523095	TMQA002	Mqatsheni Final	Conductivity	30.7	±1.5%	mS/m
26-Nov-25	2523093	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
26-Nov-25	2523093	TMQA002	Mqatsheni Final	HPC 37*	0	±21%	CFU/mL
26-Nov-25	2523092	TMQA002	Mqatsheni Final	pH OS*	8.90	-	-
26-Nov-25	2523092	TMQA002	Mqatsheni Final	Temperature OS*	19.8	-	°C
26-Nov-25	2523096	TMQA002	Mqatsheni Final	Turbidity	0.2	±6.1%	NTU
26-Nov-25	2523102	TRV002	Riverside Final	Cl2 (F) OS*	1.38	-	mg Cl2/L
26-Nov-25	2523102	TRV002	Riverside Final	Cl2 (T) OS*	1.45	-	mg Cl2/L
26-Nov-25	2523103	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
26-Nov-25	2523102	TRV002	Riverside Final	Coll Time OS*	07:05	-	-
26-Nov-25	2523105	TRV002	Riverside Final	Conductivity	6.82	±1.5%	mS/m
26-Nov-25	2523103	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

26-Nov-25	2523103	TRV002	Riverside Final	HPC 37*	40	±21%	CFU/mL
26-Nov-25	2523102	TRV002	Riverside Final	pH OS*	7.40	-	-
26-Nov-25	2523102	TRV002	Riverside Final	Temperature OS*	20.2	-	°C
26-Nov-25	2523106	TRV002	Riverside Final	Turbidity	29.4	±6.1%	NTU
26-Nov-25	2523112	TST002	St Appollinaris Final	Cl ₂ (F) OS*	0.60	-	mg Cl ₂ /L
26-Nov-25	2523112	TST002	St Appollinaris Final	Cl ₂ (T) OS*	0.71	-	mg Cl ₂ /L
26-Nov-25	2523113	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
26-Nov-25	2523112	TST002	St Appollinaris Final	Coll Time OS*	07:50	-	-
26-Nov-25	2523115	TST002	St Appollinaris Final	Conductivity	5.39	±1.5%	mS/m
26-Nov-25	2523113	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
26-Nov-25	2523113	TST002	St Appollinaris Final	HPC 37*	0	±21%	CFU/mL
26-Nov-25	2523112	TST002	St Appollinaris Final	pH OS*	7.50	-	-
26-Nov-25	2523112	TST002	St Appollinaris Final	Temperature OS*	22.2	-	°C
26-Nov-25	2523116	TST002	St Appollinaris Final	Turbidity	2.3	±6.1%	NTU
26-Nov-25	2523117	TST003	St Appollinaris Hospital Reticulation	Cl ₂ (F) OS*	0.41	-	mg Cl ₂ /L
26-Nov-25	2523117	TST003	St Appollinaris Hospital Reticulation	Cl ₂ (T) OS*	0.48	-	mg Cl ₂ /L
26-Nov-25	2523118	TST003	St Appollinaris Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
26-Nov-25	2523117	TST003	St Appollinaris Hospital Reticulation	Coll Time OS*	07:40	-	-
26-Nov-25	2523118	TST003	St Appollinaris Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
26-Nov-25	2523118	TST003	St Appollinaris Hospital Reticulation	HPC 37*	0	±21%	CFU/mL
26-Nov-25	2523117	TST003	St Appollinaris Hospital Reticulation	pH OS*	7.20	-	-
26-Nov-25	2523117	TST003	St Appollinaris Hospital Reticulation	Temperature OS*	17.1	-	°C
26-Nov-25	2523120	TST003	St Appollinaris Hospital Reticulation	Turbidity	1.7	±6.1%	NTU
26-Nov-25	2523131	TUN002	Underberg Final	Al (AE)	101	±7.6%	µg Al/L
26-Nov-25	2523126	TUN002	Underberg Final	Cl ₂ (F) OS*	0.83	-	mg Cl ₂ /L
26-Nov-25	2523126	TUN002	Underberg Final	Cl ₂ (T) OS*	0.95	-	mg Cl ₂ /L
26-Nov-25	2523127	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
26-Nov-25	2523126	TUN002	Underberg Final	Coll Time OS*	08:25	-	-
26-Nov-25	2523129	TUN002	Underberg Final	Conductivity	3.47	±1.5%	mS/m
26-Nov-25	2523127	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
26-Nov-25	2523127	TUN002	Underberg Final	HPC 37*	1	±21%	CFU/mL
26-Nov-25	2523126	TUN002	Underberg Final	pH OS*	7.40	-	-
26-Nov-25	2523126	TUN002	Underberg Final	Temperature OS*	22.3	-	°C
26-Nov-25	2523130	TUN002	Underberg Final	Turbidity	1.2	±6.1%	NTU
27-Nov-25	2523623	TMZ002	Umzimkhulu Final	Al (AE)	459	±7.6%	µg Al/L
27-Nov-25	2523618	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	0.65	-	mg Cl ₂ /L
27-Nov-25	2523618	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	0.74	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

27-Nov-25	2523619	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
27-Nov-25	2523619	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10mL
27-Nov-25	2523618	TMZ002	Umzimkhulu Final	Coll Time OS*	07:26	-	-
27-Nov-25	2523622	TMZ002	Umzimkhulu Final	Colour	1.30	±6.5%	mg Pt-Co/L
27-Nov-25	2523621	TMZ002	Umzimkhulu Final	Conductivity	5.79	±1.5%	mS/m
27-Nov-25	2523619	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
27-Nov-25	2523623	TMZ002	Umzimkhulu Final	Fe (AE)	0.21	±5.4%	mg Fe/L
27-Nov-25	2523619	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	CFU/mL
27-Nov-25	2523622	TMZ002	Umzimkhulu Final	Odour*	Nil	-	-
27-Nov-25	2523618	TMZ002	Umzimkhulu Final	pH OS*	7.50	-	-
27-Nov-25	2523618	TMZ002	Umzimkhulu Final	Temperature OS*	19.5	-	°C
27-Nov-25	2523622	TMZ002	Umzimkhulu Final	Turbidity	5.1	±6.1%	NTU
27-Nov-25	2522470	TSQ002	Esiqanduleni Final	Al (AE)	573	±7.6%	µg Al/L
27-Nov-25	2522465	TSQ002	Esiqanduleni Final	Cl ₂ (F) OS*	0.82	-	mg Cl ₂ /L
27-Nov-25	2522465	TSQ002	Esiqanduleni Final	Cl ₂ (T) OS*	0.94	-	mg Cl ₂ /L
27-Nov-25	2522466	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
27-Nov-25	2522465	TSQ002	Esiqanduleni Final	Coll Time OS*	06:36	-	-
27-Nov-25	2522468	TSQ002	Esiqanduleni Final	Conductivity	5.97	±1.5%	mS/m
27-Nov-25	2522466	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
27-Nov-25	2522466	TSQ002	Esiqanduleni Final	HPC 37*	1	±21%	CFU/mL
27-Nov-25	2522465	TSQ002	Esiqanduleni Final	pH OS*	7.40	-	-
27-Nov-25	2522465	TSQ002	Esiqanduleni Final	Temperature OS*	25.2	-	°C
27-Nov-25	2522469	TSQ002	Esiqanduleni Final	Turbidity	10.5	±6.1%	NTU
27-Nov-25	2523669	TWA002	Washbank Final	Al (AE)	986	±7.6%	µg Al/L
27-Nov-25	2523664	TWA002	Washbank Final	Cl ₂ (F) OS*	0.87	-	mg Cl ₂ /L
27-Nov-25	2523664	TWA002	Washbank Final	Cl ₂ (T) OS*	0.98	-	mg Cl ₂ /L
27-Nov-25	2523665	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
27-Nov-25	2523664	TWA002	Washbank Final	Coll Time OS*	06:30	-	-
27-Nov-25	2523667	TWA002	Washbank Final	Conductivity	12.3	±1.5%	mS/m
27-Nov-25	2523665	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
27-Nov-25	2523665	TWA002	Washbank Final	HPC 37*	0	±21%	CFU/mL
27-Nov-25	2523664	TWA002	Washbank Final	pH OS*	7.40	-	-
27-Nov-25	2523664	TWA002	Washbank Final	Temperature OS*	19.0	-	°C
27-Nov-25	2523668	TWA002	Washbank Final	Turbidity	4.2	±6.1%	NTU
28-Nov-25	2523916	TIB002	Ibisi Final	Al (AE)	6320	±7.6%	µg Al/L
28-Nov-25	2523911	TIB002	Ibisi Final	Cl ₂ (F) OS*	0.62	-	mg Cl ₂ /L
28-Nov-25	2523911	TIB002	Ibisi Final	Cl ₂ (T) OS*	0.70	-	mg Cl ₂ /L
28-Nov-25	2523912	TIB002	Ibisi Final	Coliforms*	>201	±15%	MPN/100mL
28-Nov-25	2523912	TIB002	Ibisi Final	Coliphages*	1	±8%	PFU/10mL
28-Nov-25	2523911	TIB002	Ibisi Final	Coll Time OS*	06:40	-	-
28-Nov-25	2523914	TIB002	Ibisi Final	Conductivity	8.87	±1.5%	mS/m
28-Nov-25	2523912	TIB002	Ibisi Final	E.coli*	21	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

28-Nov-25	2523912	TIB002	Ibisi Final	HPC 37*	275	±21%	CFU/mL
28-Nov-25	2523911	TIB002	Ibisi Final	pH OS*	7.30	-	-
28-Nov-25	2523911	TIB002	Ibisi Final	Temperature OS*	20.2	-	°C
28-Nov-25	2523915	TIB002	Ibisi Final	Turbidity	22.3	±6.1%	NTU
28-Nov-25	2523921	TRT002	Rietvlei Final	Cl ₂ (F) OS*	1.01	-	mg Cl ₂ /L
28-Nov-25	2523921	TRT002	Rietvlei Final	Cl ₂ (T) OS*	1.10	-	mg Cl ₂ /L
28-Nov-25	2523922	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
28-Nov-25	2523921	TRT002	Rietvlei Final	Coll Time OS*	07;28	-	-
28-Nov-25	2523924	TRT002	Rietvlei Final	Conductivity	19.0	±1.5%	mS/m
28-Nov-25	2523922	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
28-Nov-25	2523922	TRT002	Rietvlei Final	HPC 37*	8	±21%	CFU/mL
28-Nov-25	2523921	TRT002	Rietvlei Final	pH OS*	7.50	-	-
28-Nov-25	2523921	TRT002	Rietvlei Final	Temperature OS*	21.4	-	°C
28-Nov-25	2523925	TRT002	Rietvlei Final	Turbidity	1.1	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)