

Date: 05 November 2025

The Executive Director: Water Services Department

Harry Gwala District Municipality

40 Main Street

Ixopo

3276

Attention: Basetsana Khathalib and Bheki Nene

OCTOBER 2025 TREATED WATER (FINAL) RESULTS

Please find Treated Water (Final) results tabulated below for samples received during October 2025. Determinands marked with an asterix are unaccredited and are not included in uMngeni-uThukela Water's schedule of accreditation.

Please contact us immediately should you have any queries.

Yours' Sincerely



Mr M Sewcharran

Client Services Manager

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Sample Date	Sample Number	Sampling Point	Description	Determinand	Result	UOM	Unit
01-Oct-25	2484824	TBU002	Bulwer Final	Cl ₂ (F) OS*	0.99	-	mg Cl ₂ /L
01-Oct-25	2484824	TBU002	Bulwer Final	Cl ₂ (T) OS*	1.05	-	mg Cl ₂ /L
01-Oct-25	2484825	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
01-Oct-25	2484824	TBU002	Bulwer Final	Coll Time OS*	08:35	-	-
01-Oct-25	2484827	TBU002	Bulwer Final	Conductivity	5.38	±1.5%	mS/m
01-Oct-25	2484825	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
01-Oct-25	2484825	TBU002	Bulwer Final	HPC 37*	20	±21%	CFU/mL
01-Oct-25	2484824	TBU002	Bulwer Final	pH OS*	7.30	-	-
01-Oct-25	2484824	TBU002	Bulwer Final	Temperature OS*	18.5	-	°C
01-Oct-25	2484828	TBU002	Bulwer Final	Turbidity	13.1	±6.1%	NTU
01-Oct-25	2484839	TCR002	Creighton Final	Al (AE)	191	±7.6%	µg Al/L
01-Oct-25	2484834	TCR002	Creighton Final	Cl ₂ (F) OS*	1.39	-	mg Cl ₂ /L
01-Oct-25	2484834	TCR002	Creighton Final	Cl ₂ (T) OS*	1.48	-	mg Cl ₂ /L
01-Oct-25	2484835	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
01-Oct-25	2484834	TCR002	Creighton Final	Coll Time OS*	07:20	-	-
01-Oct-25	2484837	TCR002	Creighton Final	Conductivity	10.9	±1.5%	mS/m
01-Oct-25	2484835	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
01-Oct-25	2484835	TCR002	Creighton Final	HPC 37*	0	±21%	CFU/mL
01-Oct-25	2484834	TCR002	Creighton Final	pH OS*	7.30	-	-
01-Oct-25	2484834	TCR002	Creighton Final	Temperature OS*	12.4	-	°C
01-Oct-25	2484838	TCR002	Creighton Final	Turbidity	0.3	±6.1%	NTU
01-Oct-25	2484878	TRV002	Riverside Final	Cl ₂ (F) OS*	0.50	-	mg Cl ₂ /L
01-Oct-25	2484878	TRV002	Riverside Final	Cl ₂ (T) OS*	0.58	-	mg Cl ₂ /L
01-Oct-25	2484879	TRV002	Riverside Final	Coliforms*	>201	±15%	MPN/100mL
01-Oct-25	2484878	TRV002	Riverside Final	Coll Time OS*	08:00	-	-
01-Oct-25	2484881	TRV002	Riverside Final	Conductivity	8.11	±1.5%	mS/m
01-Oct-25	2484879	TRV002	Riverside Final	E.coli*	>201	±14%	MPN/100mL
01-Oct-25	2484883	TRV002	Riverside Final	Fe (AE)	0.41	±5.4%	mg Fe/L
01-Oct-25	2484879	TRV002	Riverside Final	HPC 37*	342	±21%	CFU/mL
01-Oct-25	2484878	TRV002	Riverside Final	pH OS*	7.30	-	-
01-Oct-25	2484878	TRV002	Riverside Final	Temperature OS*	10.5	-	°C
01-Oct-25	2484882	TRV002	Riverside Final	Turbidity	11.5	±6.1%	NTU
01-Oct-25	2484889	TST002	St Appollinaris Final	Cl ₂ (F) OS*	0.48	-	mg Cl ₂ /L
01-Oct-25	2484889	TST002	St Appollinaris Final	Cl ₂ (T) OS*	0.54	-	mg Cl ₂ /L
01-Oct-25	2484890	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
01-Oct-25	2484889	TST002	St Appollinaris Final	Coll Time OS*	09:16	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

01-Oct-25	2484892	TST002	St Appollinaris Final	Conductivity	11.9	±1.5%	mS/m
01-Oct-25	2484890	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
01-Oct-25	2484890	TST002	St Appollinaris Final	HPC 37*	0	±21%	CFU/mL
01-Oct-25	2484889	TST002	St Appollinaris Final	pH OS*	7.40	-	-
01-Oct-25	2484889	TST002	St Appollinaris Final	Temperature OS*	18.7	-	°C
01-Oct-25	2484893	TST002	St Appollinaris Final	Turbidity	8.4	±6.1%	NTU
01-Oct-25	2484908	TUN002	Underberg Final	Al (AE)	151	±7.6%	µg Al/L
01-Oct-25	2484903	TUN002	Underberg Final	Cl ₂ (F) OS*	0.80	-	mg Cl ₂ /L
01-Oct-25	2484903	TUN002	Underberg Final	Cl ₂ (T) OS*	0.91	-	mg Cl ₂ /L
01-Oct-25	2484904	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
01-Oct-25	2484903	TUN002	Underberg Final	Coll Time OS*	07:50	-	-
01-Oct-25	2484906	TUN002	Underberg Final	Conductivity	5.76	±1.5%	mS/m
01-Oct-25	2484904	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
01-Oct-25	2484904	TUN002	Underberg Final	HPC 37*	14	±21%	CFU/mL
01-Oct-25	2484903	TUN002	Underberg Final	pH OS*	7.40	-	-
01-Oct-25	2484903	TUN002	Underberg Final	Temperature OS*	18.7	-	°C
01-Oct-25	2484907	TUN002	Underberg Final	Turbidity	1.8	±6.1%	NTU
02-Oct-25	2485456	TMZ002	Umzimkhulu Final	Al (AE)	299	±7.6%	µg Al/L
02-Oct-25	2485451	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	1.53	-	mg Cl ₂ /L
02-Oct-25	2485451	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	1.66	-	mg Cl ₂ /L
02-Oct-25	2485452	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
02-Oct-25	2485452	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10mL
02-Oct-25	2485451	TMZ002	Umzimkhulu Final	Coll Time OS*	07:50	-	-
02-Oct-25	2485455	TMZ002	Umzimkhulu Final	Colour	<1.00	±6.5%	mg Pt-Co/L
02-Oct-25	2485454	TMZ002	Umzimkhulu Final	Conductivity	13.4	±1.5%	mS/m
02-Oct-25	2485452	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
02-Oct-25	2485452	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	CFU/mL
02-Oct-25	2485455	TMZ002	Umzimkhulu Final	Odour*	Nil	-	-
02-Oct-25	2485451	TMZ002	Umzimkhulu Final	pH OS*	7.40	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,

Telephone (033) 341 1111

E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

02-Oct-25	2485451	TMZ002	Umzimkhulu Final	Temperature OS*	16.9	-	°C
02-Oct-25	2485455	TMZ002	Umzimkhulu Final	Turbidity	3.9	±6.1%	NTU
02-Oct-25	2485502	TWA002	Washbank Final	Al (AE)	568	±7.6%	µg Al/L
02-Oct-25	2485497	TWA002	Washbank Final	Cl ₂ (F) OS*	0.26	-	mg Cl ₂ /L
02-Oct-25	2485497	TWA002	Washbank Final	Cl ₂ (T) OS*	0.56	-	mg Cl ₂ /L
02-Oct-25	2485498	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
02-Oct-25	2485497	TWA002	Washbank Final	Coll Time OS*	07:10	-	-
02-Oct-25	2485500	TWA002	Washbank Final	Conductivity	8.55	±1.5%	mS/m
02-Oct-25	2485498	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
02-Oct-25	2485498	TWA002	Washbank Final	HPC 37*	3	±21%	CFU/mL
02-Oct-25	2485497	TWA002	Washbank Final	pH OS*	7.50	-	-
02-Oct-25	2485497	TWA002	Washbank Final	Temperature OS*	16.3	-	°C
02-Oct-25	2485501	TWA002	Washbank Final	Turbidity	9.9	±6.1%	NTU
03-Oct-25	2485749	TIB002	Ibisi Final	Al (AE)	366	±7.6%	µg Al/L
03-Oct-25	2485744	TIB002	Ibisi Final	Cl ₂ (F) OS*	1.04	-	mg Cl ₂ /L
03-Oct-25	2485744	TIB002	Ibisi Final	Cl ₂ (T) OS*	1.11	-	mg Cl ₂ /L
03-Oct-25	2485745	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
03-Oct-25	2485745	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10mL
03-Oct-25	2485744	TIB002	Ibisi Final	Coll Time OS*	07:01	-	-
03-Oct-25	2485747	TIB002	Ibisi Final	Conductivity	12.1	±1.5%	mS/m
03-Oct-25	2485745	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
03-Oct-25	2485749	TIB002	Ibisi Final	Fe (AE)	0.43	±5.4%	mg Fe/L
03-Oct-25	2485745	TIB002	Ibisi Final	HPC 37*	19	±21%	CFU/mL
03-Oct-25	2485744	TIB002	Ibisi Final	pH OS*	7.30	-	-
03-Oct-25	2485744	TIB002	Ibisi Final	Temperature OS*	19.5	-	°C
03-Oct-25	2485748	TIB002	Ibisi Final	Turbidity	7.3	±6.1%	NTU
03-Oct-25	2485754	TRT002	Rietvlei Final	Cl ₂ (F) OS*	0.99	-	mg Cl ₂ /L
03-Oct-25	2485754	TRT002	Rietvlei Final	Cl ₂ (T) OS*	1.09	-	mg Cl ₂ /L
03-Oct-25	2485755	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
03-Oct-25	2485754	TRT002	Rietvlei Final	Coll Time OS*	07:30	-	-
03-Oct-25	2485757	TRT002	Rietvlei Final	Conductivity	19.0	±1.5%	mS/m
03-Oct-25	2485755	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
03-Oct-25	2485755	TRT002	Rietvlei Final	HPC 37*	7	±21%	CFU/mL
03-Oct-25	2485754	TRT002	Rietvlei Final	pH OS*	7.40	-	-
03-Oct-25	2485754	TRT002	Rietvlei Final	Temperature OS*	17.3	-	°C
03-Oct-25	2485758	TRT002	Rietvlei Final	Turbidity	1.4	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,

Telephone (033) 341 1111

E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

06-Oct-25	2489911	TFR002	Franklin Final	Al (AE)	232	±7.6%	µg Al/L
06-Oct-25	2489906	TFR002	Franklin Final	Cl ₂ (F) OS*	1.26	-	mg Cl ₂ /L
06-Oct-25	2489906	TFR002	Franklin Final	Cl ₂ (T) OS*	1.34	-	mg Cl ₂ /L
06-Oct-25	2489907	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
06-Oct-25	2489907	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10mL
06-Oct-25	2489906	TFR002	Franklin Final	Coll Time OS*	08:18	-	-
06-Oct-25	2489910	TFR002	Franklin Final	Colour	<1.00	±6.5%	mg Pt-Co/L
06-Oct-25	2489909	TFR002	Franklin Final	Conductivity	14.2	±1.5%	mS/m
06-Oct-25	2489907	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
06-Oct-25	2489911	TFR002	Franklin Final	Fe (AE)	0.08	±5.4%	mg Fe/L
06-Oct-25	2489907	TFR002	Franklin Final	HPC 37*	0	±21%	CFU/mL
06-Oct-25	2489911	TFR002	Franklin Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
06-Oct-25	2489906	TFR002	Franklin Final	pH OS*	7.60	-	-
06-Oct-25	2489906	TFR002	Franklin Final	Temperature OS*	15.3	-	°C
06-Oct-25	2489910	TFR002	Franklin Final	Turbidity	1.5	±6.1%	NTU
06-Oct-25	2489912	TFR003	Franklin Police Station Retic	Cl ₂ (F) OS*	1.24	-	mg Cl ₂ /L
06-Oct-25	2489912	TFR003	Franklin Police Station Retic	Cl ₂ (T) OS*	1.36	-	mg Cl ₂ /L
06-Oct-25	2489913	TFR003	Franklin Police Station Retic	Coliforms*	0	±15%	MPN/100mL
06-Oct-25	2489912	TFR003	Franklin Police Station Retic	Coll Time OS*	08:50	-	-
06-Oct-25	2489913	TFR003	Franklin Police Station Retic	E.coli*	0	±14%	MPN/100mL
06-Oct-25	2489913	TFR003	Franklin Police Station Retic	HPC 37*	0	±21%	CFU/mL
06-Oct-25	2489912	TFR003	Franklin Police Station Retic	pH OS*	7.40	-	-
06-Oct-25	2489912	TFR003	Franklin Police Station Retic	Temperature OS*	15.5	-	°C
06-Oct-25	2489915	TFR003	Franklin Police Station Retic	Turbidity	1.1	±6.1%	NTU
06-Oct-25	2489926	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
06-Oct-25	2489921	TKK002	Kokstad Final	Cl ₂ (F) OS*	2.22	-	mg Cl ₂ /L
06-Oct-25	2489921	TKK002	Kokstad Final	Cl ₂ (T) OS*	2.30	-	mg Cl ₂ /L
06-Oct-25	2489922	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
06-Oct-25	2489922	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10mL
06-Oct-25	2489921	TKK002	Kokstad Final	Coll Time OS*	08:44	-	-
06-Oct-25	2489925	TKK002	Kokstad Final	Colour	<1.00	±6.5%	mg Pt-Co/L
06-Oct-25	2489924	TKK002	Kokstad Final	Conductivity	18.1	±1.5%	mS/m
06-Oct-25	2489922	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
06-Oct-25	2489922	TKK002	Kokstad Final	HPC 37*	0	±21%	CFU/mL
06-Oct-25	2489925	TKK002	Kokstad Final	Odour*	Nil	-	-
06-Oct-25	2489921	TKK002	Kokstad Final	pH OS*	7.30	-	-
06-Oct-25	2489925	TKK002	Kokstad Final	Taste*	Nil	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111

E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

06-Oct-25	2489921	TKK002	Kokstad Final	Temperature OS*	18.4	-	°C
06-Oct-25	2489925	TKK002	Kokstad Final	Turbidity	0.3	±6.1%	NTU
06-Oct-25	2489936	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl ₂ (F) OS*	1.09	-	mg Cl ₂ /L
06-Oct-25	2489936	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl ₂ (T) OS*	1.20	-	mg Cl ₂ /L
06-Oct-25	2489937	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliforms*	0	±15%	MPN/100mL
06-Oct-25	2489936	TKK006	Kokstad Bongweni Correctional Serv Retic	Coll Time OS*	08:30	-	-
06-Oct-25	2489937	TKK006	Kokstad Bongweni Correctional Serv Retic	E.coli*	0	±14%	MPN/100mL
06-Oct-25	2489937	TKK006	Kokstad Bongweni Correctional Serv Retic	HPC 37*	0	±21%	CFU/mL
06-Oct-25	2489936	TKK006	Kokstad Bongweni Correctional Serv Retic	pH OS*	7.30	-	-
06-Oct-25	2489936	TKK006	Kokstad Bongweni Correctional Serv Retic	Temperature OS*	18.0	-	°C
06-Oct-25	2489939	TKK006	Kokstad Bongweni Correctional Serv Retic	Turbidity	0.3	±6.1%	NTU
06-Oct-25	2489940	TKK007	Kokstad Shayamoya Reticulation	Cl ₂ (F) OS*	0.74	-	mg Cl ₂ /L
06-Oct-25	2489940	TKK007	Kokstad Shayamoya Reticulation	Cl ₂ (T) OS*	0.80	-	mg Cl ₂ /L
06-Oct-25	2489941	TKK007	Kokstad Shayamoya Reticulation	Coliforms*	0	±15%	MPN/100mL
06-Oct-25	2489940	TKK007	Kokstad Shayamoya Reticulation	Coll Time OS*	08:15	-	-
06-Oct-25	2489943	TKK007	Kokstad Shayamoya Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

06-Oct-25	2489941	TKK007	Kokstad Shayamoya Reticulation	E.coli*	0	±14%	MPN/100mL
06-Oct-25	2489941	TKK007	Kokstad Shayamoya Reticulation	HPC 37*	0	±21%	CFU/mL
06-Oct-25	2489943	TKK007	Kokstad Shayamoya Reticulation	Odour*	Nil	-	-
06-Oct-25	2489940	TKK007	Kokstad Shayamoya Reticulation	pH OS*	7.20	-	-
06-Oct-25	2489940	TKK007	Kokstad Shayamoya Reticulation	Temperature OS*	11.2	-	°C
06-Oct-25	2489943	TKK007	Kokstad Shayamoya Reticulation	Turbidity	0.8	±6.1%	NTU
06-Oct-25	2489944	TKK009	Kokstad Farm Fresh Produce Market	Cl ₂ (F) OS*	0.38	-	mg Cl ₂ /L
06-Oct-25	2489944	TKK009	Kokstad Farm Fresh Produce Market	Cl ₂ (T) OS*	0.46	-	mg Cl ₂ /L
06-Oct-25	2489945	TKK009	Kokstad Farm Fresh Produce Market	Coliforms*	0	±15%	MPN/100mL
06-Oct-25	2489944	TKK009	Kokstad Farm Fresh Produce Market	Coll Time OS*	09:30	-	-
06-Oct-25	2489947	TKK009	Kokstad Farm Fresh Produce Market	Colour	<1.00	±6.5%	mg Pt-Co/L
06-Oct-25	2489945	TKK009	Kokstad Farm Fresh Produce Market	E.coli*	0	±14%	MPN/100mL
06-Oct-25	2489945	TKK009	Kokstad Farm Fresh Produce Market	HPC 37*	0	±21%	CFU/mL
06-Oct-25	2489947	TKK009	Kokstad Farm Fresh Produce Market	Odour*	Nil	-	-
06-Oct-25	2489944	TKK009	Kokstad Farm Fresh Produce Market	pH OS*	7.40	-	-
06-Oct-25	2489947	TKK009	Kokstad Farm Fresh Produce Market	Taste*	Nil	-	-
06-Oct-25	2489944	TKK009	Kokstad Farm Fresh Produce Market	Temperature OS*	20.2	-	°C
06-Oct-25	2489947	TKK009	Kokstad Farm Fresh Produce Market	Turbidity	0.2	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

06-Oct-25	2489948	TKK012	Kokstad FET College Reticulation	Cl ₂ (F) OS*	0.64	-	mg Cl ₂ /L
06-Oct-25	2489948	TKK012	Kokstad FET College Reticulation	Cl ₂ (T) OS*	0.74	-	mg Cl ₂ /L
06-Oct-25	2489949	TKK012	Kokstad FET College Reticulation	Coliforms*	0	±15%	MPN/100mL
06-Oct-25	2489948	TKK012	Kokstad FET College Reticulation	Coll Time OS*	09:18	-	-
06-Oct-25	2489949	TKK012	Kokstad FET College Reticulation	E.coli*	0	±14%	MPN/100mL
06-Oct-25	2489949	TKK012	Kokstad FET College Reticulation	HPC 37*	0	±21%	CFU/mL
06-Oct-25	2489948	TKK012	Kokstad FET College Reticulation	pH OS*	7.40	-	-
06-Oct-25	2489948	TKK012	Kokstad FET College Reticulation	Temperature OS*	19.4	-	°C
06-Oct-25	2489951	TKK012	Kokstad FET College Reticulation	Turbidity	0.4	±6.1%	NTU
06-Oct-25	2489974	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	0.80	-	mg Cl ₂ /L
06-Oct-25	2489974	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	0.96	-	mg Cl ₂ /L
06-Oct-25	2489975	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
06-Oct-25	2489974	TNJU002	KwaNjunga Final	Coll Time OS*	07:25	-	-
06-Oct-25	2489975	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
06-Oct-25	2489975	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	CFU/mL
06-Oct-25	2489974	TNJU002	KwaNjunga Final	pH OS*	7.40	-	-
06-Oct-25	2489974	TNJU002	KwaNjunga Final	Temperature OS*	15.2	-	°C
06-Oct-25	2489978	TNJU002	KwaNjunga Final	Turbidity	0.4	±6.1%	NTU
06-Oct-25	2489979	TNJU003	KwaNjunga Reticulation	Cl ₂ (F) OS*	0.12	-	mg Cl ₂ /L
06-Oct-25	2489979	TNJU003	KwaNjunga Reticulation	Cl ₂ (T) OS*	0.18	-	mg Cl ₂ /L
06-Oct-25	2489980	TNJU003	KwaNjunga Reticulation	Coliforms*	8	±15%	MPN/100mL
06-Oct-25	2489979	TNJU003	KwaNjunga Reticulation	Coll Time OS*	07:15	-	-
06-Oct-25	2489980	TNJU003	KwaNjunga Reticulation	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

06-Oct-25	2489980	TNJU003	KwaNjunga Reticulation	HPC 37*	0	±21%	CFU/mL
06-Oct-25	2489979	TNJU003	KwaNjunga Reticulation	pH OS*	7.40	-	-
06-Oct-25	2489979	TNJU003	KwaNjunga Reticulation	Temperature OS*	15.0	-	°C
06-Oct-25	2489982	TNJU003	KwaNjunga Reticulation	Turbidity	0.5	±6.1%	NTU
07-Oct-25	2490554	TQU002	Mnqumeni Final	Cl ₂ (F) OS*	0.20	-	mg Cl ₂ /L
07-Oct-25	2490554	TQU002	Mnqumeni Final	Cl ₂ (T) OS*	0.25	-	mg Cl ₂ /L
07-Oct-25	2490555	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
07-Oct-25	2490554	TQU002	Mnqumeni Final	Coll Time OS*	06:20	-	-
07-Oct-25	2490557	TQU002	Mnqumeni Final	Conductivity	15.6	±1.5%	mS/m
07-Oct-25	2490555	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
07-Oct-25	2490555	TQU002	Mnqumeni Final	HPC 37*	0	±21%	CFU/mL
07-Oct-25	2490554	TQU002	Mnqumeni Final	pH OS*	7.60	-	-
07-Oct-25	2490554	TQU002	Mnqumeni Final	Temperature OS*	18.3	-	°C
07-Oct-25	2490558	TQU002	Mnqumeni Final	Turbidity	0.9	±6.1%	NTU
07-Oct-25	2490559	TQU003	Mnqumeni Reticulation	Cl ₂ (F) OS*	0.18	-	mg Cl ₂ /L
07-Oct-25	2490559	TQU003	Mnqumeni Reticulation	Cl ₂ (T) OS*	0.24	-	mg Cl ₂ /L
07-Oct-25	2490560	TQU003	Mnqumeni Reticulation	Coliforms*	0	±15%	MPN/100mL
07-Oct-25	2490559	TQU003	Mnqumeni Reticulation	Coll Time OS*	06:24	-	-
07-Oct-25	2490563	TQU003	Mnqumeni Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
07-Oct-25	2490562	TQU003	Mnqumeni Reticulation	Conductivity	15.4	±1.5%	mS/m
07-Oct-25	2490560	TQU003	Mnqumeni Reticulation	E.coli*	0	±14%	MPN/100mL
07-Oct-25	2490560	TQU003	Mnqumeni Reticulation	HPC 37*	1	±21%	CFU/mL
07-Oct-25	2490563	TQU003	Mnqumeni Reticulation	Odour*	Nil	-	-
07-Oct-25	2490559	TQU003	Mnqumeni Reticulation	pH OS*	7.40	-	-
07-Oct-25	2490559	TQU003	Mnqumeni Reticulation	Temperature OS*	17.8	-	°C
07-Oct-25	2490563	TQU003	Mnqumeni Reticulation	Turbidity	1.4	±6.1%	NTU
07-Oct-25	2490574	TSQ002	Esiqanduleni Final	Al (AE)	277	±7.6%	µg Al/L
07-Oct-25	2490569	TSQ002	Esiqanduleni Final	Cl ₂ (F) OS*	1.26	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

07-Oct-25	2490569	TSQ002	Esiqanduleni Final	Cl ₂ (T) OS*	1.30	-	mg Cl ₂ /L
07-Oct-25	2490570	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
07-Oct-25	2490569	TSQ002	Esiqanduleni Final	Coll Time OS*	07:47	-	-
07-Oct-25	2490573	TSQ002	Esiqanduleni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
07-Oct-25	2490572	TSQ002	Esiqanduleni Final	Conductivity	16.2	±1.5%	mS/m
07-Oct-25	2490570	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
07-Oct-25	2490570	TSQ002	Esiqanduleni Final	HPC 37*	13	±21%	CFU/mL
07-Oct-25	2490573	TSQ002	Esiqanduleni Final	Odour*	Nil	-	-
07-Oct-25	2490569	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
07-Oct-25	2490569	TSQ002	Esiqanduleni Final	Temperature OS*	18.2	-	°C
07-Oct-25	2490573	TSQ002	Esiqanduleni Final	Turbidity	5.0	±6.1%	NTU
07-Oct-25	2490575	TSQ003	Esiqanduleni Reticulation	Cl ₂ (F) OS*	0.76	-	mg Cl ₂ /L
07-Oct-25	2490575	TSQ003	Esiqanduleni Reticulation	Cl ₂ (T) OS*	0.80	-	mg Cl ₂ /L
07-Oct-25	2490576	TSQ003	Esiqanduleni Reticulation	Coliforms*	0	±15%	MPN/100mL
07-Oct-25	2490575	TSQ003	Esiqanduleni Reticulation	Coll Time OS*	07:20	-	-
07-Oct-25	2490576	TSQ003	Esiqanduleni Reticulation	E.coli*	0	±14%	MPN/100mL
07-Oct-25	2490576	TSQ003	Esiqanduleni Reticulation	HPC 37*	0	±21%	CFU/mL
07-Oct-25	2490575	TSQ003	Esiqanduleni Reticulation	pH OS*	7.50	-	-
07-Oct-25	2490575	TSQ003	Esiqanduleni Reticulation	Temperature OS*	17.3	-	°C
07-Oct-25	2490578	TSQ003	Esiqanduleni Reticulation	Turbidity	14.0	±6.1%	NTU
08-Oct-25	2491291	TBU002	Bulwer Final	Cl ₂ (F) OS*	1.16	-	mg Cl ₂ /L
08-Oct-25	2491291	TBU002	Bulwer Final	Cl ₂ (T) OS*	1.24	-	mg Cl ₂ /L
08-Oct-25	2491292	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
08-Oct-25	2491291	TBU002	Bulwer Final	Coll Time OS*	09:05	-	-
08-Oct-25	2491295	TBU002	Bulwer Final	Colour	<1.00	±6.5%	mg Pt-Co/L
08-Oct-25	2491294	TBU002	Bulwer Final	Conductivity	5.89	±1.5%	mS/m
08-Oct-25	2491292	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
08-Oct-25	2491292	TBU002	Bulwer Final	HPC 37*	6	±21%	CFU/mL
08-Oct-25	2491295	TBU002	Bulwer Final	Odour*	Nil	-	-
08-Oct-25	2491291	TBU002	Bulwer Final	pH OS*	7.30	-	-
08-Oct-25	2491291	TBU002	Bulwer Final	Temperature OS*	20.2	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

08-Oct-25	2491295	TBU002	Bulwer Final	Turbidity	5.7	±6.1%	NTU
08-Oct-25	2491296	TBU005	Bulwer Mountain Park Hotel Retic	Cl ₂ (F) OS*	0.76	-	mg Cl ₂ /L
08-Oct-25	2491296	TBU005	Bulwer Mountain Park Hotel Retic	Cl ₂ (T) OS*	0.87	-	mg Cl ₂ /L
08-Oct-25	2491297	TBU005	Bulwer Mountain Park Hotel Retic	Coliforms*	>201	±15%	MPN/100mL
08-Oct-25	2491296	TBU005	Bulwer Mountain Park Hotel Retic	Coll Time OS*	09:20	-	-
08-Oct-25	2491300	TBU005	Bulwer Mountain Park Hotel Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
08-Oct-25	2491299	TBU005	Bulwer Mountain Park Hotel Retic	Conductivity	5.90	±1.5%	mS/m
08-Oct-25	2491297	TBU005	Bulwer Mountain Park Hotel Retic	E.coli*	3	±14%	MPN/100mL
08-Oct-25	2491297	TBU005	Bulwer Mountain Park Hotel Retic	HPC 37*	39	±21%	CFU/mL
08-Oct-25	2491296	TBU005	Bulwer Mountain Park Hotel Retic	pH OS*	7.60	-	-
08-Oct-25	2491296	TBU005	Bulwer Mountain Park Hotel Retic	Temperature OS*	19.3	-	°C
08-Oct-25	2491300	TBU005	Bulwer Mountain Park Hotel Retic	Turbidity	10.1	±6.1%	NTU
08-Oct-25	2491311	TCR002	Creighton Final	Al (AE)	152	±7.6%	µg Al/L
08-Oct-25	2491306	TCR002	Creighton Final	Cl ₂ (F) OS*	1.37	-	mg Cl ₂ /L
08-Oct-25	2491306	TCR002	Creighton Final	Cl ₂ (T) OS*	1.46	-	mg Cl ₂ /L
08-Oct-25	2491307	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
08-Oct-25	2491306	TCR002	Creighton Final	Coll Time OS*	07:31	-	-
08-Oct-25	2491309	TCR002	Creighton Final	Conductivity	11.4	±1.5%	mS/m
08-Oct-25	2491307	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
08-Oct-25	2491307	TCR002	Creighton Final	HPC 37*	0	±21%	CFU/mL
08-Oct-25	2491306	TCR002	Creighton Final	pH OS*	7.30	-	-
08-Oct-25	2491306	TCR002	Creighton Final	Temperature OS*	16.3	-	°C
08-Oct-25	2491310	TCR002	Creighton Final	Turbidity	0.4	±6.1%	NTU
08-Oct-25	2491312	TCR004	Creighton Madondo Cottages	Cl ₂ (F) OS*	0.82	-	mg Cl ₂ /L
08-Oct-25	2491312	TCR004	Creighton Madondo Cottages	Cl ₂ (T) OS*	0.90	-	mg Cl ₂ /L
08-Oct-25	2491313	TCR004	Creighton Madondo Cottages	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

08-Oct-25	2491312	TCR004	Creighton Madondo Cottages	Coll Time OS*	07:00	-	-
08-Oct-25	2491313	TCR004	Creighton Madondo Cottages	E.coli*	0	±14%	MPN/100mL
08-Oct-25	2491313	TCR004	Creighton Madondo Cottages	HPC 37*	1	±21%	CFU/mL
08-Oct-25	2491312	TCR004	Creighton Madondo Cottages	pH OS*	7.20	-	-
08-Oct-25	2491312	TCR004	Creighton Madondo Cottages	Temperature OS*	14.1	-	°C
08-Oct-25	2491315	TCR004	Creighton Madondo Cottages	Turbidity	0.8	±6.1%	NTU
08-Oct-25	2491330	THL003	Hlanganani Clinic Reticulation	Cl ₂ (F) OS*	0.54	-	mg Cl ₂ /L
08-Oct-25	2491330	THL003	Hlanganani Clinic Reticulation	Cl ₂ (T) OS*	0.60	-	mg Cl ₂ /L
08-Oct-25	2491331	THL003	Hlanganani Clinic Reticulation	Coliforms*	0	±15%	MPN/100mL
08-Oct-25	2491330	THL003	Hlanganani Clinic Reticulation	Coll Time OS*	10:15	-	-
08-Oct-25	2491334	THL003	Hlanganani Clinic Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
08-Oct-25	2491333	THL003	Hlanganani Clinic Reticulation	Conductivity	11.5	±1.5%	mS/m
08-Oct-25	2491331	THL003	Hlanganani Clinic Reticulation	E.coli*	0	±14%	MPN/100mL
08-Oct-25	2491331	THL003	Hlanganani Clinic Reticulation	HPC 37*	0	±21%	CFU/mL
08-Oct-25	2491330	THL003	Hlanganani Clinic Reticulation	pH OS*	7.30	-	-
08-Oct-25	2491330	THL003	Hlanganani Clinic Reticulation	Temperature OS*	20.1	-	°C
08-Oct-25	2491334	THL003	Hlanganani Clinic Reticulation	Turbidity	0.8	±6.1%	NTU
08-Oct-25	2491377	TRV002	Riverside Final	Cl ₂ (F) OS*	2.20	-	mg Cl ₂ /L
08-Oct-25	2491377	TRV002	Riverside Final	Cl ₂ (T) OS*	2.30	-	mg Cl ₂ /L
08-Oct-25	2491378	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
08-Oct-25	2491377	TRV002	Riverside Final	Coll Time OS*	08:02	-	-
08-Oct-25	2491381	TRV002	Riverside Final	Colour	<1.00	±6.5%	mg Pt-Co/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

08-Oct-25	2491380	TRV002	Riverside Final	Conductivity	8.47	±1.5%	mS/m
08-Oct-25	2491378	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
08-Oct-25	2491378	TRV002	Riverside Final	HPC 37*	0	±21%	CFU/mL
08-Oct-25	2491381	TRV002	Riverside Final	Odour*	Nil	-	-
08-Oct-25	2491377	TRV002	Riverside Final	pH OS*	7.40	-	-
08-Oct-25	2491377	TRV002	Riverside Final	Temperature OS*	19.3	-	°C
08-Oct-25	2491381	TRV002	Riverside Final	Turbidity	1.8	±6.1%	NTU
08-Oct-25	2491382	TRV003	Riverside Reticulation	Cl2 (F) OS*	1.07	-	mg Cl2/L
08-Oct-25	2491382	TRV003	Riverside Reticulation	Cl2 (T) OS*	1.14	-	mg Cl2/L
08-Oct-25	2491383	TRV003	Riverside Reticulation	Coliforms*	0	±15%	MPN/100mL
08-Oct-25	2491382	TRV003	Riverside Reticulation	Coll Time OS*	08:07	-	-
08-Oct-25	2491385	TRV003	Riverside Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
08-Oct-25	2491383	TRV003	Riverside Reticulation	E.coli*	0	±14%	MPN/100mL
08-Oct-25	2491383	TRV003	Riverside Reticulation	HPC 37*	0	±21%	CFU/mL
08-Oct-25	2491385	TRV003	Riverside Reticulation	Odour*	Nil	-	-
08-Oct-25	2491382	TRV003	Riverside Reticulation	pH OS*	7.30	-	-
08-Oct-25	2491382	TRV003	Riverside Reticulation	Temperature OS*	18.7	-	°C
08-Oct-25	2491385	TRV003	Riverside Reticulation	Turbidity	1.9	±6.1%	NTU
08-Oct-25	2491391	TST002	St Appollinaris Final	Cl2 (F) OS*	1.17	-	mg Cl2/L
08-Oct-25	2491391	TST002	St Appollinaris Final	Cl2 (T) OS*	1.29	-	mg Cl2/L
08-Oct-25	2491392	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
08-Oct-25	2491391	TST002	St Appollinaris Final	Coll Time OS*	08:31	-	-
08-Oct-25	2491395	TST002	St Appollinaris Final	Colour	2.10	±6.5%	mg Pt-Co/L
08-Oct-25	2491394	TST002	St Appollinaris Final	Conductivity	7.45	±1.5%	mS/m
08-Oct-25	2491392	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
08-Oct-25	2491392	TST002	St Appollinaris Final	HPC 37*	1	±21%	CFU/mL
08-Oct-25	2491395	TST002	St Appollinaris Final	Odour*	Nil	-	-
08-Oct-25	2491391	TST002	St Appollinaris Final	pH OS*	7.30	-	-
08-Oct-25	2491391	TST002	St Appollinaris Final	Temperature OS*	19.6	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

08-Oct-25	2491395	TST002	St Appollinaris Final	Turbidity	5.8	±6.1%	NTU
08-Oct-25	2491406	TUN002	Underberg Final	Al (AE)	83.6	±7.6%	µg Al/L
08-Oct-25	2491401	TUN002	Underberg Final	Cl ₂ (F) OS*	0.77	-	mg Cl ₂ /L
08-Oct-25	2491401	TUN002	Underberg Final	Cl ₂ (T) OS*	0.98	-	mg Cl ₂ /L
08-Oct-25	2491402	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
08-Oct-25	2491401	TUN002	Underberg Final	Coll Time OS*	09:25	-	-
08-Oct-25	2491405	TUN002	Underberg Final	Colour	<1.00	±6.5%	mg Pt-Co/L
08-Oct-25	2491404	TUN002	Underberg Final	Conductivity	5.36	±1.5%	mS/m
08-Oct-25	2491402	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
08-Oct-25	2491402	TUN002	Underberg Final	HPC 37*	0	±21%	CFU/mL
08-Oct-25	2491405	TUN002	Underberg Final	Odour*	Nil	-	-
08-Oct-25	2491401	TUN002	Underberg Final	pH OS*	7.40	-	-
08-Oct-25	2491401	TUN002	Underberg Final	Temperature OS*	18.5	-	°C
08-Oct-25	2491405	TUN002	Underberg Final	Turbidity	0.7	±6.1%	NTU
09-Oct-25	2492086	TMZ002	Umzimkhulu Final	Al (AE)	189	±7.6%	µg Al/L
09-Oct-25	2492081	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	1.92	-	mg Cl ₂ /L
09-Oct-25	2492081	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	2.01	-	mg Cl ₂ /L
09-Oct-25	2492082	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
09-Oct-25	2492082	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10mL
09-Oct-25	2492081	TMZ002	Umzimkhulu Final	Coll Time OS*	07:12	-	-
09-Oct-25	2492084	TMZ002	Umzimkhulu Final	Conductivity	11.0	±1.5%	mS/m
09-Oct-25	2492082	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
09-Oct-25	2492086	TMZ002	Umzimkhulu Final	Fe (AE)	0.11	±5.4%	mg Fe/L
09-Oct-25	2492082	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	CFU/mL
09-Oct-25	2492081	TMZ002	Umzimkhulu Final	pH OS*	7.50	-	-
09-Oct-25	2492081	TMZ002	Umzimkhulu Final	Temperature OS*	18.5	-	°C
09-Oct-25	2492085	TMZ002	Umzimkhulu Final	Turbidity	2.2	±6.1%	NTU
09-Oct-25	2492087	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (F) OS*	1.80	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

09-Oct-25	2492087	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (T) OS*	1.95	-	mg Cl ₂ /L
09-Oct-25	2492088	TMZ004	Umzikhulu Informal Settlement Retic	Coliforms*	3	±15%	MPN/100mL
09-Oct-25	2492087	TMZ004	Umzikhulu Informal Settlement Retic	Coll Time OS*	08:06	-	-
09-Oct-25	2492088	TMZ004	Umzikhulu Informal Settlement Retic	E.coli*	1	±14%	MPN/100mL
09-Oct-25	2492088	TMZ004	Umzikhulu Informal Settlement Retic	HPC 37*	0	±21%	CFU/mL
09-Oct-25	2492087	TMZ004	Umzikhulu Informal Settlement Retic	pH OS*	7.40	-	-
09-Oct-25	2492087	TMZ004	Umzikhulu Informal Settlement Retic	Temperature OS*	17.8	-	°C
09-Oct-25	2492090	TMZ004	Umzikhulu Informal Settlement Retic	Turbidity	1.9	±6.1%	NTU
09-Oct-25	2492091	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (F) OS*	2.02	-	mg Cl ₂ /L
09-Oct-25	2492091	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (T) OS*	2.12	-	mg Cl ₂ /L
09-Oct-25	2492092	TMZ005	Umzimkhulu Local Municipality Offices	Coliforms*	0	±15%	MPN/100mL
09-Oct-25	2492091	TMZ005	Umzimkhulu Local Municipality Offices	Coll Time OS*	7:45	-	-
09-Oct-25	2492092	TMZ005	Umzimkhulu Local Municipality Offices	E.coli*	0	±14%	MPN/100mL
09-Oct-25	2492092	TMZ005	Umzimkhulu Local Municipality Offices	HPC 37*	0	±21%	CFU/mL
09-Oct-25	2492091	TMZ005	Umzimkhulu Local Municipality Offices	pH OS*	7.20	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

09-Oct-25	2492091	TMZ005	Umzimkhulu Local Municipality Offices	Temperature OS*	17.9	-	°C
09-Oct-25	2492094	TMZ005	Umzimkhulu Local Municipality Offices	Turbidity	3.1	±6.1%	NTU
09-Oct-25	2492114	TNO002	Nokweja Final	Al (AE)	293	±7.6%	µg Al/L
09-Oct-25	2492109	TNO002	Nokweja Final	Cl ₂ (F) OS*	1.28	-	mg Cl ₂ /L
09-Oct-25	2492109	TNO002	Nokweja Final	Cl ₂ (T) OS*	1.38	-	mg Cl ₂ /L
09-Oct-25	2492110	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
09-Oct-25	2492110	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10mL
09-Oct-25	2492109	TNO002	Nokweja Final	Coll Time OS*	08:25	-	-
09-Oct-25	2492113	TNO002	Nokweja Final	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Oct-25	2492112	TNO002	Nokweja Final	Conductivity	10.1	±1.5%	mS/m
09-Oct-25	2492110	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
09-Oct-25	2492110	TNO002	Nokweja Final	HPC 37*	5	±21%	CFU/mL
09-Oct-25	2492113	TNO002	Nokweja Final	Odour*	Nil	-	-
09-Oct-25	2492109	TNO002	Nokweja Final	pH OS*	7.20	-	-
09-Oct-25	2492109	TNO002	Nokweja Final	Temperature OS*	15.0	-	°C
09-Oct-25	2492113	TNO002	Nokweja Final	Turbidity	3.0	±6.1%	NTU
09-Oct-25	2492157	TWA002	Washbank Final	Al (AE)	260	±7.6%	µg Al/L
09-Oct-25	2492152	TWA002	Washbank Final	Cl ₂ (F) OS*	0.60	-	mg Cl ₂ /L
09-Oct-25	2492152	TWA002	Washbank Final	Cl ₂ (T) OS*	0.72	-	mg Cl ₂ /L
09-Oct-25	2492153	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
09-Oct-25	2492152	TWA002	Washbank Final	Coll Time OS*	06:40	-	-
09-Oct-25	2492156	TWA002	Washbank Final	Colour	3.40	±6.5%	mg Pt-Co/L
09-Oct-25	2492155	TWA002	Washbank Final	Conductivity	8.83	±1.5%	mS/m
09-Oct-25	2492153	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
09-Oct-25	2492153	TWA002	Washbank Final	HPC 37*	1	±21%	CFU/mL
09-Oct-25	2492156	TWA002	Washbank Final	Odour*	Nil	-	-
09-Oct-25	2492152	TWA002	Washbank Final	pH OS*	7.40	-	-
09-Oct-25	2492152	TWA002	Washbank Final	Temperature OS*	18.0	-	°C
09-Oct-25	2492156	TWA002	Washbank Final	Turbidity	3.8	±6.1%	NTU
10-Oct-25	2492407	TIB002	Ibisi Final	Al (AE)	487	±7.6%	µg Al/L
10-Oct-25	2492402	TIB002	Ibisi Final	Cl ₂ (F) OS*	0.96	-	mg Cl ₂ /L
10-Oct-25	2492402	TIB002	Ibisi Final	Cl ₂ (T) OS*	1.16	-	mg Cl ₂ /L
10-Oct-25	2492403	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL

uMngeni-Uthukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,

Telephone (033) 341 1111

E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

10-Oct-25	2492403	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10mL
10-Oct-25	2492402	TIB002	Ibisi Final	Coll Time OS*	07:28	-	-
10-Oct-25	2492406	TIB002	Ibisi Final	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Oct-25	2492405	TIB002	Ibisi Final	Conductivity	13.0	±1.5%	mS/m
10-Oct-25	2492403	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
10-Oct-25	2492403	TIB002	Ibisi Final	HPC 37*	4	±21%	CFU/mL
10-Oct-25	2492406	TIB002	Ibisi Final	Odour*	Nil	-	-
10-Oct-25	2492402	TIB002	Ibisi Final	pH OS*	7.60	-	-
10-Oct-25	2492402	TIB002	Ibisi Final	Temperature OS*	22.1	-	°C
10-Oct-25	2492406	TIB002	Ibisi Final	Turbidity	4.2	±6.1%	NTU
10-Oct-25	2492408	TIB003	Ibisi Police Station Reticulation	Cl2 (F) OS*	0.22	-	mg Cl2/L
10-Oct-25	2492408	TIB003	Ibisi Police Station Reticulation	Cl2 (T) OS*	0.28	-	mg Cl2/L
10-Oct-25	2492409	TIB003	Ibisi Police Station Reticulation	Coliforms*	0	±15%	MPN/100mL
10-Oct-25	2492408	TIB003	Ibisi Police Station Reticulation	Coll Time OS*	07:01	-	-
10-Oct-25	2492412	TIB003	Ibisi Police Station Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Oct-25	2492411	TIB003	Ibisi Police Station Reticulation	Conductivity	13.2	±1.5%	mS/m
10-Oct-25	2492409	TIB003	Ibisi Police Station Reticulation	E.coli*	0	±14%	MPN/100mL
10-Oct-25	2492409	TIB003	Ibisi Police Station Reticulation	HPC 37*	0	±21%	CFU/mL
10-Oct-25	2492408	TIB003	Ibisi Police Station Reticulation	pH OS*	7.40	-	-
10-Oct-25	2492408	TIB003	Ibisi Police Station Reticulation	Temperature OS*	21.2	-	°C
10-Oct-25	2492412	TIB003	Ibisi Police Station Reticulation	Turbidity	2.1	±6.1%	NTU
10-Oct-25	2492417	TRT002	Rietvlei Final	Cl2 (F) OS*	1.44	-	mg Cl2/L
10-Oct-25	2492417	TRT002	Rietvlei Final	Cl2 (T) OS*	1.54	-	mg Cl2/L
10-Oct-25	2492418	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
10-Oct-25	2492417	TRT002	Rietvlei Final	Coll Time OS*	06:15	-	-
10-Oct-25	2492420	TRT002	Rietvlei Final	Conductivity	19.0	±1.5%	mS/m
10-Oct-25	2492418	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

10-Oct-25	2492418	TRT002	Rietvlei Final	HPC 37*	1	±21%	CFU/mL
10-Oct-25	2492417	TRT002	Rietvlei Final	pH OS*	7.40	-	-
10-Oct-25	2492417	TRT002	Rietvlei Final	Temperature OS*	19.1	-	°C
10-Oct-25	2492421	TRT002	Rietvlei Final	Turbidity	2.0	±6.1%	NTU
10-Oct-25	2492422	TRT004	Rietvlei Hospital Reticulation	Cl ₂ (F) OS*	0.20	-	mg Cl ₂ /L
10-Oct-25	2492422	TRT004	Rietvlei Hospital Reticulation	Cl ₂ (T) OS*	0.29	-	mg Cl ₂ /L
10-Oct-25	2492423	TRT004	Rietvlei Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
10-Oct-25	2492422	TRT004	Rietvlei Hospital Reticulation	Coll Time OS*	06:10	-	-
10-Oct-25	2492423	TRT004	Rietvlei Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
10-Oct-25	2492423	TRT004	Rietvlei Hospital Reticulation	HPC 37*	0	±21%	CFU/mL
10-Oct-25	2492422	TRT004	Rietvlei Hospital Reticulation	pH OS*	7.20	-	-
10-Oct-25	2492422	TRT004	Rietvlei Hospital Reticulation	Temperature OS*	18.0	-	°C
10-Oct-25	2492425	TRT004	Rietvlei Hospital Reticulation	Turbidity	3.1	±6.1%	NTU
13-Oct-25	2494093	TFR002	Franklin Final	Al (AE)	149	±7.6%	µg Al/L
13-Oct-25	2494088	TFR002	Franklin Final	Cl ₂ (F) OS*	1.11	-	mg Cl ₂ /L
13-Oct-25	2494088	TFR002	Franklin Final	Cl ₂ (T) OS*	1.23	-	mg Cl ₂ /L
13-Oct-25	2494089	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
13-Oct-25	2494089	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10mL
13-Oct-25	2494088	TFR002	Franklin Final	Coll Time OS*	07:03	-	-
13-Oct-25	2494091	TFR002	Franklin Final	Conductivity	13.3	±1.5%	mS/m
13-Oct-25	2494089	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
13-Oct-25	2494089	TFR002	Franklin Final	HPC 37*	0	±21%	CFU/mL
13-Oct-25	2494088	TFR002	Franklin Final	pH OS*	7.40	-	-
13-Oct-25	2494088	TFR002	Franklin Final	Temperature OS*	18.4	-	°C
13-Oct-25	2494092	TFR002	Franklin Final	Turbidity	1.3	±6.1%	NTU
13-Oct-25	2494104	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
13-Oct-25	2494099	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.39	-	mg Cl ₂ /L
13-Oct-25	2494099	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.46	-	mg Cl ₂ /L
13-Oct-25	2494100	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
13-Oct-25	2494100	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10mL
13-Oct-25	2494099	TKK002	Kokstad Final	Coll Time OS*	09:02	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

13-Oct-25	2494102	TKK002	Kokstad Final	Conductivity	17.3	±1.5%	mS/m
13-Oct-25	2494100	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
13-Oct-25	2494100	TKK002	Kokstad Final	HPC 37*	0	±21%	CFU/mL
13-Oct-25	2494099	TKK002	Kokstad Final	pH OS*	7.30	-	-
13-Oct-25	2494099	TKK002	Kokstad Final	Temperature OS*	19.6	-	°C
13-Oct-25	2494103	TKK002	Kokstad Final	Turbidity	0.7	±6.1%	NTU
13-Oct-25	2494141	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	0.82	-	mg Cl ₂ /L
13-Oct-25	2494141	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	1.05	-	mg Cl ₂ /L
13-Oct-25	2494142	TNJU002	KwaNjunga Final	Coliforms*	11	±15%	MPN/100mL
13-Oct-25	2494141	TNJU002	KwaNjunga Final	Coll Time OS*	06:23	-	-
13-Oct-25	2494144	TNJU002	KwaNjunga Final	Conductivity	19.0	±1.5%	mS/m
13-Oct-25	2494142	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
13-Oct-25	2494142	TNJU002	KwaNjunga Final	HPC 37*	1	±21%	CFU/mL
13-Oct-25	2494141	TNJU002	KwaNjunga Final	pH OS*	7.30	-	-
13-Oct-25	2494141	TNJU002	KwaNjunga Final	Temperature OS*	17.9	-	°C
13-Oct-25	2494145	TNJU002	KwaNjunga Final	Turbidity	0.8	±6.1%	NTU
14-Oct-25	2494718	TJO001	Jolivet RRT frn Vulamehlo	Cl ₂ (F) OS*	0.63	-	mg Cl ₂ /L
14-Oct-25	2494718	TJO001	Jolivet RRT frn Vulamehlo	Cl ₂ (T) OS*	0.71	-	mg Cl ₂ /L
14-Oct-25	2494719	TJO001	Jolivet RRT frn Vulamehlo	Coliforms*	0	±15%	MPN/100mL
14-Oct-25	2494718	TJO001	Jolivet RRT frn Vulamehlo	Coll Time OS*	08:34	-	-
14-Oct-25	2494722	TJO001	Jolivet RRT frn Vulamehlo	Colour	1.40	±6.5%	mg Pt-Co/L
14-Oct-25	2494721	TJO001	Jolivet RRT frn Vulamehlo	Conductivity	13.2	±1.5%	mS/m
14-Oct-25	2494719	TJO001	Jolivet RRT frn Vulamehlo	E.coli*	0	±14%	MPN/100mL
14-Oct-25	2494719	TJO001	Jolivet RRT frn Vulamehlo	HPC 37*	0	±21%	CFU/mL
14-Oct-25	2494722	TJO001	Jolivet RRT frn Vulamehlo	Odour*	Nil	-	-
14-Oct-25	2494718	TJO001	Jolivet RRT frn Vulamehlo	pH OS*	7.84	-	-
14-Oct-25	2494718	TJO001	Jolivet RRT frn Vulamehlo	Temperature OS*	21.5	-	°C
14-Oct-25	2494722	TJO001	Jolivet RRT frn Vulamehlo	Turbidity	1.4	±6.1%	NTU
14-Oct-25	2494774	TQU002	Mnqumeni Final	Cl ₂ (F) OS*	0.79	-	mg Cl ₂ /L
14-Oct-25	2494774	TQU002	Mnqumeni Final	Cl ₂ (T) OS*	0.99	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

14-Oct-25	2494775	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
14-Oct-25	2494774	TQU002	Mnqumeni Final	Coll Time OS*	07:40	-	-
14-Oct-25	2494777	TQU002	Mnqumeni Final	Conductivity	17.0	±1.5%	mS/m
14-Oct-25	2494775	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
14-Oct-25	2494775	TQU002	Mnqumeni Final	HPC 37*	0	±21%	CFU/mL
14-Oct-25	2494774	TQU002	Mnqumeni Final	pH OS*	7.40	-	-
14-Oct-25	2494774	TQU002	Mnqumeni Final	Temperature OS*	18.8	-	°C
14-Oct-25	2494778	TQU002	Mnqumeni Final	Turbidity	0.4	±6.1%	NTU
14-Oct-25	2494789	TSQ002	Esiqanduleni Final	Al (AE)	149	±7.6%	µg Al/L
14-Oct-25	2494784	TSQ002	Esiqanduleni Final	Cl ₂ (F) OS*	1.05	-	mg Cl ₂ /L
14-Oct-25	2494784	TSQ002	Esiqanduleni Final	Cl ₂ (T) OS*	1.15	-	mg Cl ₂ /L
14-Oct-25	2494785	TSQ002	Esiqanduleni Final	Coliforms*	1	±15%	MPN/100mL
14-Oct-25	2494784	TSQ002	Esiqanduleni Final	Coll Time OS*	08:35	-	-
14-Oct-25	2494787	TSQ002	Esiqanduleni Final	Conductivity	17.5	±1.5%	mS/m
14-Oct-25	2494785	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
14-Oct-25	2494785	TSQ002	Esiqanduleni Final	HPC 37*	14	±21%	CFU/mL
14-Oct-25	2494784	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
14-Oct-25	2494784	TSQ002	Esiqanduleni Final	Temperature OS*	20.2	-	°C
14-Oct-25	2494788	TSQ002	Esiqanduleni Final	Turbidity	1.0	±6.1%	NTU
15-Oct-25	2495397	TBU002	Bulwer Final	Cl ₂ (F) OS*	1.03	-	mg Cl ₂ /L
15-Oct-25	2495397	TBU002	Bulwer Final	Cl ₂ (T) OS*	1.11	-	mg Cl ₂ /L
15-Oct-25	2495398	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
15-Oct-25	2495397	TBU002	Bulwer Final	Coll Time OS*	09:08	-	-
15-Oct-25	2495400	TBU002	Bulwer Final	Conductivity	6.42	±1.5%	mS/m
15-Oct-25	2495398	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
15-Oct-25	2495402	TBU002	Bulwer Final	Fe (AE)	0.33	±5.4%	mg Fe/L
15-Oct-25	2495398	TBU002	Bulwer Final	HPC 37*	7	±21%	CFU/mL
15-Oct-25	2495397	TBU002	Bulwer Final	pH OS*	7.30	-	-
15-Oct-25	2495397	TBU002	Bulwer Final	Temperature OS*	18.2	-	°C
15-Oct-25	2495401	TBU002	Bulwer Final	Turbidity	6.4	±6.1%	NTU
15-Oct-25	2495433	TMAN002	Mangwaneni Final	Cl ₂ (F) OS*	0.72	-	mg Cl ₂ /L
15-Oct-25	2495433	TMAN002	Mangwaneni Final	Cl ₂ (T) OS*	0.83	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

15-Oct-25	2495434	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
15-Oct-25	2495433	TMAN002	Mangwaneni Final	Coll Time OS*	10:16	-	-
15-Oct-25	2495436	TMAN002	Mangwaneni Final	Conductivity	14.1	±1.5%	mS/m
15-Oct-25	2495434	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
15-Oct-25	2495438	TMAN002	Mangwaneni Final	Fe (AE)	0.16	±5.4%	mg Fe/L
15-Oct-25	2495434	TMAN002	Mangwaneni Final	HPC 37*	0	±21%	CFU/mL
15-Oct-25	2495433	TMAN002	Mangwaneni Final	pH OS*	7.50	-	-
15-Oct-25	2495433	TMAN002	Mangwaneni Final	Temperature OS*	17.7	-	°C
15-Oct-25	2495437	TMAN002	Mangwaneni Final	Turbidity	3.0	±6.1%	NTU
15-Oct-25	2495454	TRV002	Riverside Final	Cl ₂ (F) OS*	1.63	-	mg Cl ₂ /L
15-Oct-25	2495454	TRV002	Riverside Final	Cl ₂ (T) OS*	1.70	-	mg Cl ₂ /L
15-Oct-25	2495455	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
15-Oct-25	2495454	TRV002	Riverside Final	Coll Time OS*	07:52	-	-
15-Oct-25	2495457	TRV002	Riverside Final	Conductivity	8.41	±1.5%	mS/m
15-Oct-25	2495455	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
15-Oct-25	2495455	TRV002	Riverside Final	HPC 37*	2	±21%	CFU/mL
15-Oct-25	2495454	TRV002	Riverside Final	pH OS*	7.30	-	-
15-Oct-25	2495454	TRV002	Riverside Final	Temperature OS*	17.1	-	°C
15-Oct-25	2495458	TRV002	Riverside Final	Turbidity	1.0	±6.1%	NTU
15-Oct-25	2495464	TST002	St Appollinaris Final	Cl ₂ (F) OS*	0.50	-	mg Cl ₂ /L
15-Oct-25	2495464	TST002	St Appollinaris Final	Cl ₂ (T) OS*	0.60	-	mg Cl ₂ /L
15-Oct-25	2495465	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
15-Oct-25	2495464	TST002	St Appollinaris Final	Coll Time OS*	08:25	-	-
15-Oct-25	2495467	TST002	St Appollinaris Final	Conductivity	9.47	±1.5%	mS/m
15-Oct-25	2495465	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
15-Oct-25	2495465	TST002	St Appollinaris Final	HPC 37*	2	±21%	CFU/mL
15-Oct-25	2495464	TST002	St Appollinaris Final	pH OS*	7.40	-	-
15-Oct-25	2495464	TST002	St Appollinaris Final	Temperature OS*	20.3	-	°C
15-Oct-25	2495468	TST002	St Appollinaris Final	Turbidity	21.5	±6.1%	NTU
15-Oct-25	2495483	TUN002	Underberg Final	Al (AE)	32.9	±7.6%	µg Al/L
15-Oct-25	2495478	TUN002	Underberg Final	Cl ₂ (F) OS*	0.19	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

15-Oct-25	2495478	TUN002	Underberg Final	Cl ₂ (T) OS*	0.28	-	mg Cl ₂ /L
15-Oct-25	2495479	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
15-Oct-25	2495478	TUN002	Underberg Final	Coll Time OS*	08:50	-	-
15-Oct-25	2495481	TUN002	Underberg Final	Conductivity	5.53	±1.5%	mS/m
15-Oct-25	2495479	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
15-Oct-25	2495479	TUN002	Underberg Final	HPC 37*	1	±21%	CFU/mL
15-Oct-25	2495478	TUN002	Underberg Final	pH OS*	7.60	-	-
15-Oct-25	2495478	TUN002	Underberg Final	Temperature OS*	18.5	-	°C
15-Oct-25	2495482	TUN002	Underberg Final	Turbidity	0.3	±6.1%	NTU
16-Oct-25	2496010	TMZ002	Umzimkhulu Final	Al (AE)	206	±7.6%	µg Al/L
16-Oct-25	2496005	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	1.05	-	mg Cl ₂ /L
16-Oct-25	2496005	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	1.14	-	mg Cl ₂ /L
16-Oct-25	2496006	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
16-Oct-25	2496006	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10mL
16-Oct-25	2496005	TMZ002	Umzimkhulu Final	Coll Time OS*	07:20	-	-
16-Oct-25	2496009	TMZ002	Umzimkhulu Final	Colour	<1.00	±6.5%	mg Pt-Co/L
16-Oct-25	2496008	TMZ002	Umzimkhulu Final	Conductivity	10.7	±1.5%	mS/m
16-Oct-25	2496006	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
16-Oct-25	2496006	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	CFU/mL
16-Oct-25	2496009	TMZ002	Umzimkhulu Final	Odour*	Nil	-	-
16-Oct-25	2496005	TMZ002	Umzimkhulu Final	pH OS*	7.50	-	-
16-Oct-25	2496005	TMZ002	Umzimkhulu Final	Temperature OS*	18.7	-	°C
16-Oct-25	2496009	TMZ002	Umzimkhulu Final	Turbidity	2.3	±6.1%	NTU
16-Oct-25	2496021	TNO002	Nokweja Final	Al (AE)	348	±7.6%	µg Al/L
16-Oct-25	2496016	TNO002	Nokweja Final	Cl ₂ (F) OS*	1.37	-	mg Cl ₂ /L
16-Oct-25	2496016	TNO002	Nokweja Final	Cl ₂ (T) OS*	1.46	-	mg Cl ₂ /L
16-Oct-25	2496017	TNO002	Nokweja Final	Coliforms*	45	±15%	MPN/100mL
16-Oct-25	2496017	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10mL
16-Oct-25	2496016	TNO002	Nokweja Final	Coll Time OS*	07:40	-	-
16-Oct-25	2496019	TNO002	Nokweja Final	Conductivity	10.3	±1.5%	mS/m
16-Oct-25	2496017	TNO002	Nokweja Final	E.coli*	4	±14%	MPN/100mL
16-Oct-25	2496017	TNO002	Nokweja Final	HPC 37*	18	±21%	CFU/mL
16-Oct-25	2496016	TNO002	Nokweja Final	pH OS*	7.50	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

16-Oct-25	2496016	TNO002	Nokweja Final	Temperature OS*	18.2	-	°C
16-Oct-25	2496020	TNO002	Nokweja Final	Turbidity	2.6	±6.1%	NTU
16-Oct-25	2496071	TWA002	Washbank Final	Al (AE)	322	±7.6%	µg Al/L
16-Oct-25	2496066	TWA002	Washbank Final	Cl ₂ (F) OS*	0.80	-	mg Cl ₂ /L
16-Oct-25	2496066	TWA002	Washbank Final	Cl ₂ (T) OS*	0.95	-	mg Cl ₂ /L
16-Oct-25	2496067	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
16-Oct-25	2496066	TWA002	Washbank Final	Coll Time OS*	06:40	-	-
16-Oct-25	2496069	TWA002	Washbank Final	Conductivity	8.64	±1.5%	mS/m
16-Oct-25	2496067	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
16-Oct-25	2496067	TWA002	Washbank Final	HPC 37*	4	±21%	CFU/mL
16-Oct-25	2496066	TWA002	Washbank Final	pH OS*	7.30	-	-
16-Oct-25	2496066	TWA002	Washbank Final	Temperature OS*	18.9	-	°C
16-Oct-25	2496070	TWA002	Washbank Final	Turbidity	4.6	±6.1%	NTU
17-Oct-25	2496389	TIB002	Ibisi Final	Al (AE)	262	±7.6%	µg Al/L
17-Oct-25	2496384	TIB002	Ibisi Final	Cl ₂ (F) OS*	0.80	-	mg Cl ₂ /L
17-Oct-25	2496384	TIB002	Ibisi Final	Cl ₂ (T) OS*	0.99	-	mg Cl ₂ /L
17-Oct-25	2496385	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
17-Oct-25	2496385	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10mL
17-Oct-25	2496384	TIB002	Ibisi Final	Coll Time OS*	07:17	-	-
17-Oct-25	2496387	TIB002	Ibisi Final	Conductivity	13.2	±1.5%	mS/m
17-Oct-25	2496385	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
17-Oct-25	2496385	TIB002	Ibisi Final	HPC 37*	11	±21%	CFU/mL
17-Oct-25	2496384	TIB002	Ibisi Final	pH OS*	7.30	-	-
17-Oct-25	2496384	TIB002	Ibisi Final	Temperature OS*	17.4	-	°C
17-Oct-25	2496388	TIB002	Ibisi Final	Turbidity	5.2	±6.1%	NTU
17-Oct-25	2496399	TRT002	Rietvlei Final	Al (AE)	415	±7.6%	µg Al/L
17-Oct-25	2496394	TRT002	Rietvlei Final	Cl ₂ (F) OS*	1.05	-	mg Cl ₂ /L
17-Oct-25	2496394	TRT002	Rietvlei Final	Cl ₂ (T) OS*	1.19	-	mg Cl ₂ /L
17-Oct-25	2496395	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
17-Oct-25	2496394	TRT002	Rietvlei Final	Coll Time OS*	07:40	-	-
17-Oct-25	2496397	TRT002	Rietvlei Final	Conductivity	18.9	±1.5%	mS/m
17-Oct-25	2496395	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
17-Oct-25	2496399	TRT002	Rietvlei Final	Fe (AE)	0.08	±5.4%	mg Fe/L
17-Oct-25	2496395	TRT002	Rietvlei Final	HPC 37*	0	±21%	CFU/mL
17-Oct-25	2496399	TRT002	Rietvlei Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
17-Oct-25	2496398	TRT002	Rietvlei Final	Odour*	Nil	-	-
17-Oct-25	2496394	TRT002	Rietvlei Final	pH OS*	7.50	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

17-Oct-25	2496398	TRT002	Rietvlei Final	Taste*	Nil	-	-
17-Oct-25	2496394	TRT002	Rietvlei Final	Temperature OS*	17.2	-	°C
17-Oct-25	2496398	TRT002	Rietvlei Final	Turbidity	1.9	±6.1%	NTU
20-Oct-25	2499383	TFR002	Franklin Final	Al (AE)	148	±7.6%	µg Al/L
20-Oct-25	2499378	TFR002	Franklin Final	Cl ₂ (F) OS*	0.80	-	mg Cl ₂ /L
20-Oct-25	2499378	TFR002	Franklin Final	Cl ₂ (T) OS*	0.95	-	mg Cl ₂ /L
20-Oct-25	2499379	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
20-Oct-25	2499379	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10mL
20-Oct-25	2499378	TFR002	Franklin Final	Coll Time OS*	7:12	-	-
20-Oct-25	2499382	TFR002	Franklin Final	Colour	<1.00	±6.5%	mg Pt-Co/L
20-Oct-25	2499381	TFR002	Franklin Final	Conductivity	12.3	±1.5%	mS/m
20-Oct-25	2499379	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
20-Oct-25	2499383	TFR002	Franklin Final	Fe (AE)	0.06	±5.4%	mg Fe/L
20-Oct-25	2499379	TFR002	Franklin Final	HPC 37*	0	±21%	CFU/mL
20-Oct-25	2499383	TFR002	Franklin Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
20-Oct-25	2499382	TFR002	Franklin Final	Odour*	Nil	-	-
20-Oct-25	2499378	TFR002	Franklin Final	pH OS*	7.30	-	-
20-Oct-25	2499378	TFR002	Franklin Final	Temperature OS*	18.0	-	°C
20-Oct-25	2499382	TFR002	Franklin Final	Turbidity	1.4	±6.1%	NTU
20-Oct-25	2499384	TFR003	Franklin Police Station Retic	Cl ₂ (F) OS*	0.71	-	mg Cl ₂ /L
20-Oct-25	2499384	TFR003	Franklin Police Station Retic	Cl ₂ (T) OS*	0.84	-	mg Cl ₂ /L
20-Oct-25	2499385	TFR003	Franklin Police Station Retic	Coliforms*	0	±15%	MPN/100mL
20-Oct-25	2499384	TFR003	Franklin Police Station Retic	Coll Time OS*	7:21	-	-
20-Oct-25	2499388	TFR003	Franklin Police Station Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
20-Oct-25	2499387	TFR003	Franklin Police Station Retic	Conductivity	12.3	±1.5%	mS/m
20-Oct-25	2499385	TFR003	Franklin Police Station Retic	E.coli*	0	±14%	MPN/100mL
20-Oct-25	2499385	TFR003	Franklin Police Station Retic	HPC 37*	0	±21%	CFU/mL
20-Oct-25	2499388	TFR003	Franklin Police Station Retic	Odour*	Nil	-	-
20-Oct-25	2499384	TFR003	Franklin Police Station Retic	pH OS*	7.40	-	-
20-Oct-25	2499384	TFR003	Franklin Police Station Retic	Temperature OS*	18.0	-	°C
20-Oct-25	2499388	TFR003	Franklin Police Station Retic	Turbidity	1.2	±6.1%	NTU
20-Oct-25	2499399	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
20-Oct-25	2499394	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.07	-	mg Cl ₂ /L
20-Oct-25	2499394	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.18	-	mg Cl ₂ /L
20-Oct-25	2499395	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,

Telephone (033) 341 1111

E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

20-Oct-25	2499395	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10mL
20-Oct-25	2499394	TKK002	Kokstad Final	Coll Time OS*	7:36	-	-
20-Oct-25	2499398	TKK002	Kokstad Final	Colour	2.10	±6.5%	mg Pt-Co/L
20-Oct-25	2499397	TKK002	Kokstad Final	Conductivity	16.4	±1.5%	mS/m
20-Oct-25	2499395	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
20-Oct-25	2499399	TKK002	Kokstad Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
20-Oct-25	2499395	TKK002	Kokstad Final	HPC 37*	0	±21%	CFU/mL
20-Oct-25	2499398	TKK002	Kokstad Final	Odour*	Nil	-	-
20-Oct-25	2499394	TKK002	Kokstad Final	pH OS*	7.40	-	-
20-Oct-25	2499398	TKK002	Kokstad Final	Taste*	Nil	-	-
20-Oct-25	2499394	TKK002	Kokstad Final	Temperature OS*	16.2	-	°C
20-Oct-25	2499398	TKK002	Kokstad Final	Turbidity	0.3	±6.1%	NTU
20-Oct-25	2499409	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl2 (F) OS*	0.76	-	mg Cl2/L
20-Oct-25	2499409	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl2 (T) OS*	0.84	-	mg Cl2/L
20-Oct-25	2499410	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliforms*	0	±15%	MPN/100mL
20-Oct-25	2499409	TKK006	Kokstad Bongweni Correctional Serv Retic	Coll Time OS*	8:14	-	-
20-Oct-25	2499412	TKK006	Kokstad Bongweni Correctional Serv Retic	Colour	1.50	±6.5%	mg Pt-Co/L
20-Oct-25	2499410	TKK006	Kokstad Bongweni Correctional Serv Retic	E.coli*	0	±14%	MPN/100mL
20-Oct-25	2499410	TKK006	Kokstad Bongweni Correctional Serv Retic	HPC 37*	0	±21%	CFU/mL
20-Oct-25	2499412	TKK006	Kokstad Bongweni Correctional Serv Retic	Odour*	Nil	-	-
20-Oct-25	2499409	TKK006	Kokstad Bongweni Correctional Serv Retic	pH OS*	7.50	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

20-Oct-25	2499412	TKK006	Kokstad Bongweni Correctional Serv Retic	Taste*	Nil	-	-
20-Oct-25	2499409	TKK006	Kokstad Bongweni Correctional Serv Retic	Temperature OS*	15.4	-	°C
20-Oct-25	2499412	TKK006	Kokstad Bongweni Correctional Serv Retic	Turbidity	0.3	±6.1%	NTU
20-Oct-25	2499413	TKK007	Kokstad Shayamoya Reticulation	Cl ₂ (F) OS*	0.36	-	mg Cl ₂ /L
20-Oct-25	2499413	TKK007	Kokstad Shayamoya Reticulation	Cl ₂ (T) OS*	0.58	-	mg Cl ₂ /L
20-Oct-25	2499414	TKK007	Kokstad Shayamoya Reticulation	Coliforms*	0	±15%	MPN/100mL
20-Oct-25	2499413	TKK007	Kokstad Shayamoya Reticulation	Coll Time OS*	8:40	-	-
20-Oct-25	2499414	TKK007	Kokstad Shayamoya Reticulation	E.coli*	0	±14%	MPN/100mL
20-Oct-25	2499414	TKK007	Kokstad Shayamoya Reticulation	HPC 37*	0	±21%	CFU/mL
20-Oct-25	2499413	TKK007	Kokstad Shayamoya Reticulation	pH OS*	7.50	-	-
20-Oct-25	2499413	TKK007	Kokstad Shayamoya Reticulation	Temperature OS*	15.8	-	°C
20-Oct-25	2499416	TKK007	Kokstad Shayamoya Reticulation	Turbidity	0.4	±6.1%	NTU
20-Oct-25	2499417	TKK009	Kokstad Farm Fresh Produce Market	Cl ₂ (F) OS*	0.70	-	mg Cl ₂ /L
20-Oct-25	2499417	TKK009	Kokstad Farm Fresh Produce Market	Cl ₂ (T) OS*	0.90	-	mg Cl ₂ /L
20-Oct-25	2499418	TKK009	Kokstad Farm Fresh Produce Market	Coliforms*	0	±15%	MPN/100mL
20-Oct-25	2499417	TKK009	Kokstad Farm Fresh Produce Market	Coll Time OS*	9:05	-	-
20-Oct-25	2499418	TKK009	Kokstad Farm Fresh Produce Market	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

20-Oct-25	2499418	TKK009	Kokstad Farm Fresh Produce Market	HPC 37*	0	±21%	CFU/mL
20-Oct-25	2499417	TKK009	Kokstad Farm Fresh Produce Market	pH OS*	7.60	-	-
20-Oct-25	2499417	TKK009	Kokstad Farm Fresh Produce Market	Temperature OS*	16.1	-	°C
20-Oct-25	2499420	TKK009	Kokstad Farm Fresh Produce Market	Turbidity	0.3	±6.1%	NTU
20-Oct-25	2494110	TKK011	Kokstad Hospital Reticulation	Cl ₂ (F) OS*	0.25	-	mg Cl ₂ /L
20-Oct-25	2494110	TKK011	Kokstad Hospital Reticulation	Cl ₂ (T) OS*	0.30	-	mg Cl ₂ /L
20-Oct-25	2494111	TKK011	Kokstad Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
20-Oct-25	2494110	TKK011	Kokstad Hospital Reticulation	Coll Time OS*	8:25	-	-
20-Oct-25	2494111	TKK011	Kokstad Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
20-Oct-25	2494111	TKK011	Kokstad Hospital Reticulation	HPC 37*	0	±21%	CFU/mL
20-Oct-25	2494110	TKK011	Kokstad Hospital Reticulation	pH OS*	7.10	-	-
20-Oct-25	2494110	TKK011	Kokstad Hospital Reticulation	Temperature OS*	16.9	-	°C
20-Oct-25	2494113	TKK011	Kokstad Hospital Reticulation	Turbidity	0.3	±6.1%	NTU
20-Oct-25	2499421	TKK012	Kokstad FET College Reticulation	Cl ₂ (F) OS*	0.56	-	mg Cl ₂ /L
20-Oct-25	2499421	TKK012	Kokstad FET College Reticulation	Cl ₂ (T) OS*	0.68	-	mg Cl ₂ /L
20-Oct-25	2499422	TKK012	Kokstad FET College Reticulation	Coliforms*	0	±15%	MPN/100mL
20-Oct-25	2499421	TKK012	Kokstad FET College Reticulation	Coll Time OS*	9:12	-	-
20-Oct-25	2499425	TKK012	Kokstad FET College Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
20-Oct-25	2499424	TKK012	Kokstad FET College Reticulation	Conductivity	17.3	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

20-Oct-25	2499422	TKK012	Kokstad FET College Reticulation	E.coli*	0	±14%	MPN/100mL
20-Oct-25	2499422	TKK012	Kokstad FET College Reticulation	HPC 37*	0	±21%	CFU/mL
20-Oct-25	2499421	TKK012	Kokstad FET College Reticulation	pH OS*	7.40	-	-
20-Oct-25	2499421	TKK012	Kokstad FET College Reticulation	Temperature OS*	15.2	-	°C
20-Oct-25	2499425	TKK012	Kokstad FET College Reticulation	Turbidity	0.4	±6.1%	NTU
20-Oct-25	2499448	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	0.22	-	mg Cl ₂ /L
20-Oct-25	2499448	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	0.33	-	mg Cl ₂ /L
20-Oct-25	2499449	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
20-Oct-25	2499448	TNJU002	KwaNjunga Final	Coll Time OS*	6:35	-	-
20-Oct-25	2499451	TNJU002	KwaNjunga Final	Conductivity	20.8	±1.5%	mS/m
20-Oct-25	2499449	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
20-Oct-25	2499453	TNJU002	KwaNjunga Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
20-Oct-25	2499449	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	CFU/mL
20-Oct-25	2499453	TNJU002	KwaNjunga Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
20-Oct-25	2499452	TNJU002	KwaNjunga Final	Odour*	Nil	-	-
20-Oct-25	2499448	TNJU002	KwaNjunga Final	pH OS*	7.40	-	-
20-Oct-25	2499452	TNJU002	KwaNjunga Final	Taste*	Nil	-	-
20-Oct-25	2499448	TNJU002	KwaNjunga Final	Temperature OS*	17.7	-	°C
20-Oct-25	2499452	TNJU002	KwaNjunga Final	Turbidity	0.2	±6.1%	NTU
21-Oct-25	2499956	TQU002	Mnqumeni Final	Al (AE)	83.5	±7.6%	µg Al/L
21-Oct-25	2499951	TQU002	Mnqumeni Final	Cl ₂ (F) OS*	0.75	-	mg Cl ₂ /L
21-Oct-25	2499951	TQU002	Mnqumeni Final	Cl ₂ (T) OS*	0.79	-	mg Cl ₂ /L
21-Oct-25	2499952	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
21-Oct-25	2499951	TQU002	Mnqumeni Final	Coll Time OS*	07:30	-	-
21-Oct-25	2499954	TQU002	Mnqumeni Final	Conductivity	15.5	±1.5%	mS/m
21-Oct-25	2499952	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

21-Oct-25	2499956	TQU002	Mnqumeni Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
21-Oct-25	2499952	TQU002	Mnqumeni Final	HPC 37*	0	±21%	CFU/mL
21-Oct-25	2499956	TQU002	Mnqumeni Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
21-Oct-25	2499955	TQU002	Mnqumeni Final	Odour*	Mild Chlorinous	-	-
21-Oct-25	2499951	TQU002	Mnqumeni Final	pH OS*	7.30	-	-
21-Oct-25	2499955	TQU002	Mnqumeni Final	Taste*	Nil	-	-
21-Oct-25	2499951	TQU002	Mnqumeni Final	Temperature OS*	19.4	-	°C
21-Oct-25	2499955	TQU002	Mnqumeni Final	Turbidity	0.4	±6.1%	NTU
21-Oct-25	2499957	TQU003	Mnqumeni Reticulation	Cl ₂ (F) OS*	0.48	-	mg Cl ₂ /L
21-Oct-25	2499957	TQU003	Mnqumeni Reticulation	Cl ₂ (T) OS*	0.58	-	mg Cl ₂ /L
21-Oct-25	2499958	TQU003	Mnqumeni Reticulation	Coliforms*	0	±15%	MPN/100mL
21-Oct-25	2499957	TQU003	Mnqumeni Reticulation	Coll Time OS*	07;48	-	-
21-Oct-25	2499958	TQU003	Mnqumeni Reticulation	E.coli*	0	±14%	MPN/100mL
21-Oct-25	2499958	TQU003	Mnqumeni Reticulation	HPC 37*	0	±21%	CFU/mL
21-Oct-25	2499957	TQU003	Mnqumeni Reticulation	pH OS*	7.30	-	-
21-Oct-25	2499957	TQU003	Mnqumeni Reticulation	Temperature OS*	19.1	-	°C
21-Oct-25	2499960	TQU003	Mnqumeni Reticulation	Turbidity	1.1	±6.1%	NTU
21-Oct-25	2499971	TSQ002	Esiqanduleni Final	Al (AE)	161	±7.6%	µg Al/L
21-Oct-25	2499966	TSQ002	Esiqanduleni Final	Cl ₂ (F) OS*	1.35	-	mg Cl ₂ /L
21-Oct-25	2499966	TSQ002	Esiqanduleni Final	Cl ₂ (T) OS*	1.40	-	mg Cl ₂ /L
21-Oct-25	2499967	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
21-Oct-25	2499966	TSQ002	Esiqanduleni Final	Coll Time OS*	08:00	-	-
21-Oct-25	2499970	TSQ002	Esiqanduleni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
21-Oct-25	2499969	TSQ002	Esiqanduleni Final	Conductivity	22.0	±1.5%	mS/m
21-Oct-25	2499967	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
21-Oct-25	2499967	TSQ002	Esiqanduleni Final	HPC 37*	9	±21%	CFU/mL
21-Oct-25	2499970	TSQ002	Esiqanduleni Final	Odour*	Mild Chlorinous	-	-
21-Oct-25	2499966	TSQ002	Esiqanduleni Final	pH OS*	7.40	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

21-Oct-25	2499966	TSQ002	Esiqanduleni Final	Temperature OS*	17.3	-	°C
21-Oct-25	2499970	TSQ002	Esiqanduleni Final	Turbidity	1.8	±6.1%	NTU
21-Oct-25	2499972	TSQ003	Esiqanduleni Reticulation	Cl ₂ (F) OS*	0.74	-	mg Cl ₂ /L
21-Oct-25	2499972	TSQ003	Esiqanduleni Reticulation	Cl ₂ (T) OS*	0.80	-	mg Cl ₂ /L
21-Oct-25	2499973	TSQ003	Esiqanduleni Reticulation	Coliforms*	0	±15%	MPN/100mL
21-Oct-25	2499972	TSQ003	Esiqanduleni Reticulation	Coll Time OS*	08;35	-	-
21-Oct-25	2499976	TSQ003	Esiqanduleni Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
21-Oct-25	2499975	TSQ003	Esiqanduleni Reticulation	Conductivity	16.9	±1.5%	mS/m
21-Oct-25	2499973	TSQ003	Esiqanduleni Reticulation	E.coli*	0	±14%	MPN/100mL
21-Oct-25	2499973	TSQ003	Esiqanduleni Reticulation	HPC 37*	0	±21%	CFU/mL
21-Oct-25	2499976	TSQ003	Esiqanduleni Reticulation	Odour*	Mild Chlorinous	-	-
21-Oct-25	2499972	TSQ003	Esiqanduleni Reticulation	pH OS*	7.50	-	-
21-Oct-25	2499972	TSQ003	Esiqanduleni Reticulation	Temperature OS*	19.2	-	°C
21-Oct-25	2499976	TSQ003	Esiqanduleni Reticulation	Turbidity	4.2	±6.1%	NTU
22-Oct-25	2500578	TBU002	Bulwer Final	Cl ₂ (F) OS*	1.26	-	mg Cl ₂ /L
22-Oct-25	2500578	TBU002	Bulwer Final	Cl ₂ (T) OS*	1.36	-	mg Cl ₂ /L
22-Oct-25	2500579	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
22-Oct-25	2500578	TBU002	Bulwer Final	Coll Time OS*	9:00	-	-
22-Oct-25	2500582	TBU002	Bulwer Final	Colour	<1.00	±6.5%	mg Pt-Co/L
22-Oct-25	2500581	TBU002	Bulwer Final	Conductivity	5.34	±1.5%	mS/m
22-Oct-25	2500579	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
22-Oct-25	2500579	TBU002	Bulwer Final	HPC 37*	5	±21%	CFU/mL
22-Oct-25	2500582	TBU002	Bulwer Final	Odour*	Nil	-	-
22-Oct-25	2500578	TBU002	Bulwer Final	pH OS*	7.40	-	-
22-Oct-25	2500578	TBU002	Bulwer Final	Temperature OS*	21.4	-	°C
22-Oct-25	2500582	TBU002	Bulwer Final	Turbidity	3.9	±6.1%	NTU
22-Oct-25	2500583	TBU005	Bulwer Mountain Park Hotel Retic	Cl ₂ (F) OS*	0.74	-	mg Cl ₂ /L
22-Oct-25	2500583	TBU005	Bulwer Mountain Park Hotel Retic	Cl ₂ (T) OS*	0.82	-	mg Cl ₂ /L
22-Oct-25	2500584	TBU005	Bulwer Mountain Park Hotel Retic	Coliforms*	0	±15%	MPN/100mL
22-Oct-25	2500583	TBU005	Bulwer Mountain Park Hotel Retic	Coll Time OS*	9:30	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

22-Oct-25	2500584	TBU005	Bulwer Mountain Park Hotel Retic	E.coli*	0	±14%	MPN/100mL
22-Oct-25	2500584	TBU005	Bulwer Mountain Park Hotel Retic	HPC 37*	2	±21%	CFU/mL
22-Oct-25	2500583	TBU005	Bulwer Mountain Park Hotel Retic	pH OS*	7.50	-	-
22-Oct-25	2500583	TBU005	Bulwer Mountain Park Hotel Retic	Temperature OS*	21.6	-	°C
22-Oct-25	2500586	TBU005	Bulwer Mountain Park Hotel Retic	Turbidity	2.6	±6.1%	NTU
22-Oct-25	2500597	TCR002	Creighton Final	Al (AE)	137	±7.6%	µg Al/L
22-Oct-25	2500592	TCR002	Creighton Final	Cl ₂ (F) OS*	1.48	-	mg Cl ₂ /L
22-Oct-25	2500592	TCR002	Creighton Final	Cl ₂ (T) OS*	1.60	-	mg Cl ₂ /L
22-Oct-25	2500593	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
22-Oct-25	2500592	TCR002	Creighton Final	Coll Time OS*	7:17	-	-
22-Oct-25	2500595	TCR002	Creighton Final	Conductivity	11.5	±1.5%	mS/m
22-Oct-25	2500593	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
22-Oct-25	2500593	TCR002	Creighton Final	HPC 37*	0	±21%	CFU/mL
22-Oct-25	2500592	TCR002	Creighton Final	pH OS*	7.30	-	-
22-Oct-25	2500592	TCR002	Creighton Final	Temperature OS*	19.3	-	°C
22-Oct-25	2500596	TCR002	Creighton Final	Turbidity	0.8	±6.1%	NTU
22-Oct-25	2500598	TCR004	Creighton Madondo Cottages	Cl ₂ (F) OS*	0.78	-	mg Cl ₂ /L
22-Oct-25	2500598	TCR004	Creighton Madondo Cottages	Cl ₂ (T) OS*	0.90	-	mg Cl ₂ /L
22-Oct-25	2500599	TCR004	Creighton Madondo Cottages	Coliforms*	0	±15%	MPN/100mL
22-Oct-25	2500598	TCR004	Creighton Madondo Cottages	Coll Time OS*	7:07	-	-
22-Oct-25	2500602	TCR004	Creighton Madondo Cottages	Colour	<1.00	±6.5%	mg Pt-Co/L
22-Oct-25	2500601	TCR004	Creighton Madondo Cottages	Conductivity	10.4	±1.5%	mS/m
22-Oct-25	2500599	TCR004	Creighton Madondo Cottages	E.coli*	0	±14%	MPN/100mL
22-Oct-25	2500599	TCR004	Creighton Madondo Cottages	HPC 37*	0	±21%	CFU/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

22-Oct-25	2500598	TCR004	Creighton Madondo Cottages	pH OS*	7.30	-	-
22-Oct-25	2500598	TCR004	Creighton Madondo Cottages	Temperature OS*	18.0	-	°C
22-Oct-25	2500602	TCR004	Creighton Madondo Cottages	Turbidity	0.8	±6.1%	NTU
22-Oct-25	2500617	THL003	Hlanganani Clinic Reticulation	Cl ₂ (F) OS*	0.35	-	mg Cl ₂ /L
22-Oct-25	2500617	THL003	Hlanganani Clinic Reticulation	Cl ₂ (T) OS*	0.40	-	mg Cl ₂ /L
22-Oct-25	2500618	THL003	Hlanganani Clinic Reticulation	Coliforms*	0	±15%	MPN/100mL
22-Oct-25	2500617	THL003	Hlanganani Clinic Reticulation	Coll Time OS*	10:04	-	-
22-Oct-25	2500618	THL003	Hlanganani Clinic Reticulation	E.coli*	0	±14%	MPN/100mL
22-Oct-25	2500618	THL003	Hlanganani Clinic Reticulation	HPC 37*	0	±21%	CFU/mL
22-Oct-25	2500617	THL003	Hlanganani Clinic Reticulation	pH OS*	7.40	-	-
22-Oct-25	2500617	THL003	Hlanganani Clinic Reticulation	Temperature OS*	22.0	-	°C
22-Oct-25	2500620	THL003	Hlanganani Clinic Reticulation	Turbidity	0.3	±6.1%	NTU
22-Oct-25	2500635	TMAN002	Mangwaneni Final	Cl ₂ (F) OS*	0.99	-	mg Cl ₂ /L
22-Oct-25	2500635	TMAN002	Mangwaneni Final	Cl ₂ (T) OS*	1.08	-	mg Cl ₂ /L
22-Oct-25	2500636	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
22-Oct-25	2500635	TMAN002	Mangwaneni Final	Coll Time OS*	9:53	-	-
22-Oct-25	2500639	TMAN002	Mangwaneni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
22-Oct-25	2500638	TMAN002	Mangwaneni Final	Conductivity	9.97	±1.5%	mS/m
22-Oct-25	2500636	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
22-Oct-25	2500636	TMAN002	Mangwaneni Final	HPC 37*	3	±21%	CFU/mL
22-Oct-25	2500639	TMAN002	Mangwaneni Final	Odour*	Nil	-	-
22-Oct-25	2500635	TMAN002	Mangwaneni Final	pH OS*	7.40	-	-
22-Oct-25	2500635	TMAN002	Mangwaneni Final	Temperature OS*	19.0	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

22-Oct-25	2500639	TMAN002	Mangwaneni Final	Turbidity	1.7	±6.1%	NTU
22-Oct-25	2500640	TMAN003	Mangwaneni Reticulation	Cl ₂ (F) OS*	0.72	-	mg Cl ₂ /L
22-Oct-25	2500640	TMAN003	Mangwaneni Reticulation	Cl ₂ (T) OS*	0.88	-	mg Cl ₂ /L
22-Oct-25	2500641	TMAN003	Mangwaneni Reticulation	Coliforms*	0	±15%	MPN/100mL
22-Oct-25	2500640	TMAN003	Mangwaneni Reticulation	Coll Time OS*	10:02	-	-
22-Oct-25	2500641	TMAN003	Mangwaneni Reticulation	E.coli*	0	±14%	MPN/100mL
22-Oct-25	2500641	TMAN003	Mangwaneni Reticulation	HPC 37*	0	±21%	CFU/mL
22-Oct-25	2500640	TMAN003	Mangwaneni Reticulation	pH OS*	7.30	-	-
22-Oct-25	2500640	TMAN003	Mangwaneni Reticulation	Temperature OS*	18.5	-	°C
22-Oct-25	2500643	TMAN003	Mangwaneni Reticulation	Turbidity	1.9	±6.1%	NTU
22-Oct-25	2500668	TRV002	Riverside Final	Cl ₂ (F) OS*	2.22	-	mg Cl ₂ /L
22-Oct-25	2500668	TRV002	Riverside Final	Cl ₂ (T) OS*	2.32	-	mg Cl ₂ /L
22-Oct-25	2500669	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
22-Oct-25	2500668	TRV002	Riverside Final	Coll Time OS*	7:46	-	-
22-Oct-25	2500672	TRV002	Riverside Final	Colour	<1.00	±6.5%	mg Pt-Co/L
22-Oct-25	2500671	TRV002	Riverside Final	Conductivity	8.80	±1.5%	mS/m
22-Oct-25	2500669	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
22-Oct-25	2500669	TRV002	Riverside Final	HPC 37*	0	±21%	CFU/mL
22-Oct-25	2500672	TRV002	Riverside Final	Odour*	Nil	-	-
22-Oct-25	2500668	TRV002	Riverside Final	pH OS*	7.40	-	-
22-Oct-25	2500668	TRV002	Riverside Final	Temperature OS*	19.0	-	°C
22-Oct-25	2500672	TRV002	Riverside Final	Turbidity	1.8	±6.1%	NTU
22-Oct-25	2500673	TRV003	Riverside Reticulation	Cl ₂ (F) OS*	1.05	-	mg Cl ₂ /L
22-Oct-25	2500673	TRV003	Riverside Reticulation	Cl ₂ (T) OS*	1.16	-	mg Cl ₂ /L
22-Oct-25	2500674	TRV003	Riverside Reticulation	Coliforms*	0	±15%	MPN/100mL
22-Oct-25	2500673	TRV003	Riverside Reticulation	Coll Time OS*	7:40	-	-
22-Oct-25	2500676	TRV003	Riverside Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
22-Oct-25	2500674	TRV003	Riverside Reticulation	E.coli*	0	±14%	MPN/100mL
22-Oct-25	2500674	TRV003	Riverside Reticulation	HPC 37*	0	±21%	CFU/mL
22-Oct-25	2500676	TRV003	Riverside Reticulation	Odour*	Nil	-	-
22-Oct-25	2500673	TRV003	Riverside Reticulation	pH OS*	7.30	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

22-Oct-25	2500673	TRV003	Riverside Reticulation	Temperature OS*	18.3	-	°C
22-Oct-25	2500676	TRV003	Riverside Reticulation	Turbidity	2.2	±6.1%	NTU
22-Oct-25	2500682	TST002	St Appollinaris Final	Cl ₂ (F) OS*	0.66	-	mg Cl ₂ /L
22-Oct-25	2500682	TST002	St Appollinaris Final	Cl ₂ (T) OS*	0.72	-	mg Cl ₂ /L
22-Oct-25	2500683	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
22-Oct-25	2500682	TST002	St Appollinaris Final	Coll Time OS*	8:20	-	-
22-Oct-25	2500686	TST002	St Appollinaris Final	Colour	<1.00	±6.5%	mg Pt-Co/L
22-Oct-25	2500685	TST002	St Appollinaris Final	Conductivity	8.89	±1.5%	mS/m
22-Oct-25	2500683	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
22-Oct-25	2500683	TST002	St Appollinaris Final	HPC 37*	0	±21%	CFU/mL
22-Oct-25	2500686	TST002	St Appollinaris Final	Odour*	Nil	-	-
22-Oct-25	2500682	TST002	St Appollinaris Final	pH OS*	7.40	-	-
22-Oct-25	2500682	TST002	St Appollinaris Final	Temperature OS*	20.2	-	°C
22-Oct-25	2500686	TST002	St Appollinaris Final	Turbidity	0.7	±6.1%	NTU
22-Oct-25	2500697	TUN002	Underberg Final	Al (AE)	125	±7.6%	µg Al/L
22-Oct-25	2500692	TUN002	Underberg Final	Cl ₂ (F) OS*	1.05	-	mg Cl ₂ /L
22-Oct-25	2500692	TUN002	Underberg Final	Cl ₂ (T) OS*	1.16	-	mg Cl ₂ /L
22-Oct-25	2500693	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
22-Oct-25	2500692	TUN002	Underberg Final	Coll Time OS*	8:38	-	-
22-Oct-25	2500696	TUN002	Underberg Final	Colour	1.00	±6.5%	mg Pt-Co/L
22-Oct-25	2500695	TUN002	Underberg Final	Conductivity	5.00	±1.5%	mS/m
22-Oct-25	2500693	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
22-Oct-25	2500693	TUN002	Underberg Final	HPC 37*	7	±21%	CFU/mL
22-Oct-25	2500696	TUN002	Underberg Final	Odour*	Nil	-	-
22-Oct-25	2500692	TUN002	Underberg Final	pH OS*	7.40	-	-
22-Oct-25	2500696	TUN002	Underberg Final	Taste*	Nil	-	-
22-Oct-25	2500692	TUN002	Underberg Final	Temperature OS*	18.9	-	°C
22-Oct-25	2500696	TUN002	Underberg Final	Turbidity	1.0	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

23-Oct-25	2501230	TMZ002	Umzimkhulu Final	Al (AE)	218	±7.6%	µg Al/L
23-Oct-25	2501225	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	0.98	-	mg Cl ₂ /L
23-Oct-25	2501225	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	1.10	-	mg Cl ₂ /L
23-Oct-25	2501226	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
23-Oct-25	2501226	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10mL
23-Oct-25	2501225	TMZ002	Umzimkhulu Final	Coll Time OS*	07:30	-	-
23-Oct-25	2501228	TMZ002	Umzimkhulu Final	Conductivity	11.4	±1.5%	mS/m
23-Oct-25	2501226	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
23-Oct-25	2501226	TMZ002	Umzimkhulu Final	HPC 37*	1	±21%	CFU/mL
23-Oct-25	2501225	TMZ002	Umzimkhulu Final	pH OS*	7.20	-	-
23-Oct-25	2501225	TMZ002	Umzimkhulu Final	Temperature OS*	21.8	-	°C
23-Oct-25	2501229	TMZ002	Umzimkhulu Final	Turbidity	2.3	±6.1%	NTU
23-Oct-25	2501231	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (F) OS*	1.30	-	mg Cl ₂ /L
23-Oct-25	2501231	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (T) OS*	1.45	-	mg Cl ₂ /L
23-Oct-25	2501232	TMZ004	Umzikhulu Informal Settlement Retic	Coliforms*	8	±15%	MPN/100mL
23-Oct-25	2501231	TMZ004	Umzikhulu Informal Settlement Retic	Coll Time OS*	08:15	-	-
23-Oct-25	2501235	TMZ004	Umzikhulu Informal Settlement Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
23-Oct-25	2501234	TMZ004	Umzikhulu Informal Settlement Retic	Conductivity	11.6	±1.5%	mS/m
23-Oct-25	2501232	TMZ004	Umzikhulu Informal Settlement Retic	E.coli*	0	±14%	MPN/100mL
23-Oct-25	2501232	TMZ004	Umzikhulu Informal Settlement Retic	HPC 37*	0	±21%	CFU/mL
23-Oct-25	2501235	TMZ004	Umzikhulu Informal Settlement Retic	Odour*	Nil	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

23-Oct-25	2501231	TMZ004	Umzikhulu Informal Settlement Retic	pH OS*	7.40	-	-
23-Oct-25	2501231	TMZ004	Umzikhulu Informal Settlement Retic	Temperature OS*	22.3	-	°C
23-Oct-25	2501235	TMZ004	Umzikhulu Informal Settlement Retic	Turbidity	2.7	±6.1%	NTU
23-Oct-25	2501236	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (F) OS*	0.45	-	mg Cl ₂ /L
23-Oct-25	2501236	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (T) OS*	0.49	-	mg Cl ₂ /L
23-Oct-25	2501237	TMZ005	Umzimkhulu Local Municipality Offices	Coliforms*	0	±15%	MPN/100mL
23-Oct-25	2501236	TMZ005	Umzimkhulu Local Municipality Offices	Coll Time OS*	07:59	-	-
23-Oct-25	2501240	TMZ005	Umzimkhulu Local Municipality Offices	Colour	<1.00	±6.5%	mg Pt-Co/L
23-Oct-25	2501239	TMZ005	Umzimkhulu Local Municipality Offices	Conductivity	11.6	±1.5%	mS/m
23-Oct-25	2501237	TMZ005	Umzimkhulu Local Municipality Offices	E.coli*	0	±14%	MPN/100mL
23-Oct-25	2501237	TMZ005	Umzimkhulu Local Municipality Offices	HPC 37*	1	±21%	CFU/mL
23-Oct-25	2501236	TMZ005	Umzimkhulu Local Municipality Offices	pH OS*	7.10	-	-
23-Oct-25	2501236	TMZ005	Umzimkhulu Local Municipality Offices	Temperature OS*	21.5	-	°C
23-Oct-25	2501240	TMZ005	Umzimkhulu Local Municipality Offices	Turbidity	3.1	±6.1%	NTU
23-Oct-25	2501241	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (F) OS*	0.31	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

23-Oct-25	2501241	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (T) OS*	0.47	-	mg Cl ₂ /L
23-Oct-25	2501242	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coliforms*	1	±15%	MPN/100mL
23-Oct-25	2501241	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coll Time OS*	07:55	-	-
23-Oct-25	2501245	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
23-Oct-25	2501244	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Conductivity	11.5	±1.5%	mS/m
23-Oct-25	2501242	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
23-Oct-25	2501242	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	HPC 37*	0	±21%	CFU/mL
23-Oct-25	2501241	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	pH OS*	7.20	-	-
23-Oct-25	2501241	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Temperature OS*	19.9	-	°C
23-Oct-25	2501245	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Turbidity	2.7	±6.1%	NTU
23-Oct-25	2501256	TNO002	Nokweja Final	Al (AE)	427	±7.6%	µg Al/L
23-Oct-25	2501251	TNO002	Nokweja Final	Cl ₂ (F) OS*	1.84	-	mg Cl ₂ /L
23-Oct-25	2501251	TNO002	Nokweja Final	Cl ₂ (T) OS*	1.90	-	mg Cl ₂ /L
23-Oct-25	2501252	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
23-Oct-25	2501252	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10mL
23-Oct-25	2501251	TNO002	Nokweja Final	Coll Time OS*	7:25	-	-
23-Oct-25	2501255	TNO002	Nokweja Final	Colour	<1.00	±6.5%	mg Pt-Co/L
23-Oct-25	2501254	TNO002	Nokweja Final	Conductivity	11.1	±1.5%	mS/m
23-Oct-25	2501252	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
23-Oct-25	2501252	TNO002	Nokweja Final	HPC 37*	3	±21%	CFU/mL
23-Oct-25	2501255	TNO002	Nokweja Final	Odour*	Nil	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

23-Oct-25	2501251	TNO002	Nokweja Final	pH OS*	7.30	-	-
23-Oct-25	2501251	TNO002	Nokweja Final	Temperature OS*	20.3	-	°C
23-Oct-25	2501255	TNO002	Nokweja Final	Turbidity	4.0	±6.1%	NTU
23-Oct-25	2501257	TNO003	Nokweja Standpipe A Reticulation	Cl ₂ (F) OS*	0.44	-	mg Cl ₂ /L
23-Oct-25	2501257	TNO003	Nokweja Standpipe A Reticulation	Cl ₂ (T) OS*	0.56	-	mg Cl ₂ /L
23-Oct-25	2501258	TNO003	Nokweja Standpipe A Reticulation	Coliforms*	0	±15%	MPN/100mL
23-Oct-25	2501257	TNO003	Nokweja Standpipe A Reticulation	Coll Time OS*	07:12	-	-
23-Oct-25	2501261	TNO003	Nokweja Standpipe A Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
23-Oct-25	2501260	TNO003	Nokweja Standpipe A Reticulation	Conductivity	11.5	±1.5%	mS/m
23-Oct-25	2501258	TNO003	Nokweja Standpipe A Reticulation	E.coli*	0	±14%	MPN/100mL
23-Oct-25	2501258	TNO003	Nokweja Standpipe A Reticulation	HPC 37*	39	±21%	CFU/mL
23-Oct-25	2501261	TNO003	Nokweja Standpipe A Reticulation	Odour*	Nil	-	-
23-Oct-25	2501257	TNO003	Nokweja Standpipe A Reticulation	pH OS*	7.30	-	-
23-Oct-25	2501257	TNO003	Nokweja Standpipe A Reticulation	Temperature OS*	20.6	-	°C
23-Oct-25	2501261	TNO003	Nokweja Standpipe A Reticulation	Turbidity	6.4	±6.1%	NTU
23-Oct-25	2501262	TNO004	Nokweja Standpipe B Reticulation	Cl ₂ (F) OS*	0.50	-	mg Cl ₂ /L
23-Oct-25	2501262	TNO004	Nokweja Standpipe B Reticulation	Cl ₂ (T) OS*	0.60	-	mg Cl ₂ /L
23-Oct-25	2501263	TNO004	Nokweja Standpipe B Reticulation	Coliforms*	0	±15%	MPN/100mL
23-Oct-25	2501262	TNO004	Nokweja Standpipe B Reticulation	Coll Time OS*	7:05	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

23-Oct-25	2501266	TNO004	Nokweja Standpipe B Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
23-Oct-25	2501265	TNO004	Nokweja Standpipe B Reticulation	Conductivity	11.2	±1.5%	mS/m
23-Oct-25	2501263	TNO004	Nokweja Standpipe B Reticulation	E.coli*	0	±14%	MPN/100mL
23-Oct-25	2501263	TNO004	Nokweja Standpipe B Reticulation	HPC 37*	10	±21%	CFU/mL
23-Oct-25	2501266	TNO004	Nokweja Standpipe B Reticulation	Odour*	Nil	-	-
23-Oct-25	2501262	TNO004	Nokweja Standpipe B Reticulation	pH OS*	7.40	-	-
23-Oct-25	2501262	TNO004	Nokweja Standpipe B Reticulation	Temperature OS*	21.2	-	°C
23-Oct-25	2501266	TNO004	Nokweja Standpipe B Reticulation	Turbidity	4.9	±6.1%	NTU
23-Oct-25	2501301	TWA002	Washbank Final	Al (AE)	1481	±7.6%	µg Al/L
23-Oct-25	2501296	TWA002	Washbank Final	Cl ₂ (F) OS*	0.95	-	mg Cl ₂ /L
23-Oct-25	2501296	TWA002	Washbank Final	Cl ₂ (T) OS*	1.02	-	mg Cl ₂ /L
23-Oct-25	2501297	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
23-Oct-25	2501296	TWA002	Washbank Final	Coll Time OS*	06:47	-	-
23-Oct-25	2501300	TWA002	Washbank Final	Colour	1.40	±6.5%	mg Pt-Co/L
23-Oct-25	2501299	TWA002	Washbank Final	Conductivity	8.95	±1.5%	mS/m
23-Oct-25	2501297	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
23-Oct-25	2501297	TWA002	Washbank Final	HPC 37*	9	±21%	CFU/mL
23-Oct-25	2501300	TWA002	Washbank Final	Odour*	Nil	-	-
23-Oct-25	2501296	TWA002	Washbank Final	pH OS*	7.20	-	-
23-Oct-25	2501296	TWA002	Washbank Final	Temperature OS*	20.5	-	°C
23-Oct-25	2501300	TWA002	Washbank Final	Turbidity	6.4	±6.1%	NTU
24-Oct-25	2501494	TIB002	Ibisi Final	Al (AE)	459	±7.6%	µg Al/L
24-Oct-25	2501489	TIB002	Ibisi Final	Cl ₂ (F) OS*	0.36	-	mg Cl ₂ /L
24-Oct-25	2501489	TIB002	Ibisi Final	Cl ₂ (T) OS*	0.43	-	mg Cl ₂ /L
24-Oct-25	2501490	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
24-Oct-25	2501490	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

24-Oct-25	2501489	TIB002	Ibisi Final	Coll Time OS*	06:32	-	-
24-Oct-25	2501493	TIB002	Ibisi Final	Colour	<1.00	±6.5%	mg Pt-Co/L
24-Oct-25	2501492	TIB002	Ibisi Final	Conductivity	12.2	±1.5%	mS/m
24-Oct-25	2501490	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
24-Oct-25	2501490	TIB002	Ibisi Final	HPC 37*	3	±21%	CFU/mL
24-Oct-25	2501493	TIB002	Ibisi Final	Odour*	Nil	-	-
24-Oct-25	2501489	TIB002	Ibisi Final	pH OS*	7.40	-	-
24-Oct-25	2501489	TIB002	Ibisi Final	Temperature OS*	21.7	-	°C
24-Oct-25	2501493	TIB002	Ibisi Final	Turbidity	4.9	±6.1%	NTU
24-Oct-25	2501495	TIB003	Ibisi Police Station Reticulation	Cl ₂ (F) OS*	0.28	-	mg Cl ₂ /L
24-Oct-25	2501495	TIB003	Ibisi Police Station Reticulation	Cl ₂ (T) OS*	0.36	-	mg Cl ₂ /L
24-Oct-25	2501496	TIB003	Ibisi Police Station Reticulation	Coliforms*	0	±15%	MPN/100mL
24-Oct-25	2501495	TIB003	Ibisi Police Station Reticulation	Coll Time OS*	06:42	-	-
24-Oct-25	2501496	TIB003	Ibisi Police Station Reticulation	E.coli*	0	±14%	MPN/100mL
24-Oct-25	2501496	TIB003	Ibisi Police Station Reticulation	HPC 37*	1	±21%	CFU/mL
24-Oct-25	2501495	TIB003	Ibisi Police Station Reticulation	pH OS*	7.60	-	-
24-Oct-25	2501495	TIB003	Ibisi Police Station Reticulation	Temperature OS*	21.0	-	°C
24-Oct-25	2501498	TIB003	Ibisi Police Station Reticulation	Turbidity	2.8	±6.1%	NTU
24-Oct-25	2501503	TRT002	Rietvlei Final	Cl ₂ (F) OS*	0.64	-	mg Cl ₂ /L
24-Oct-25	2501503	TRT002	Rietvlei Final	Cl ₂ (T) OS*	0.72	-	mg Cl ₂ /L
24-Oct-25	2501504	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
24-Oct-25	2501503	TRT002	Rietvlei Final	Coll Time OS*	05:37	-	-
24-Oct-25	2501506	TRT002	Rietvlei Final	Conductivity	18.5	±1.5%	mS/m
24-Oct-25	2501504	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
24-Oct-25	2501504	TRT002	Rietvlei Final	HPC 37*	2	±21%	CFU/mL
24-Oct-25	2501503	TRT002	Rietvlei Final	pH OS*	7.40	-	-
24-Oct-25	2501503	TRT002	Rietvlei Final	Temperature OS*	19.2	-	°C
24-Oct-25	2501507	TRT002	Rietvlei Final	Turbidity	4.1	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

24-Oct-25	2501508	TRT004	Rietvlei Hospital Reticulation	Cl ₂ (F) OS*	0.54	-	mg Cl ₂ /L
24-Oct-25	2501508	TRT004	Rietvlei Hospital Reticulation	Cl ₂ (T) OS*	0.65	-	mg Cl ₂ /L
24-Oct-25	2501509	TRT004	Rietvlei Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
24-Oct-25	2501508	TRT004	Rietvlei Hospital Reticulation	Coll Time OS*	05:51	-	-
24-Oct-25	2501512	TRT004	Rietvlei Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
24-Oct-25	2501511	TRT004	Rietvlei Hospital Reticulation	Conductivity	18.8	±1.5%	mS/m
24-Oct-25	2501509	TRT004	Rietvlei Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
24-Oct-25	2501509	TRT004	Rietvlei Hospital Reticulation	HPC 37*	0	±21%	CFU/mL
24-Oct-25	2501508	TRT004	Rietvlei Hospital Reticulation	pH OS*	7.20	-	-
24-Oct-25	2501508	TRT004	Rietvlei Hospital Reticulation	Temperature OS*	19.4	-	°C
24-Oct-25	2501512	TRT004	Rietvlei Hospital Reticulation	Turbidity	2.4	±6.1%	NTU
27-Oct-25	2502566	TFR002	Franklin Final	Al (AE)	108	±7.6%	µg Al/L
27-Oct-25	2502561	TFR002	Franklin Final	Cl ₂ (F) OS*	0.82	-	mg Cl ₂ /L
27-Oct-25	2502561	TFR002	Franklin Final	Cl ₂ (T) OS*	0.90	-	mg Cl ₂ /L
27-Oct-25	2502562	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
27-Oct-25	2502562	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10mL
27-Oct-25	2502561	TFR002	Franklin Final	Coll Time OS*	08:07	-	-
27-Oct-25	2502564	TFR002	Franklin Final	Conductivity	10.9	±1.5%	mS/m
27-Oct-25	2502562	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
27-Oct-25	2502562	TFR002	Franklin Final	HPC 37*	0	±21%	CFU/mL
27-Oct-25	2502561	TFR002	Franklin Final	pH OS*	7.20	-	-
27-Oct-25	2502561	TFR002	Franklin Final	Temperature OS*	18.0	-	°C
27-Oct-25	2502565	TFR002	Franklin Final	Turbidity	1.3	±6.1%	NTU
27-Oct-25	2502577	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
27-Oct-25	2502572	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.75	-	mg Cl ₂ /L
27-Oct-25	2502572	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.84	-	mg Cl ₂ /L
27-Oct-25	2502573	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
27-Oct-25	2502573	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10mL
27-Oct-25	2502572	TKK002	Kokstad Final	Coll Time OS*	08:48	-	-
27-Oct-25	2502575	TKK002	Kokstad Final	Conductivity	15.6	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

27-Oct-25	2502573	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
27-Oct-25	2502573	TKK002	Kokstad Final	HPC 37*	0	±21%	CFU/mL
27-Oct-25	2502572	TKK002	Kokstad Final	pH OS*	7.30	-	-
27-Oct-25	2502572	TKK002	Kokstad Final	Temperature OS*	18.2	-	°C
27-Oct-25	2502576	TKK002	Kokstad Final	Turbidity	0.2	±6.1%	NTU
27-Oct-25	2502583	TKK011	Kokstad Hospital Reticulation	Cl ₂ (F) OS*	0.84	-	mg Cl ₂ /L
27-Oct-25	2502583	TKK011	Kokstad Hospital Reticulation	Cl ₂ (T) OS*	0.92	-	mg Cl ₂ /L
27-Oct-25	2502584	TKK011	Kokstad Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
27-Oct-25	2502583	TKK011	Kokstad Hospital Reticulation	Coll Time OS*	08:20	-	-
27-Oct-25	2502587	TKK011	Kokstad Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
27-Oct-25	2502586	TKK011	Kokstad Hospital Reticulation	Conductivity	16.0	±1.5%	mS/m
27-Oct-25	2502584	TKK011	Kokstad Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
27-Oct-25	2502584	TKK011	Kokstad Hospital Reticulation	HPC 37*	0	±21%	CFU/mL
27-Oct-25	2502583	TKK011	Kokstad Hospital Reticulation	pH OS*	7.40	-	-
27-Oct-25	2502583	TKK011	Kokstad Hospital Reticulation	Temperature OS*	20.4	-	°C
27-Oct-25	2502587	TKK011	Kokstad Hospital Reticulation	Turbidity	0.3	±6.1%	NTU
27-Oct-25	2502610	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	0.94	-	mg Cl ₂ /L
27-Oct-25	2502610	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	1.02	-	mg Cl ₂ /L
27-Oct-25	2502611	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
27-Oct-25	2502610	TNJU002	KwaNjunga Final	Coll Time OS*	7.30	-	-
27-Oct-25	2502613	TNJU002	KwaNjunga Final	Conductivity	21.2	±1.5%	mS/m
27-Oct-25	2502611	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
27-Oct-25	2502611	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	CFU/mL
27-Oct-25	2502610	TNJU002	KwaNjunga Final	pH OS*	7.00	-	-
27-Oct-25	2502610	TNJU002	KwaNjunga Final	Temperature OS*	17.5	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,

Telephone (033) 341 1111

E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

27-Oct-25	2502614	TNJU002	KwaNjunga Final	Turbidity	0.3	±6.1%	NTU
28-Oct-25	2503515	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (F) OS*	0.46	-	mg Cl2/L
28-Oct-25	2503515	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (T) OS*	0.66	-	mg Cl2/L
28-Oct-25	2503516	TJO001	Jolivet RRT frn Vulamehlo	Coliforms*	0	±15%	MPN/100mL
28-Oct-25	2503515	TJO001	Jolivet RRT frn Vulamehlo	Coll Time OS*	9:49	-	-
28-Oct-25	2503516	TJO001	Jolivet RRT frn Vulamehlo	E.coli*	0	±14%	MPN/100mL
28-Oct-25	2503516	TJO001	Jolivet RRT frn Vulamehlo	HPC 37*	0	±21%	CFU/mL
28-Oct-25	2503515	TJO001	Jolivet RRT frn Vulamehlo	pH OS*	7.34	-	-
28-Oct-25	2503515	TJO001	Jolivet RRT frn Vulamehlo	Temperature OS*	18.5	-	°C
28-Oct-25	2503518	TJO001	Jolivet RRT frn Vulamehlo	Turbidity	1.3	±6.1%	NTU
28-Oct-25	2503577	TSQ002	Esiqanduleni Final	Al (AE)	300	±7.6%	µg Al/L
28-Oct-25	2503572	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	0.67	-	mg Cl2/L
28-Oct-25	2503572	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	0.72	-	mg Cl2/L
28-Oct-25	2503573	TSQ002	Esiqanduleni Final	Coliforms*	2	±15%	MPN/100mL
28-Oct-25	2503572	TSQ002	Esiqanduleni Final	Coll Time OS*	7:25	-	-
28-Oct-25	2503575	TSQ002	Esiqanduleni Final	Conductivity	11.7	±1.5%	mS/m
28-Oct-25	2503573	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
28-Oct-25	2503573	TSQ002	Esiqanduleni Final	HPC 37*	16	±21%	CFU/mL
28-Oct-25	2503572	TSQ002	Esiqanduleni Final	pH OS*	7.30	-	-
28-Oct-25	2503572	TSQ002	Esiqanduleni Final	Temperature OS*	18.9	-	°C
28-Oct-25	2503576	TSQ002	Esiqanduleni Final	Turbidity	4.0	±6.1%	NTU
29-Oct-25	2504164	TBU002	Bulwer Final	Cl2 (F) OS*	1.14	-	mg Cl2/L
29-Oct-25	2504164	TBU002	Bulwer Final	Cl2 (T) OS*	1.26	-	mg Cl2/L
29-Oct-25	2504165	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
29-Oct-25	2504164	TBU002	Bulwer Final	Coll Time OS*	09:40	-	-
29-Oct-25	2504167	TBU002	Bulwer Final	Conductivity	5.56	±1.5%	mS/m
29-Oct-25	2504165	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
29-Oct-25	2504165	TBU002	Bulwer Final	HPC 37*	0	±21%	CFU/mL
29-Oct-25	2504164	TBU002	Bulwer Final	pH OS*	7.30	-	-
29-Oct-25	2504164	TBU002	Bulwer Final	Temperature OS*	20.5	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,

Telephone (033) 341 1111

E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

29-Oct-25	2504168	TBU002	Bulwer Final	Turbidity	3.7	±6.1%	NTU
29-Oct-25	2504179	TCR002	Creighton Final	Al (AE)	202	±7.6%	µg Al/L
29-Oct-25	2504174	TCR002	Creighton Final	Cl ₂ (F) OS*	1.57	-	mg Cl ₂ /L
29-Oct-25	2504174	TCR002	Creighton Final	Cl ₂ (T) OS*	1.64	-	mg Cl ₂ /L
29-Oct-25	2504175	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
29-Oct-25	2504174	TCR002	Creighton Final	Coll Time OS*	07:25	-	-
29-Oct-25	2504177	TCR002	Creighton Final	Conductivity	11.7	±1.5%	mS/m
29-Oct-25	2504175	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
29-Oct-25	2504175	TCR002	Creighton Final	HPC 37*	0	±21%	CFU/mL
29-Oct-25	2504174	TCR002	Creighton Final	pH OS*	7.30	-	-
29-Oct-25	2504174	TCR002	Creighton Final	Temperature OS*	19.4	-	°C
29-Oct-25	2504178	TCR002	Creighton Final	Turbidity	0.6	±6.1%	NTU
29-Oct-25	2504198	TMAN002	Mangwaneni Final	Cl ₂ (F) OS*	0.88	-	mg Cl ₂ /L
29-Oct-25	2504198	TMAN002	Mangwaneni Final	Cl ₂ (T) OS*	0.98	-	mg Cl ₂ /L
29-Oct-25	2504199	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
29-Oct-25	2504198	TMAN002	Mangwaneni Final	Coll Time OS*	10:30	-	-
29-Oct-25	2504201	TMAN002	Mangwaneni Final	Conductivity	10.7	±1.5%	mS/m
29-Oct-25	2504199	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
29-Oct-25	2504199	TMAN002	Mangwaneni Final	HPC 37*	1	±21%	CFU/mL
29-Oct-25	2504198	TMAN002	Mangwaneni Final	pH OS*	7.50	-	-
29-Oct-25	2504198	TMAN002	Mangwaneni Final	Temperature OS*	21.3	-	°C
29-Oct-25	2504202	TMAN002	Mangwaneni Final	Turbidity	4.0	±6.1%	NTU
29-Oct-25	2504207	TMQA002	Mqatsheni Final	Cl ₂ (F) OS*	0.82	-	mg Cl ₂ /L
29-Oct-25	2504207	TMQA002	Mqatsheni Final	Cl ₂ (T) OS*	0.95	-	mg Cl ₂ /L
29-Oct-25	2504208	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
29-Oct-25	2504207	TMQA002	Mqatsheni Final	Coll Time OS*	08:00	-	-
29-Oct-25	2504210	TMQA002	Mqatsheni Final	Conductivity	24.5	±1.5%	mS/m
29-Oct-25	2504208	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
29-Oct-25	2504208	TMQA002	Mqatsheni Final	HPC 37*	48	±21%	CFU/mL
29-Oct-25	2504207	TMQA002	Mqatsheni Final	pH OS*	8.90	-	-
29-Oct-25	2504207	TMQA002	Mqatsheni Final	Temperature OS*	18.5	-	°C
29-Oct-25	2504211	TMQA002	Mqatsheni Final	Turbidity	6.8	±6.1%	NTU
29-Oct-25	2504217	TRV002	Riverside Final	Cl ₂ (F) OS*	2.04	-	mg Cl ₂ /L
29-Oct-25	2504217	TRV002	Riverside Final	Cl ₂ (T) OS*	2.12	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,

Telephone (033) 341 1111

E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

29-Oct-25	2504218	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
29-Oct-25	2504217	TRV002	Riverside Final	Coll Time OS*	08:25	-	-
29-Oct-25	2504220	TRV002	Riverside Final	Conductivity	9.05	±1.5%	mS/m
29-Oct-25	2504218	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
29-Oct-25	2504218	TRV002	Riverside Final	HPC 37*	0	±21%	CFU/mL
29-Oct-25	2504217	TRV002	Riverside Final	pH OS*	7.30	-	-
29-Oct-25	2504217	TRV002	Riverside Final	Temperature OS*	19.4	-	°C
29-Oct-25	2504221	TRV002	Riverside Final	Turbidity	1.0	±6.1%	NTU
29-Oct-25	2504227	TST002	St Appollinaris Final	Cl ₂ (F) OS*	0.66	-	mg Cl ₂ /L
29-Oct-25	2504227	TST002	St Appollinaris Final	Cl ₂ (T) OS*	0.77	-	mg Cl ₂ /L
29-Oct-25	2504228	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
29-Oct-25	2504227	TST002	St Appollinaris Final	Coll Time OS*	09:10	-	-
29-Oct-25	2504230	TST002	St Appollinaris Final	Conductivity	6.87	±1.5%	mS/m
29-Oct-25	2504228	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
29-Oct-25	2504228	TST002	St Appollinaris Final	HPC 37*	5	±21%	CFU/mL
29-Oct-25	2504227	TST002	St Appollinaris Final	pH OS*	7.30	-	-
29-Oct-25	2504227	TST002	St Appollinaris Final	Temperature OS*	20.2	-	°C
29-Oct-25	2504231	TST002	St Appollinaris Final	Turbidity	1.9	±6.1%	NTU
29-Oct-25	2504247	TUN002	Underberg Final	Al (AE)	52.5	±7.6%	µg Al/L
29-Oct-25	2504242	TUN002	Underberg Final	Cl ₂ (F) OS*	0.50	-	mg Cl ₂ /L
29-Oct-25	2504242	TUN002	Underberg Final	Cl ₂ (T) OS*	0.62	-	mg Cl ₂ /L
29-Oct-25	2504243	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
29-Oct-25	2504242	TUN002	Underberg Final	Coll Time OS*	08:49	-	-
29-Oct-25	2504245	TUN002	Underberg Final	Conductivity	4.91	±1.5%	mS/m
29-Oct-25	2504243	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
29-Oct-25	2504243	TUN002	Underberg Final	HPC 37*	2	±21%	CFU/mL
29-Oct-25	2504242	TUN002	Underberg Final	pH OS*	7.00	-	-
29-Oct-25	2504242	TUN002	Underberg Final	Temperature OS*	18.9	-	°C
29-Oct-25	2504246	TUN002	Underberg Final	Turbidity	0.8	±6.1%	NTU
30-Oct-25	2504718	TMZ002	Umzimkhulu Final	Al (AE)	234	±7.6%	µg Al/L
30-Oct-25	2504713	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	0.19	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

30-Oct-25	2504713	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	0.21	-	mg Cl ₂ /L
30-Oct-25	2504714	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
30-Oct-25	2504714	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10mL
30-Oct-25	2504713	TMZ002	Umzimkhulu Final	Coll Time OS*	06:32	-	-
30-Oct-25	2504717	TMZ002	Umzimkhulu Final	Colour	<1.00	±6.5%	mg Pt-Co/L
30-Oct-25	2504716	TMZ002	Umzimkhulu Final	Conductivity	9.56	±1.5%	mS/m
30-Oct-25	2504714	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
30-Oct-25	2504714	TMZ002	Umzimkhulu Final	HPC 37*	7	±21%	CFU/mL
30-Oct-25	2504717	TMZ002	Umzimkhulu Final	Odour*	Nil	-	-
30-Oct-25	2504713	TMZ002	Umzimkhulu Final	pH OS*	7.10	-	-
30-Oct-25	2504713	TMZ002	Umzimkhulu Final	Temperature OS*	20.1	-	°C
30-Oct-25	2504717	TMZ002	Umzimkhulu Final	Turbidity	3.9	±6.1%	NTU
30-Oct-25	2504729	TNO002	Nokweja Final	Al (AE)	178	±7.6%	µg Al/L
30-Oct-25	2504724	TNO002	Nokweja Final	Cl ₂ (F) OS*	0.48	-	mg Cl ₂ /L
30-Oct-25	2504724	TNO002	Nokweja Final	Cl ₂ (T) OS*	0.54	-	mg Cl ₂ /L
30-Oct-25	2504725	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
30-Oct-25	2504725	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10mL
30-Oct-25	2504724	TNO002	Nokweja Final	Coll Time OS*	07:12	-	-
30-Oct-25	2504727	TNO002	Nokweja Final	Conductivity	10.0	±1.5%	mS/m
30-Oct-25	2504725	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
30-Oct-25	2504725	TNO002	Nokweja Final	HPC 37*	5	±21%	CFU/mL
30-Oct-25	2504724	TNO002	Nokweja Final	pH OS*	7.20	-	-
30-Oct-25	2504724	TNO002	Nokweja Final	Temperature OS*	18.6	-	°C
30-Oct-25	2504728	TNO002	Nokweja Final	Turbidity	2.8	±6.1%	NTU
30-Oct-25	2504764	TWA002	Washbank Final	Al (AE)	777	±7.6%	µg Al/L
30-Oct-25	2504759	TWA002	Washbank Final	Cl ₂ (F) OS*	0.72	-	mg Cl ₂ /L
30-Oct-25	2504759	TWA002	Washbank Final	Cl ₂ (T) OS*	0.80	-	mg Cl ₂ /L
30-Oct-25	2504760	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
30-Oct-25	2504759	TWA002	Washbank Final	Coll Time OS*	06:05	-	-
30-Oct-25	2504762	TWA002	Washbank Final	Conductivity	14.1	±1.5%	mS/m
30-Oct-25	2504760	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
30-Oct-25	2504760	TWA002	Washbank Final	HPC 37*	3	±21%	CFU/mL
30-Oct-25	2504759	TWA002	Washbank Final	pH OS*	7.00	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

30-Oct-25	2504759	TWA002	Washbank Final	Temperature OS*	18.6	-	°C
30-Oct-25	2504763	TWA002	Washbank Final	Turbidity	4.5	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)