

Date: 13 September 2025

The Executive Director: Water Services Department

Harry Gwala District Municipality

40 Main Street

Ixopo

3276

Attention: Basetsana Khathalib and Bheki Nene

SEPTEMBER 2025 TREATED WATER (FINAL) RESULTS

Please find September 2025 Treated Water (Final) results tabulated below for samples received during September 2025. Determinands marked with an asterix are unaccredited and are not included in uMngeni-uThukela Water's schedule of accreditation.

Please contact us immediately should you have any queries.

Yours' Sincerely

Mr M Sewcharan

Client Services Manager

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Sample Date	Sample Number	Sampling Point	Description	Determinand	Result	UOM	Unit
01-Sep-25	2465544	TFR002	Franklin Final	Al (AE)	267	±7.6%	µg Al/L
01-Sep-25	2465539	TFR002	Franklin Final	Batch No.*	20250201	-	-
01-Sep-25	2465539	TFR002	Franklin Final	Cl ₂ (F) OS*	0.85	-	mg Cl ₂ /L
01-Sep-25	2465539	TFR002	Franklin Final	Cl ₂ (T) OS*	0.97	-	mg Cl ₂ /L
01-Sep-25	2465540	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
01-Sep-25	2465540	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
01-Sep-25	2465539	TFR002	Franklin Final	Coll Time OS*	07:52	-	-
01-Sep-25	2465542	TFR002	Franklin Final	Conductivity	13.5	±1.5%	mS/m
01-Sep-25	2465540	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
01-Sep-25	2465540	TFR002	Franklin Final	HPC 37*	0	±21%	cfu/mL
01-Sep-25	2465539	TFR002	Franklin Final	pH OS*	7.40	-	-
01-Sep-25	2465539	TFR002	Franklin Final	Temperature OS*	11.5	-	°C
01-Sep-25	2465543	TFR002	Franklin Final	Turbidity	1.8	±6.1%	NTU
01-Sep-25	2465555	TKK002	Kokstad Final	Al (AE)	30.2	±7.6%	µg Al/L
01-Sep-25	2465550	TKK002	Kokstad Final	Batch No.*	20250401	-	-
01-Sep-25	2465550	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.60	-	mg Cl ₂ /L
01-Sep-25	2465550	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.70	-	mg Cl ₂ /L
01-Sep-25	2465551	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
01-Sep-25	2465551	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
01-Sep-25	2465550	TKK002	Kokstad Final	Coll Time OS*	09:38	-	-
01-Sep-25	2465553	TKK002	Kokstad Final	Conductivity	14.1	±1.5%	mS/m
01-Sep-25	2465551	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
01-Sep-25	2465551	TKK002	Kokstad Final	HPC 37*	4	±21%	cfu/mL
01-Sep-25	2465550	TKK002	Kokstad Final	pH OS*	7.30	-	-
01-Sep-25	2465550	TKK002	Kokstad Final	Temperature OS*	14.3	-	°C
01-Sep-25	2465554	TKK002	Kokstad Final	Turbidity	0.5	±6.1%	NTU
01-Sep-25	2465561	TKK011	Kokstad Hospital Reticulation	Batch No.*	20250401	-	-
01-Sep-25	2465561	TKK011	Kokstad Hospital Reticulation	Cl ₂ (F) OS*	0.89	-	mg Cl ₂ /L
01-Sep-25	2465561	TKK011	Kokstad Hospital Reticulation	Cl ₂ (T) OS*	0.94	-	mg Cl ₂ /L
01-Sep-25	2465562	TKK011	Kokstad Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
01-Sep-25	2465561	TKK011	Kokstad Hospital Reticulation	Coll Time OS*	09:02	-	-
01-Sep-25	2465562	TKK011	Kokstad Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
01-Sep-25	2465562	TKK011	Kokstad Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
01-Sep-25	2465561	TKK011	Kokstad Hospital Reticulation	pH OS*	7.30	-	-
01-Sep-25	2465561	TKK011	Kokstad Hospital Reticulation	Temperature OS*	13.4	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

01-Sep-25	2465564	TKK011	Kokstad Hospital Reticulation	Turbidity	0.3	±6.1%	NTU
01-Sep-25	2465587	TNJU002	KwaNjunga Final	Batch No.*	20250201	-	-
01-Sep-25	2465587	TNJU002	KwaNjunga Final	Cl2 (F) OS*	1.05	-	mg Cl2/L
01-Sep-25	2465587	TNJU002	KwaNjunga Final	Cl2 (T) OS*	1.10	-	mg Cl2/L
01-Sep-25	2465588	TNJU002	KwaNjunga Final	Coliforms*	3	±15%	MPN/100mL
01-Sep-25	2465587	TNJU002	KwaNjunga Final	Coll Time OS*	07:10	-	-
01-Sep-25	2465590	TNJU002	KwaNjunga Final	Conductivity	18.2	±1.5%	mS/m
01-Sep-25	2465588	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
01-Sep-25	2465588	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	cfu/mL
01-Sep-25	2465587	TNJU002	KwaNjunga Final	pH OS*	7.50	-	-
01-Sep-25	2465587	TNJU002	KwaNjunga Final	Temperature OS*	13.0	-	°C
01-Sep-25	2465591	TNJU002	KwaNjunga Final	Turbidity	0.3	±6.1%	NTU
02-Sep-25	2466119	TJO001	Jolivet RRT frn Vulamehlo	Batch No.*	20250201	-	-
02-Sep-25	2466119	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (F) OS*	1.05	-	mg Cl2/L
02-Sep-25	2466119	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (T) OS*	1.14	-	mg Cl2/L
02-Sep-25	2466120	TJO001	Jolivet RRT frn Vulamehlo	Coliforms*	0	±15%	MPN/100mL
02-Sep-25	2466119	TJO001	Jolivet RRT frn Vulamehlo	Coll Time OS*	09:50	-	-
02-Sep-25	2466123	TJO001	Jolivet RRT frn Vulamehlo	Colour	1.20	±6.5%	mg Pt-Co/L
02-Sep-25	2466122	TJO001	Jolivet RRT frn Vulamehlo	Conductivity	13.5	±1.5%	mS/m
02-Sep-25	2466120	TJO001	Jolivet RRT frn Vulamehlo	E.coli*	0	±14%	MPN/100mL
02-Sep-25	2466120	TJO001	Jolivet RRT frn Vulamehlo	HPC 37*	0	±21%	cfu/mL
02-Sep-25	2466123	TJO001	Jolivet RRT frn Vulamehlo	Odour*	Nil	-	-
02-Sep-25	2466119	TJO001	Jolivet RRT frn Vulamehlo	pH OS*	8.12	-	-
02-Sep-25	2466119	TJO001	Jolivet RRT frn Vulamehlo	Temperature OS*	17.9	-	°C
02-Sep-25	2466123	TJO001	Jolivet RRT frn Vulamehlo	Turbidity	1.3	±6.1%	NTU
02-Sep-25	2466167	TQU002	Mnqumeni Final	Batch No.*	20250201	-	-
02-Sep-25	2466167	TQU002	Mnqumeni Final	Cl2 (F) OS*	0.74	-	mg Cl2/L
02-Sep-25	2466167	TQU002	Mnqumeni Final	Cl2 (T) OS*	0.82	-	mg Cl2/L
02-Sep-25	2466168	TQU002	Mnqumeni Final	Coliforms*	3	±15%	MPN/100mL
02-Sep-25	2466167	TQU002	Mnqumeni Final	Coll Time OS*	7:13	-	-
02-Sep-25	2466170	TQU002	Mnqumeni Final	Conductivity	15.9	±1.5%	mS/m
02-Sep-25	2466168	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
02-Sep-25	2466168	TQU002	Mnqumeni Final	HPC 37*	1	±21%	cfu/mL
02-Sep-25	2466167	TQU002	Mnqumeni Final	pH OS*	7.40	-	-
02-Sep-25	2466167	TQU002	Mnqumeni Final	Temperature OS*	12.2	-	°C
02-Sep-25	2466171	TQU002	Mnqumeni Final	Turbidity	0.6	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

02-Sep-25	2466185	TSQ002	Esiqanduleni Final	Al (AE)	39.7	±7.6%	µg Al/L
02-Sep-25	2466180	TSQ002	Esiqanduleni Final	Batch No.*	20250201	-	-
02-Sep-25	2466180	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	0.75	-	mg Cl2/L
02-Sep-25	2466180	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	0.81	-	mg Cl2/L
02-Sep-25	2466181	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
02-Sep-25	2466180	TSQ002	Esiqanduleni Final	Coll Time OS*	8:40	-	-
02-Sep-25	2466183	TSQ002	Esiqanduleni Final	Conductivity	24.0	±1.5%	mS/m
02-Sep-25	2466181	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
02-Sep-25	2466181	TSQ002	Esiqanduleni Final	HPC 37*	0	±21%	cfu/mL
02-Sep-25	2466180	TSQ002	Esiqanduleni Final	pH OS*	7.30	-	-
02-Sep-25	2466180	TSQ002	Esiqanduleni Final	Temperature OS*	16.7	-	°C
02-Sep-25	2466184	TSQ002	Esiqanduleni Final	Turbidity	0.6	±6.1%	NTU
03-Sep-25	2466800	TBU002	Bulwer Final	Batch No.*	20250401	-	-
03-Sep-25	2466800	TBU002	Bulwer Final	Cl2 (F) OS*	1.09	-	mg Cl2/L
03-Sep-25	2466800	TBU002	Bulwer Final	Cl2 (T) OS*	1.17	-	mg Cl2/L
03-Sep-25	2466801	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
03-Sep-25	2466800	TBU002	Bulwer Final	Coll Time OS*	09:40	-	-
03-Sep-25	2466803	TBU002	Bulwer Final	Conductivity	6.70	±1.5%	mS/m
03-Sep-25	2466801	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
03-Sep-25	2466801	TBU002	Bulwer Final	HPC 37*	2	±21%	cfu/mL
03-Sep-25	2466800	TBU002	Bulwer Final	pH OS*	7.40	-	-
03-Sep-25	2466800	TBU002	Bulwer Final	Temperature OS*	26.7	-	°C
03-Sep-25	2466804	TBU002	Bulwer Final	Turbidity	4.9	±6.1%	NTU
03-Sep-25	2466815	TCR002	Creighton Final	Al (AE)	339	±7.6%	µg Al/L
03-Sep-25	2466810	TCR002	Creighton Final	Batch No.*	20250401	-	-
03-Sep-25	2466810	TCR002	Creighton Final	Cl2 (F) OS*	1.20	-	mg Cl2/L
03-Sep-25	2466810	TCR002	Creighton Final	Cl2 (T) OS*	1.28	-	mg Cl2/L
03-Sep-25	2466811	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
03-Sep-25	2466810	TCR002	Creighton Final	Coll Time OS*	07:02	-	-
03-Sep-25	2466813	TCR002	Creighton Final	Conductivity	11.0	±1.5%	mS/m
03-Sep-25	2466811	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
03-Sep-25	2466811	TCR002	Creighton Final	HPC 37*	0	±21%	cfu/mL
03-Sep-25	2466810	TCR002	Creighton Final	pH OS*	7.30	-	-
03-Sep-25	2466810	TCR002	Creighton Final	Temperature OS*	16.6	-	°C
03-Sep-25	2466814	TCR002	Creighton Final	Turbidity	0.6	±6.1%	NTU
03-Sep-25	2466820	THL002	Hlanganani Final	Batch No.*	20250401	-	-
03-Sep-25	2466820	THL002	Hlanganani Final	Cl2 (F) OS*	0.77	-	mg Cl2/L
03-Sep-25	2466820	THL002	Hlanganani Final	Cl2 (T) OS*	0.86	-	mg Cl2/L
03-Sep-25	2466821	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
03-Sep-25	2466820	THL002	Hlanganani Final	Coll Time OS*	10:15	-	-
03-Sep-25	2466823	THL002	Hlanganani Final	Conductivity	12.9	±1.5%	mS/m
03-Sep-25	2466821	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

03-Sep-25	2466821	THL002	Hlanganani Final	HPC 37*	2	±21%	cfu/mL
03-Sep-25	2466820	THL002	Hlanganani Final	pH OS*	7.40	-	-
03-Sep-25	2466820	THL002	Hlanganani Final	Temperature OS*	28.4	-	°C
03-Sep-25	2466824	THL002	Hlanganani Final	Turbidity	0.3	±6.1%	NTU
03-Sep-25	2466834	TMAN002	Mangwaneni Final	Batch No.*	20250201	-	-
03-Sep-25	2466834	TMAN002	Mangwaneni Final	Cl ₂ (F) OS*	0.32	-	mg Cl ₂ /L
03-Sep-25	2466834	TMAN002	Mangwaneni Final	Cl ₂ (T) OS*	0.40	-	mg Cl ₂ /L
03-Sep-25	2466835	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
03-Sep-25	2466834	TMAN002	Mangwaneni Final	Coll Time OS*	09:40	-	-
03-Sep-25	2466837	TMAN002	Mangwaneni Final	Conductivity	13.0	±1.5%	mS/m
03-Sep-25	2466835	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
03-Sep-25	2466835	TMAN002	Mangwaneni Final	HPC 37*	10	±21%	cfu/mL
03-Sep-25	2466834	TMAN002	Mangwaneni Final	pH OS*	7.40	-	-
03-Sep-25	2466834	TMAN002	Mangwaneni Final	Temperature OS*	14.8	-	°C
03-Sep-25	2466838	TMAN002	Mangwaneni Final	Turbidity	2.0	±6.1%	NTU
03-Sep-25	2466843	TMQA002	Mqatsheni Final	Batch No.*	20250201	-	-
03-Sep-25	2466843	TMQA002	Mqatsheni Final	Cl ₂ (F) OS*	1.28	-	mg Cl ₂ /L
03-Sep-25	2466843	TMQA002	Mqatsheni Final	Cl ₂ (T) OS*	1.35	-	mg Cl ₂ /L
03-Sep-25	2466844	TMQA002	Mqatsheni Final	Coliforms*	2	±15%	MPN/100mL
03-Sep-25	2466843	TMQA002	Mqatsheni Final	Coll Time OS*	07:25	-	-
03-Sep-25	2466846	TMQA002	Mqatsheni Final	Conductivity	25.7	±1.5%	mS/m
03-Sep-25	2466844	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
03-Sep-25	2466844	TMQA002	Mqatsheni Final	HPC 37*	3	±21%	cfu/mL
03-Sep-25	2466843	TMQA002	Mqatsheni Final	pH OS*	8.80	-	-
03-Sep-25	2466843	TMQA002	Mqatsheni Final	Temperature OS*	18.4	-	°C
03-Sep-25	2466847	TMQA002	Mqatsheni Final	Turbidity	0.9	±6.1%	NTU
03-Sep-25	2466853	TRV002	Riverside Final	Batch No.*	20250401	-	-
03-Sep-25	2466853	TRV002	Riverside Final	Cl ₂ (F) OS*	1.36	-	mg Cl ₂ /L
03-Sep-25	2466853	TRV002	Riverside Final	Cl ₂ (T) OS*	1.44	-	mg Cl ₂ /L
03-Sep-25	2466854	TRV002	Riverside Final	Coliforms*	201	±15%	MPN/100mL
03-Sep-25	2466853	TRV002	Riverside Final	Coll Time OS*	07:40	-	-
03-Sep-25	2466856	TRV002	Riverside Final	Conductivity	9.62	±1.5%	mS/m
03-Sep-25	2466854	TRV002	Riverside Final	E.coli*	53	±14%	MPN/100mL
03-Sep-25	2466858	TRV002	Riverside Final	Fe (AE)	0.16	±5.4%	mg Fe/L
03-Sep-25	2466854	TRV002	Riverside Final	HPC 37*	131	±21%	cfu/mL
03-Sep-25	2466853	TRV002	Riverside Final	pH OS*	7.30	-	-
03-Sep-25	2466853	TRV002	Riverside Final	Temperature OS*	17.1	-	°C
03-Sep-25	2466857	TRV002	Riverside Final	Turbidity	3.3	±6.1%	NTU
03-Sep-25	2466864	TST002	St Appollinaris Final	Batch No.*	20250401	-	-
03-Sep-25	2466864	TST002	St Appollinaris Final	Cl ₂ (F) OS*	0.60	-	mg Cl ₂ /L
03-Sep-25	2466864	TST002	St Appollinaris Final	Cl ₂ (T) OS*	0.70	-	mg Cl ₂ /L
03-Sep-25	2466865	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

03-Sep-25	2466864	TST002	St Appollinaris Final	Coll Time OS*	08:30	-	-
03-Sep-25	2466867	TST002	St Appollinaris Final	Conductivity	11.0	±1.5%	mS/m
03-Sep-25	2466865	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
03-Sep-25	2466865	TST002	St Appollinaris Final	HPC 37*	1	±21%	cfu/mL
03-Sep-25	2466864	TST002	St Appollinaris Final	pH OS*	7.40	-	-
03-Sep-25	2466864	TST002	St Appollinaris Final	Temperature OS*	24.7	-	°C
03-Sep-25	2466868	TST002	St Appollinaris Final	Turbidity	2.2	±6.1%	NTU
03-Sep-25	2466869	TST003	St Appollinaris Hospital Reticulation	Batch No.*	20250401	-	-
03-Sep-25	2466869	TST003	St Appollinaris Hospital Reticulation	Cl ₂ (F) OS*	0.48	-	mg Cl ₂ /L
03-Sep-25	2466869	TST003	St Appollinaris Hospital Reticulation	Cl ₂ (T) OS*	0.55	-	mg Cl ₂ /L
03-Sep-25	2466870	TST003	St Appollinaris Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
03-Sep-25	2466869	TST003	St Appollinaris Hospital Reticulation	Coll Time OS*	08:10	-	-
03-Sep-25	2466870	TST003	St Appollinaris Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
03-Sep-25	2466870	TST003	St Appollinaris Hospital Reticulation	HPC 37*	1	±21%	cfu/mL
03-Sep-25	2466869	TST003	St Appollinaris Hospital Reticulation	pH OS*	7.30	-	-
03-Sep-25	2466869	TST003	St Appollinaris Hospital Reticulation	Temperature OS*	22.2	-	°C
03-Sep-25	2466872	TST003	St Appollinaris Hospital Reticulation	Turbidity	3.1	±6.1%	NTU
03-Sep-25	2466883	TUN002	Underberg Final	Al (AE)	<25.0	±7.6%	µg Al/L
03-Sep-25	2466878	TUN002	Underberg Final	Batch No.*	20250201	-	-
03-Sep-25	2466878	TUN002	Underberg Final	Cl ₂ (F) OS*	0.40	-	mg Cl ₂ /L
03-Sep-25	2466878	TUN002	Underberg Final	Cl ₂ (T) OS*	0.48	-	mg Cl ₂ /L
03-Sep-25	2466879	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
03-Sep-25	2466878	TUN002	Underberg Final	Coll Time OS*	08:40	-	-
03-Sep-25	2466881	TUN002	Underberg Final	Conductivity	8.24	±1.5%	mS/m
03-Sep-25	2466879	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
03-Sep-25	2466879	TUN002	Underberg Final	HPC 37*	1	±21%	cfu/mL
03-Sep-25	2466878	TUN002	Underberg Final	pH OS*	7.30	-	-
03-Sep-25	2466878	TUN002	Underberg Final	Temperature OS*	13.7	-	°C
03-Sep-25	2466882	TUN002	Underberg Final	Turbidity	0.8	±6.1%	NTU
04-Sep-25	2467447	TMZ002	Umzimkhulu Final	Al (AE)	206	±7.6%	µg Al/L
04-Sep-25	2467442	TMZ002	Umzimkhulu Final	Batch No.*	20250201	-	-
04-Sep-25	2467442	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	1.33	-	mg Cl ₂ /L
04-Sep-25	2467442	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	1.40	-	mg Cl ₂ /L
04-Sep-25	2467443	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
04-Sep-25	2467443	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
04-Sep-25	2467442	TMZ002	Umzimkhulu Final	Coll Time OS*	08:17	-	-
04-Sep-25	2467446	TMZ002	Umzimkhulu Final	Colour	<1.00	±6.5%	mg Pt-Co/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

04-Sep-25	2467445	TMZ002	Umzimkhulu Final	Conductivity	14.0	±1.5%	mS/m
04-Sep-25	2467443	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
04-Sep-25	2467443	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	cfu/mL
04-Sep-25	2467446	TMZ002	Umzimkhulu Final	Odour*	Mild Chlorinous	-	-
04-Sep-25	2467442	TMZ002	Umzimkhulu Final	pH OS*	7.20	-	-
04-Sep-25	2467442	TMZ002	Umzimkhulu Final	Temperature OS*	17.5	-	°C
04-Sep-25	2467446	TMZ002	Umzimkhulu Final	Turbidity	1.4	±6.1%	NTU
04-Sep-25	2467458	TNO002	Nokweja Final	Al (AE)	201	±7.6%	µg Al/L
04-Sep-25	2467453	TNO002	Nokweja Final	Batch No.*	20250401	-	-
04-Sep-25	2467453	TNO002	Nokweja Final	Cl ₂ (F) OS*	1.03	-	mg Cl ₂ /L
04-Sep-25	2467453	TNO002	Nokweja Final	Cl ₂ (T) OS*	1.14	-	mg Cl ₂ /L
04-Sep-25	2467454	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
04-Sep-25	2467454	TNO002	Nokweja Final	Coliphages*	1	±8%	PFU/10ml
04-Sep-25	2467453	TNO002	Nokweja Final	Coll Time OS*	07:45	-	-
04-Sep-25	2467456	TNO002	Nokweja Final	Conductivity	15.1	±1.5%	mS/m
04-Sep-25	2467454	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
04-Sep-25	2467454	TNO002	Nokweja Final	HPC 37*	10	±21%	cfu/mL
04-Sep-25	2467453	TNO002	Nokweja Final	pH OS*	7.30	-	-
04-Sep-25	2467453	TNO002	Nokweja Final	Temperature OS*	14.4	-	°C
04-Sep-25	2467457	TNO002	Nokweja Final	Turbidity	2.6	±6.1%	NTU
04-Sep-25	2467496	TWA002	Washbank Final	Al (AE)	420	±7.6%	µg Al/L
04-Sep-25	2467491	TWA002	Washbank Final	Batch No.*	20250201	-	-
04-Sep-25	2467491	TWA002	Washbank Final	Cl ₂ (F) OS*	0.29	-	mg Cl ₂ /L
04-Sep-25	2467491	TWA002	Washbank Final	Cl ₂ (T) OS*	0.36	-	mg Cl ₂ /L
04-Sep-25	2467492	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
04-Sep-25	2467491	TWA002	Washbank Final	Coll Time OS*	07:17	-	-
04-Sep-25	2467494	TWA002	Washbank Final	Conductivity	8.72	±1.5%	mS/m
04-Sep-25	2467492	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
04-Sep-25	2467492	TWA002	Washbank Final	HPC 37*	13	±21%	cfu/mL
04-Sep-25	2467491	TWA002	Washbank Final	pH OS*	7.40	-	-
04-Sep-25	2467491	TWA002	Washbank Final	Temperature OS*	17.3	-	°C
04-Sep-25	2467495	TWA002	Washbank Final	Turbidity	6.8	±6.1%	NTU
05-Sep-25	2468891	TIB002	Ibisi Final	Al (AE)	151	±7.6%	µg Al/L
05-Sep-25	2468886	TIB002	Ibisi Final	Batch No.*	20250401	-	-
05-Sep-25	2468886	TIB002	Ibisi Final	Cl ₂ (F) OS*	0.70	-	mg Cl ₂ /L
05-Sep-25	2468886	TIB002	Ibisi Final	Cl ₂ (T) OS*	0.81	-	mg Cl ₂ /L
05-Sep-25	2468887	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
05-Sep-25	2468887	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
05-Sep-25	2468886	TIB002	Ibisi Final	Coll Time OS*	06:15	-	-
05-Sep-25	2468889	TIB002	Ibisi Final	Conductivity	12.8	±1.5%	mS/m
05-Sep-25	2468887	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
05-Sep-25	2468891	TIB002	Ibisi Final	Fe (AE)	0.12	±5.4%	mg Fe/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

05-Sep-25	2468887	TIB002	Ibisi Final	HPC 37*	5	±21%	cfu/mL
05-Sep-25	2468886	TIB002	Ibisi Final	pH OS*	7.30	-	-
05-Sep-25	2468886	TIB002	Ibisi Final	Temperature OS*	13.2	-	°C
05-Sep-25	2468890	TIB002	Ibisi Final	Turbidity	2.5	±6.1%	NTU
05-Sep-25	2468896	TRT002	Rietvlei Final	Batch No.*	20250401	-	-
05-Sep-25	2468896	TRT002	Rietvlei Final	Cl ₂ (F) OS*	1.13	-	mg Cl ₂ /L
05-Sep-25	2468896	TRT002	Rietvlei Final	Cl ₂ (T) OS*	1.20	-	mg Cl ₂ /L
05-Sep-25	2468897	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
05-Sep-25	2468896	TRT002	Rietvlei Final	Coll Time OS*	06:57	-	-
05-Sep-25	2468899	TRT002	Rietvlei Final	Conductivity	20.1	±1.5%	mS/m
05-Sep-25	2468897	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
05-Sep-25	2468897	TRT002	Rietvlei Final	HPC 37*	1	±21%	cfu/mL
05-Sep-25	2468896	TRT002	Rietvlei Final	pH OS*	7.30	-	-
05-Sep-25	2468896	TRT002	Rietvlei Final	Temperature OS*	14.3	-	°C
05-Sep-25	2468900	TRT002	Rietvlei Final	Turbidity	1.0	±6.1%	NTU
08-Sep-25	2471662	TFR002	Franklin Final	Al (AE)	195	±7.6%	µg Al/L
08-Sep-25	2471657	TFR002	Franklin Final	Batch No.*	20250201	-	-
08-Sep-25	2471657	TFR002	Franklin Final	Cl ₂ (F) OS*	1.10	-	mg Cl ₂ /L
08-Sep-25	2471657	TFR002	Franklin Final	Cl ₂ (T) OS*	1.21	-	mg Cl ₂ /L
08-Sep-25	2471658	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
08-Sep-25	2471658	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
08-Sep-25	2471657	TFR002	Franklin Final	Coll Time OS*	7:44	-	-
08-Sep-25	2471661	TFR002	Franklin Final	Colour	<1.00	±6.5%	mg Pt-Co/L
08-Sep-25	2471660	TFR002	Franklin Final	Conductivity	13.4	±1.5%	mS/m
08-Sep-25	2471658	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
08-Sep-25	2471662	TFR002	Franklin Final	Fe (AE)	0.08	±5.4%	mg Fe/L
08-Sep-25	2471658	TFR002	Franklin Final	HPC 37*	0	±21%	cfu/mL
08-Sep-25	2471662	TFR002	Franklin Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
08-Sep-25	2471657	TFR002	Franklin Final	pH OS*	7.20	-	-
08-Sep-25	2471657	TFR002	Franklin Final	Temperature OS*	13.9	-	°C
08-Sep-25	2471661	TFR002	Franklin Final	Turbidity	1.7	±6.1%	NTU
08-Sep-25	2471663	TFR003	Franklin Police Station Retic	Batch No.*	20250201	-	-
08-Sep-25	2471663	TFR003	Franklin Police Station Retic	Cl ₂ (F) OS*	0.48	-	mg Cl ₂ /L
08-Sep-25	2471663	TFR003	Franklin Police Station Retic	Cl ₂ (T) OS*	0.57	-	mg Cl ₂ /L
08-Sep-25	2471664	TFR003	Franklin Police Station Retic	Coliforms*	0	±15%	MPN/100mL
08-Sep-25	2471663	TFR003	Franklin Police Station Retic	Coll Time OS*	8:05	-	-
08-Sep-25	2471664	TFR003	Franklin Police Station Retic	E.coli*	0	±14%	MPN/100mL
08-Sep-25	2471664	TFR003	Franklin Police Station Retic	HPC 37*	0	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

08-Sep-25	2471663	TFR003	Franklin Police Station Retic	pH OS*	7.40	-	-
08-Sep-25	2471663	TFR003	Franklin Police Station Retic	Temperature OS*	14.2	-	°C
08-Sep-25	2471666	TFR003	Franklin Police Station Retic	Turbidity	3.7	±6.1%	NTU
08-Sep-25	2471677	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
08-Sep-25	2471672	TKK002	Kokstad Final	Batch No.*	20250201	-	-
08-Sep-25	2471672	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.38	-	mg Cl ₂ /L
08-Sep-25	2471672	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.48	-	mg Cl ₂ /L
08-Sep-25	2471673	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
08-Sep-25	2471673	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
08-Sep-25	2471672	TKK002	Kokstad Final	Coll Time OS*	9:00	-	-
08-Sep-25	2471676	TKK002	Kokstad Final	Colour	<1.00	±6.5%	mg Pt-Co/L
08-Sep-25	2471675	TKK002	Kokstad Final	Conductivity	16.7	±1.5%	mS/m
08-Sep-25	2471673	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
08-Sep-25	2471673	TKK002	Kokstad Final	HPC 37*	0	±21%	cfu/mL
08-Sep-25	2471676	TKK002	Kokstad Final	Odour*	Nil	-	-
08-Sep-25	2471672	TKK002	Kokstad Final	pH OS*	7.30	-	-
08-Sep-25	2471676	TKK002	Kokstad Final	Taste*	Nil	-	-
08-Sep-25	2471672	TKK002	Kokstad Final	Temperature OS*	16.3	-	°C
08-Sep-25	2471676	TKK002	Kokstad Final	Turbidity	0.3	±6.1%	NTU
08-Sep-25	2471687	TKK006	Kokstad Bongweni Correctional Serv Retic	Batch No.*	20250201	-	-
08-Sep-25	2471687	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl ₂ (F) OS*	0.55	-	mg Cl ₂ /L
08-Sep-25	2471687	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl ₂ (T) OS*	0.60	-	mg Cl ₂ /L
08-Sep-25	2471688	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliforms*	0	±15%	MPN/100mL
08-Sep-25	2471687	TKK006	Kokstad Bongweni Correctional Serv Retic	Coll Time OS*	8:49	-	-
08-Sep-25	2471688	TKK006	Kokstad Bongweni Correctional Serv Retic	E.coli*	0	±14%	MPN/100mL
08-Sep-25	2471688	TKK006	Kokstad Bongweni Correctional Serv Retic	HPC 37*	0	±21%	cfu/mL
08-Sep-25	2471687	TKK006	Kokstad Bongweni Correctional Serv Retic	pH OS*	7.30	-	-
08-Sep-25	2471687	TKK006	Kokstad Bongweni Correctional Serv Retic	Temperature OS*	14.6	-	°C
08-Sep-25	2471690	TKK006	Kokstad Bongweni Correctional Serv Retic	Turbidity	0.3	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

08-Sep-25	2471691	TKK007	Kokstad Shayamoya Reticulation	Batch No.*	20250201	-	-
08-Sep-25	2471691	TKK007	Kokstad Shayamoya Reticulation	Cl2 (F) OS*	1.03	-	mg Cl2/L
08-Sep-25	2471691	TKK007	Kokstad Shayamoya Reticulation	Cl2 (T) OS*	1.09	-	mg Cl2/L
08-Sep-25	2471692	TKK007	Kokstad Shayamoya Reticulation	Coliforms*	0	±15%	MPN/100mL
08-Sep-25	2471691	TKK007	Kokstad Shayamoya Reticulation	Coll Time OS*	9:36	-	-
08-Sep-25	2471694	TKK007	Kokstad Shayamoya Reticulation	Colour	1.20	±6.5%	mg Pt-Co/L
08-Sep-25	2471692	TKK007	Kokstad Shayamoya Reticulation	E.coli*	0	±14%	MPN/100mL
08-Sep-25	2471692	TKK007	Kokstad Shayamoya Reticulation	HPC 37*	1	±21%	cfu/mL
08-Sep-25	2471694	TKK007	Kokstad Shayamoya Reticulation	Odour*	Nil	-	-
08-Sep-25	2471691	TKK007	Kokstad Shayamoya Reticulation	pH OS*	7.30	-	-
08-Sep-25	2471694	TKK007	Kokstad Shayamoya Reticulation	Taste*	Nil	-	-
08-Sep-25	2471691	TKK007	Kokstad Shayamoya Reticulation	Temperature OS*	17.2	-	°C
08-Sep-25	2471694	TKK007	Kokstad Shayamoya Reticulation	Turbidity	0.2	±6.1%	NTU
08-Sep-25	2471695	TKK009	Kokstad Farm Fresh Produce Market	Batch No.*	20250201	-	-
08-Sep-25	2471695	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (F) OS*	1.12	-	mg Cl2/L
08-Sep-25	2471695	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (T) OS*	1.25	-	mg Cl2/L
08-Sep-25	2471696	TKK009	Kokstad Farm Fresh Produce Market	Coliforms*	22	±15%	MPN/100mL
08-Sep-25	2471695	TKK009	Kokstad Farm Fresh Produce Market	Coll Time OS*	9:08	-	-
08-Sep-25	2471696	TKK009	Kokstad Farm Fresh Produce Market	E.coli*	0	±14%	MPN/100mL
08-Sep-25	2471696	TKK009	Kokstad Farm Fresh Produce Market	HPC 37*	17	±21%	cfu/mL
08-Sep-25	2471695	TKK009	Kokstad Farm Fresh Produce Market	pH OS*	7.30	-	-
08-Sep-25	2471695	TKK009	Kokstad Farm Fresh Produce Market	Temperature OS*	17.0	-	°C
08-Sep-25	2471698	TKK009	Kokstad Farm Fresh Produce Market	Turbidity	0.3	±6.1%	NTU
08-Sep-25	2471699	TKK012	Kokstad FET College Reticulation	Batch No.*	20250201	-	-
08-Sep-25	2471699	TKK012	Kokstad FET College Reticulation	Cl2 (F) OS*	0.81	-	mg Cl2/L
08-Sep-25	2471699	TKK012	Kokstad FET College Reticulation	Cl2 (T) OS*	0.99	-	mg Cl2/L
08-Sep-25	2471700	TKK012	Kokstad FET College Reticulation	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

08-Sep-25	2471699	TKK012	Kokstad FET College Reticulation	Coll Time OS*	8:30	-	-
08-Sep-25	2471703	TKK012	Kokstad FET College Reticulation	Colour	1.20	±6.5%	mg Pt-Co/L
08-Sep-25	2471702	TKK012	Kokstad FET College Reticulation	Conductivity	16.3	±1.5%	mS/m
08-Sep-25	2471700	TKK012	Kokstad FET College Reticulation	E.coli*	0	±14%	MPN/100mL
08-Sep-25	2471700	TKK012	Kokstad FET College Reticulation	HPC 37*	26	±21%	cfu/mL
08-Sep-25	2471699	TKK012	Kokstad FET College Reticulation	pH OS*	7.20	-	-
08-Sep-25	2471699	TKK012	Kokstad FET College Reticulation	Temperature OS*	14.1	-	°C
08-Sep-25	2471703	TKK012	Kokstad FET College Reticulation	Turbidity	0.4	±6.1%	NTU
08-Sep-25	2471729	TNJU002	KwaNjunga Final	Batch No.*	20250201	-	-
08-Sep-25	2471729	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	0.27	-	mg Cl ₂ /L
08-Sep-25	2471729	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	0.41	-	mg Cl ₂ /L
08-Sep-25	2471730	TNJU002	KwaNjunga Final	Coliforms*	130	±15%	MPN/100mL
08-Sep-25	2471729	TNJU002	KwaNjunga Final	Coll Time OS*	7:05	-	-
08-Sep-25	2471732	TNJU002	KwaNjunga Final	Conductivity	20.0	±1.5%	mS/m
08-Sep-25	2471730	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
08-Sep-25	2471730	TNJU002	KwaNjunga Final	HPC 37*	22	±21%	cfu/mL
08-Sep-25	2471729	TNJU002	KwaNjunga Final	pH OS*	7.40	-	-
08-Sep-25	2471729	TNJU002	KwaNjunga Final	Temperature OS*	15.5	-	°C
08-Sep-25	2471733	TNJU002	KwaNjunga Final	Turbidity	0.3	±6.1%	NTU
08-Sep-25	2471734	TNJU003	KwaNjunga Reticulation	Batch No.*	20250201	-	-
08-Sep-25	2471734	TNJU003	KwaNjunga Reticulation	Cl ₂ (F) OS*	0.09	-	mg Cl ₂ /L
08-Sep-25	2471734	TNJU003	KwaNjunga Reticulation	Cl ₂ (T) OS*	0.15	-	mg Cl ₂ /L
08-Sep-25	2471735	TNJU003	KwaNjunga Reticulation	Coliforms*	0	±15%	MPN/100mL
08-Sep-25	2471734	TNJU003	KwaNjunga Reticulation	Coll Time OS*	6:40	-	-
08-Sep-25	2471738	TNJU003	KwaNjunga Reticulation	Colour	1.20	±6.5%	mg Pt-Co/L
08-Sep-25	2471737	TNJU003	KwaNjunga Reticulation	Conductivity	18.7	±1.5%	mS/m
08-Sep-25	2471735	TNJU003	KwaNjunga Reticulation	E.coli*	0	±14%	MPN/100mL
08-Sep-25	2471735	TNJU003	KwaNjunga Reticulation	HPC 37*	0	±21%	cfu/mL
08-Sep-25	2471738	TNJU003	KwaNjunga Reticulation	Odour*	Nil	-	-
08-Sep-25	2471734	TNJU003	KwaNjunga Reticulation	pH OS*	7.50	-	-
08-Sep-25	2471734	TNJU003	KwaNjunga Reticulation	Temperature OS*	14.8	-	°C
08-Sep-25	2471738	TNJU003	KwaNjunga Reticulation	Turbidity	0.4	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

09-Sep-25	2472299	TQU002	Mnqumeni Final	Batch No.*	20250201	-	-
09-Sep-25	2472299	TQU002	Mnqumeni Final	Cl2 (F) OS*	1.20	-	mg Cl2/L
09-Sep-25	2472299	TQU002	Mnqumeni Final	Cl2 (T) OS*	1.36	-	mg Cl2/L
09-Sep-25	2472300	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
09-Sep-25	2472299	TQU002	Mnqumeni Final	Coll Time OS*	06:20	-	-
09-Sep-25	2472302	TQU002	Mnqumeni Final	Conductivity	16.0	±1.5%	mS/m
09-Sep-25	2472300	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
09-Sep-25	2472300	TQU002	Mnqumeni Final	HPC 37*	0	±21%	cfu/mL
09-Sep-25	2472299	TQU002	Mnqumeni Final	pH OS*	7.30	-	-
09-Sep-25	2472299	TQU002	Mnqumeni Final	Temperature OS*	17.1	-	°C
09-Sep-25	2472303	TQU002	Mnqumeni Final	Turbidity	0.5	±6.1%	NTU
09-Sep-25	2472304	TQU003	Mnqumeni Reticulation	Batch No.*	20250201	-	-
09-Sep-25	2472304	TQU003	Mnqumeni Reticulation	Cl2 (F) OS*	0.84	-	mg Cl2/L
09-Sep-25	2472304	TQU003	Mnqumeni Reticulation	Cl2 (T) OS*	0.99	-	mg Cl2/L
09-Sep-25	2472305	TQU003	Mnqumeni Reticulation	Coliforms*	0	±15%	MPN/100mL
09-Sep-25	2472304	TQU003	Mnqumeni Reticulation	Coll Time OS*	06:57	-	-
09-Sep-25	2472308	TQU003	Mnqumeni Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Sep-25	2472307	TQU003	Mnqumeni Reticulation	Conductivity	16.2	±1.5%	mS/m
09-Sep-25	2472305	TQU003	Mnqumeni Reticulation	E.coli*	0	±14%	MPN/100mL
09-Sep-25	2472305	TQU003	Mnqumeni Reticulation	HPC 37*	0	±21%	cfu/mL
09-Sep-25	2472308	TQU003	Mnqumeni Reticulation	Odour*	Nil	-	-
09-Sep-25	2472304	TQU003	Mnqumeni Reticulation	pH OS*	7.40	-	-
09-Sep-25	2472304	TQU003	Mnqumeni Reticulation	Temperature OS*	13.1	-	°C
09-Sep-25	2472308	TQU003	Mnqumeni Reticulation	Turbidity	0.7	±6.1%	NTU
09-Sep-25	2472319	TSQ002	Esiqanduleni Final	Al (AE)	26.4	±7.6%	µg Al/L
09-Sep-25	2472314	TSQ002	Esiqanduleni Final	Batch No.*	20250401	-	-
09-Sep-25	2472314	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	1.19	-	mg Cl2/L
09-Sep-25	2472314	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	1.27	-	mg Cl2/L
09-Sep-25	2472315	TSQ002	Esiqanduleni Final	Coliforms*	2	±15%	MPN/100mL
09-Sep-25	2472314	TSQ002	Esiqanduleni Final	Coll Time OS*	8:12	-	-
09-Sep-25	2472318	TSQ002	Esiqanduleni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Sep-25	2472317	TSQ002	Esiqanduleni Final	Conductivity	23.4	±1.5%	mS/m
09-Sep-25	2472315	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
09-Sep-25	2472315	TSQ002	Esiqanduleni Final	HPC 37*	0	±21%	cfu/mL
09-Sep-25	2472318	TSQ002	Esiqanduleni Final	Odour*	Mild Chlorinous	-	-
09-Sep-25	2472314	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtololo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

09-Sep-25	2472318	TSQ002	Esiqanduleni Final	Taste*	Nil	-	-
09-Sep-25	2472314	TSQ002	Esiqanduleni Final	Temperature OS*	14.2	-	°C
09-Sep-25	2472318	TSQ002	Esiqanduleni Final	Turbidity	0.4	±6.1%	NTU
09-Sep-25	2472320	TSQ003	Esiqanduleni Reticulation	Batch No.*	20250401	-	-
09-Sep-25	2472320	TSQ003	Esiqanduleni Reticulation	Cl ₂ (F) OS*	0.76	-	mg Cl ₂ /L
09-Sep-25	2472320	TSQ003	Esiqanduleni Reticulation	Cl ₂ (T) OS*	0.96	-	mg Cl ₂ /L
09-Sep-25	2472321	TSQ003	Esiqanduleni Reticulation	Coliforms*	0	±15%	MPN/100mL
09-Sep-25	2472320	TSQ003	Esiqanduleni Reticulation	Coll Time OS*	08:30	-	-
09-Sep-25	2472324	TSQ003	Esiqanduleni Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
09-Sep-25	2472323	TSQ003	Esiqanduleni Reticulation	Conductivity	23.5	±1.5%	mS/m
09-Sep-25	2472321	TSQ003	Esiqanduleni Reticulation	E.coli*	0	±14%	MPN/100mL
09-Sep-25	2472321	TSQ003	Esiqanduleni Reticulation	HPC 37*	0	±21%	cfu/mL
09-Sep-25	2472324	TSQ003	Esiqanduleni Reticulation	Odour*	Nil	-	-
09-Sep-25	2472320	TSQ003	Esiqanduleni Reticulation	pH OS*	7.50	-	-
09-Sep-25	2472320	TSQ003	Esiqanduleni Reticulation	Temperature OS*	15.4	-	°C
09-Sep-25	2472324	TSQ003	Esiqanduleni Reticulation	Turbidity	0.5	±6.1%	NTU
10-Sep-25	2472961	TBU002	Bulwer Final	Batch No.*	20250401	-	-
10-Sep-25	2472961	TBU002	Bulwer Final	Cl ₂ (F) OS*	0.99	-	mg Cl ₂ /L
10-Sep-25	2472961	TBU002	Bulwer Final	Cl ₂ (T) OS*	1.15	-	mg Cl ₂ /L
10-Sep-25	2472962	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
10-Sep-25	2472961	TBU002	Bulwer Final	Coll Time OS*	09:56	-	-
10-Sep-25	2472965	TBU002	Bulwer Final	Colour	1.60	±6.5%	mg Pt-Co/L
10-Sep-25	2472964	TBU002	Bulwer Final	Conductivity	6.82	±1.5%	mS/m
10-Sep-25	2472962	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
10-Sep-25	2472962	TBU002	Bulwer Final	HPC 37*	2	±21%	cfu/mL
10-Sep-25	2472965	TBU002	Bulwer Final	Odour*	Nil	-	-
10-Sep-25	2472961	TBU002	Bulwer Final	pH OS*	7.30	-	-
10-Sep-25	2472961	TBU002	Bulwer Final	Temperature OS*	16.3	-	°C
10-Sep-25	2472965	TBU002	Bulwer Final	Turbidity	4.9	±6.1%	NTU
10-Sep-25	2472966	TBU005	Bulwer Mountain Park Hotel Retic	Batch No.*	20250401	-	-
10-Sep-25	2472966	TBU005	Bulwer Mountain Park Hotel Retic	Cl ₂ (F) OS*	0.52	-	mg Cl ₂ /L
10-Sep-25	2472966	TBU005	Bulwer Mountain Park Hotel Retic	Cl ₂ (T) OS*	0.61	-	mg Cl ₂ /L
10-Sep-25	2472967	TBU005	Bulwer Mountain Park Hotel Retic	Coliforms*	0	±15%	MPN/100mL
10-Sep-25	2472966	TBU005	Bulwer Mountain Park Hotel Retic	Coll Time OS*	10:15	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

10-Sep-25	2472970	TBU005	Bulwer Mountain Park Hotel Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Sep-25	2472969	TBU005	Bulwer Mountain Park Hotel Retic	Conductivity	6.81	±1.5%	mS/m
10-Sep-25	2472967	TBU005	Bulwer Mountain Park Hotel Retic	E.coli*	0	±14%	MPN/100mL
10-Sep-25	2472967	TBU005	Bulwer Mountain Park Hotel Retic	HPC 37*	1	±21%	cfu/mL
10-Sep-25	2472966	TBU005	Bulwer Mountain Park Hotel Retic	pH OS*	7.40	-	-
10-Sep-25	2472966	TBU005	Bulwer Mountain Park Hotel Retic	Temperature OS*	22.3	-	°C
10-Sep-25	2472970	TBU005	Bulwer Mountain Park Hotel Retic	Turbidity	4.4	±6.1%	NTU
10-Sep-25	2472981	TCR002	Creighton Final	Al (AE)	363	±7.6%	µg Al/L
10-Sep-25	2472976	TCR002	Creighton Final	Batch No.*	20250401	-	-
10-Sep-25	2472976	TCR002	Creighton Final	Cl ₂ (F) OS*	1.64	-	mg Cl ₂ /L
10-Sep-25	2472976	TCR002	Creighton Final	Cl ₂ (T) OS*	1.74	-	mg Cl ₂ /L
10-Sep-25	2472977	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
10-Sep-25	2472976	TCR002	Creighton Final	Coll Time OS*	08:10	-	-
10-Sep-25	2472979	TCR002	Creighton Final	Conductivity	10.3	±1.5%	mS/m
10-Sep-25	2472977	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
10-Sep-25	2472977	TCR002	Creighton Final	HPC 37*	0	±21%	cfu/mL
10-Sep-25	2472976	TCR002	Creighton Final	pH OS*	7.30	-	-
10-Sep-25	2472976	TCR002	Creighton Final	Temperature OS*	18.0	-	°C
10-Sep-25	2472980	TCR002	Creighton Final	Turbidity	0.4	±6.1%	NTU
10-Sep-25	2472982	TCR004	Creighton Madondo Cottages	Batch No.*	20250401	-	-
10-Sep-25	2472982	TCR004	Creighton Madondo Cottages	Cl ₂ (F) OS*	0.72	-	mg Cl ₂ /L
10-Sep-25	2472982	TCR004	Creighton Madondo Cottages	Cl ₂ (T) OS*	0.80	-	mg Cl ₂ /L
10-Sep-25	2472983	TCR004	Creighton Madondo Cottages	Coliforms*	0	±15%	MPN/100mL
10-Sep-25	2472982	TCR004	Creighton Madondo Cottages	Coll Time OS*	07:48	-	-
10-Sep-25	2472983	TCR004	Creighton Madondo Cottages	E.coli*	0	±14%	MPN/100mL
10-Sep-25	2472983	TCR004	Creighton Madondo Cottages	HPC 37*	0	±21%	cfu/mL
10-Sep-25	2472982	TCR004	Creighton Madondo Cottages	pH OS*	7.20	-	-
10-Sep-25	2472982	TCR004	Creighton Madondo Cottages	Temperature OS*	13.5	-	°C
10-Sep-25	2472985	TCR004	Creighton Madondo Cottages	Turbidity	1.7	±6.1%	NTU
10-Sep-25	2472995	THL002	Hlanganani Final	Batch No.*	20250401	-	-
10-Sep-25	2472995	THL002	Hlanganani Final	Cl ₂ (F) OS*	0.78	-	mg Cl ₂ /L
10-Sep-25	2472995	THL002	Hlanganani Final	Cl ₂ (T) OS*	0.90	-	mg Cl ₂ /L
10-Sep-25	2472996	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

10-Sep-25	2472995	THL002	Hlanganani Final	Coll Time OS*	10:35	-	-
10-Sep-25	2472999	THL002	Hlanganani Final	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Sep-25	2472998	THL002	Hlanganani Final	Conductivity	11.3	±1.5%	mS/m
10-Sep-25	2472996	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
10-Sep-25	2472996	THL002	Hlanganani Final	HPC 37*	3	±21%	cfu/mL
10-Sep-25	2472999	THL002	Hlanganani Final	Odour*	Nil	-	-
10-Sep-25	2472995	THL002	Hlanganani Final	pH OS*	7.30	-	-
10-Sep-25	2472999	THL002	Hlanganani Final	Taste*	Nil	-	-
10-Sep-25	2472995	THL002	Hlanganani Final	Temperature OS*	19.3	-	°C
10-Sep-25	2472999	THL002	Hlanganani Final	Turbidity	<0.2	±6.1%	NTU
10-Sep-25	2473000	THL003	Hlanganani Clinic Reticulation	Batch No.*	20250401	-	-
10-Sep-25	2473000	THL003	Hlanganani Clinic Reticulation	Cl2 (F) OS*	0.38	-	mg Cl2/L
10-Sep-25	2473000	THL003	Hlanganani Clinic Reticulation	Cl2 (T) OS*	0.45	-	mg Cl2/L
10-Sep-25	2473001	THL003	Hlanganani Clinic Reticulation	Coliforms*	0	±15%	MPN/100mL
10-Sep-25	2473000	THL003	Hlanganani Clinic Reticulation	Coll Time OS*	10:58	-	-
10-Sep-25	2473004	THL003	Hlanganani Clinic Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Sep-25	2473003	THL003	Hlanganani Clinic Reticulation	Conductivity	11.4	±1.5%	mS/m
10-Sep-25	2473001	THL003	Hlanganani Clinic Reticulation	E.coli*	0	±14%	MPN/100mL
10-Sep-25	2473001	THL003	Hlanganani Clinic Reticulation	HPC 37*	2	±21%	cfu/mL
10-Sep-25	2473000	THL003	Hlanganani Clinic Reticulation	pH OS*	7.40	-	-
10-Sep-25	2473000	THL003	Hlanganani Clinic Reticulation	Temperature OS*	23.5	-	°C
10-Sep-25	2473004	THL003	Hlanganani Clinic Reticulation	Turbidity	<0.2	±6.1%	NTU
10-Sep-25	2473033	TMQA002	Mqatsheni Final	Batch No.*	20250201	-	-
10-Sep-25	2473033	TMQA002	Mqatsheni Final	Cl2 (F) OS*	1.52	-	mg Cl2/L
10-Sep-25	2473033	TMQA002	Mqatsheni Final	Cl2 (T) OS*	1.60	-	mg Cl2/L
10-Sep-25	2473034	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
10-Sep-25	2473033	TMQA002	Mqatsheni Final	Coll Time OS*	06:39	-	-
10-Sep-25	2473037	TMQA002	Mqatsheni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Sep-25	2473036	TMQA002	Mqatsheni Final	Conductivity	24.4	±1.5%	mS/m
10-Sep-25	2473034	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
10-Sep-25	2473034	TMQA002	Mqatsheni Final	HPC 37*	0	±21%	cfu/mL
10-Sep-25	2473037	TMQA002	Mqatsheni Final	Odour*	Nil	-	-
10-Sep-25	2473033	TMQA002	Mqatsheni Final	pH OS*	8.70	-	-
10-Sep-25	2473033	TMQA002	Mqatsheni Final	Temperature OS*	16.7	-	°C
10-Sep-25	2473037	TMQA002	Mqatsheni Final	Turbidity	1.0	±6.1%	NTU
10-Sep-25	2473047	TRV002	Riverside Final	Batch No.*	20250401	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

10-Sep-25	2473047	TRV002	Riverside Final	Cl2 (F) OS*	1.46	-	mg Cl2/L
10-Sep-25	2473047	TRV002	Riverside Final	Cl2 (T) OS*	1.57	-	mg Cl2/L
10-Sep-25	2473048	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
10-Sep-25	2473047	TRV002	Riverside Final	Coll Time OS*	08:38	-	-
10-Sep-25	2473051	TRV002	Riverside Final	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Sep-25	2473050	TRV002	Riverside Final	Conductivity	10.6	±1.5%	mS/m
10-Sep-25	2473048	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
10-Sep-25	2473048	TRV002	Riverside Final	HPC 37*	12	±21%	cfu/mL
10-Sep-25	2473051	TRV002	Riverside Final	Odour*	Mild Chlorinous	-	-
10-Sep-25	2473047	TRV002	Riverside Final	pH OS*	7.30	-	-
10-Sep-25	2473047	TRV002	Riverside Final	Temperature OS*	15.1	-	°C
10-Sep-25	2473051	TRV002	Riverside Final	Turbidity	4.4	±6.1%	NTU
10-Sep-25	2473052	TRV003	Riverside Reticulation	Batch No.*	20250401	-	-
10-Sep-25	2473052	TRV003	Riverside Reticulation	Cl2 (F) OS*	0.66	-	mg Cl2/L
10-Sep-25	2473052	TRV003	Riverside Reticulation	Cl2 (T) OS*	0.74	-	mg Cl2/L
10-Sep-25	2473053	TRV003	Riverside Reticulation	Coliforms*	0	±15%	MPN/100mL
10-Sep-25	2473052	TRV003	Riverside Reticulation	Coll Time OS*	08:32	-	-
10-Sep-25	2473055	TRV003	Riverside Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Sep-25	2473053	TRV003	Riverside Reticulation	E.coli*	0	±14%	MPN/100mL
10-Sep-25	2473053	TRV003	Riverside Reticulation	HPC 37*	5	±21%	cfu/mL
10-Sep-25	2473055	TRV003	Riverside Reticulation	Odour*	Nil	-	-
10-Sep-25	2473052	TRV003	Riverside Reticulation	pH OS*	7.20	-	-
10-Sep-25	2473052	TRV003	Riverside Reticulation	Temperature OS*	14.7	-	°C
10-Sep-25	2473055	TRV003	Riverside Reticulation	Turbidity	4.4	±6.1%	NTU
10-Sep-25	2473061	TST002	St Appollinaris Final	Batch No.*	20250401	-	-
10-Sep-25	2473061	TST002	St Appollinaris Final	Cl2 (F) OS*	1.04	-	mg Cl2/L
10-Sep-25	2473061	TST002	St Appollinaris Final	Cl2 (T) OS*	1.09	-	mg Cl2/L
10-Sep-25	2473062	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
10-Sep-25	2473061	TST002	St Appollinaris Final	Coll Time OS*	09:10	-	-
10-Sep-25	2473065	TST002	St Appollinaris Final	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Sep-25	2473064	TST002	St Appollinaris Final	Conductivity	11.1	±1.5%	mS/m
10-Sep-25	2473062	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
10-Sep-25	2473062	TST002	St Appollinaris Final	HPC 37*	0	±21%	cfu/mL
10-Sep-25	2473065	TST002	St Appollinaris Final	Odour*	Nil	-	-
10-Sep-25	2473061	TST002	St Appollinaris Final	pH OS*	7.40	-	-
10-Sep-25	2473061	TST002	St Appollinaris Final	Temperature OS*	22.2	-	°C
10-Sep-25	2473065	TST002	St Appollinaris Final	Turbidity	2.9	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

10-Sep-25	2473076	TUN002	Underberg Final	Al (AE)	<25.0	±7.6%	µg Al/L
10-Sep-25	2473071	TUN002	Underberg Final	Batch No.*	20250201	-	-
10-Sep-25	2473071	TUN002	Underberg Final	Cl2 (F) OS*	0.56	-	mg Cl2/L
10-Sep-25	2473071	TUN002	Underberg Final	Cl2 (T) OS*	0.69	-	mg Cl2/L
10-Sep-25	2473072	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
10-Sep-25	2473071	TUN002	Underberg Final	Coll Time OS*	08:20	-	-
10-Sep-25	2473075	TUN002	Underberg Final	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Sep-25	2473074	TUN002	Underberg Final	Conductivity	8.47	±1.5%	mS/m
10-Sep-25	2473072	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
10-Sep-25	2473072	TUN002	Underberg Final	HPC 37*	2	±21%	cfu/mL
10-Sep-25	2473075	TUN002	Underberg Final	Odour*	Nil	-	-
10-Sep-25	2473071	TUN002	Underberg Final	pH OS*	7.40	-	-
10-Sep-25	2473071	TUN002	Underberg Final	Temperature OS*	14.6	-	°C
10-Sep-25	2473075	TUN002	Underberg Final	Turbidity	0.5	±6.1%	NTU
11-Sep-25	2473722	TMZ002	Umzimkhulu Final	Al (AE)	151	±7.6%	µg Al/L
11-Sep-25	2473717	TMZ002	Umzimkhulu Final	Batch No.*	20250201	-	-
11-Sep-25	2473717	TMZ002	Umzimkhulu Final	Cl2 (F) OS*	1.15	-	mg Cl2/L
11-Sep-25	2473717	TMZ002	Umzimkhulu Final	Cl2 (T) OS*	1.27	-	mg Cl2/L
11-Sep-25	2473718	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
11-Sep-25	2473718	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
11-Sep-25	2473717	TMZ002	Umzimkhulu Final	Coll Time OS*	08:05	-	-
11-Sep-25	2473720	TMZ002	Umzimkhulu Final	Conductivity	14.5	±1.5%	mS/m
11-Sep-25	2473718	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
11-Sep-25	2473722	TMZ002	Umzimkhulu Final	Fe (AE)	0.07	±5.4%	mg Fe/L
11-Sep-25	2473718	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	cfu/mL
11-Sep-25	2473717	TMZ002	Umzimkhulu Final	pH OS*	7.40	-	-
11-Sep-25	2473717	TMZ002	Umzimkhulu Final	Temperature OS*	16.9	-	°C
11-Sep-25	2473721	TMZ002	Umzimkhulu Final	Turbidity	1.6	±6.1%	NTU
11-Sep-25	2473723	TMZ004	Umzikhulu Informal Settlement Retic	Batch No.*	20250201	-	-
11-Sep-25	2473723	TMZ004	Umzikhulu Informal Settlement Retic	Cl2 (F) OS*	0.92	-	mg Cl2/L
11-Sep-25	2473723	TMZ004	Umzikhulu Informal Settlement Retic	Cl2 (T) OS*	1.01	-	mg Cl2/L
11-Sep-25	2473724	TMZ004	Umzikhulu Informal Settlement Retic	Coliforms*	1	±15%	MPN/100mL
11-Sep-25	2473723	TMZ004	Umzikhulu Informal Settlement Retic	Coll Time OS*	07:6	-	-
11-Sep-25	2473724	TMZ004	Umzikhulu Informal Settlement Retic	E.coli*	1	±14%	MPN/100mL
11-Sep-25	2473724	TMZ004	Umzikhulu Informal Settlement Retic	HPC 37*	3	±21%	cfu/mL
11-Sep-25	2473723	TMZ004	Umzikhulu Informal Settlement Retic	pH OS*	7.40	-	-
11-Sep-25	2473723	TMZ004	Umzikhulu Informal Settlement Retic	Temperature OS*	15.9	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Sep-25	2473726	TMZ004	Umzikhulu Informal Settlement Retic	Turbidity	1.4	±6.1%	NTU
11-Sep-25	2473727	TMZ005	Umzikhulu Local Municipality Offices	Batch No.*	20250201	-	-
11-Sep-25	2473727	TMZ005	Umzikhulu Local Municipality Offices	Cl2 (F) OS*	1.05	-	mg Cl2/L
11-Sep-25	2473727	TMZ005	Umzikhulu Local Municipality Offices	Cl2 (T) OS*	1.10	-	mg Cl2/L
11-Sep-25	2473728	TMZ005	Umzikhulu Local Municipality Offices	Coliforms*	0	±15%	MPN/100mL
11-Sep-25	2473727	TMZ005	Umzikhulu Local Municipality Offices	Coll Time OS*	7:25	-	-
11-Sep-25	2473728	TMZ005	Umzikhulu Local Municipality Offices	E.coli*	0	±14%	MPN/100mL
11-Sep-25	2473728	TMZ005	Umzikhulu Local Municipality Offices	HPC 37*	0	±21%	cfu/mL
11-Sep-25	2473727	TMZ005	Umzikhulu Local Municipality Offices	pH OS*	7.30	-	-
11-Sep-25	2473727	TMZ005	Umzikhulu Local Municipality Offices	Temperature OS*	15.8	-	°C
11-Sep-25	2473730	TMZ005	Umzikhulu Local Municipality Offices	Turbidity	2.8	±6.1%	NTU
11-Sep-25	2473731	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Batch No.*	20250201	-	-
11-Sep-25	2473731	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Cl2 (F) OS*	0.46	-	mg Cl2/L
11-Sep-25	2473731	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Cl2 (T) OS*	0.55	-	mg Cl2/L
11-Sep-25	2473732	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
11-Sep-25	2473731	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Coll Time OS*	07:37	-	-
11-Sep-25	2473735	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
11-Sep-25	2473734	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Conductivity	14.5	±1.5%	mS/m
11-Sep-25	2473732	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
11-Sep-25	2473732	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
11-Sep-25	2473731	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	pH OS*	7.40	-	-
11-Sep-25	2473731	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Temperature OS*	16.0	-	°C
11-Sep-25	2473735	TMZ006	Umzikhulu Mbizweni Hospital Reticulation	Turbidity	1.0	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

11-Sep-25	2473736	TMZ007	Umzimkhulu Local FET College	Batch No.*	20250201	-	-
11-Sep-25	2473736	TMZ007	Umzimkhulu Local FET College	Cl2 (F) OS*	0.32	-	mg Cl2/L
11-Sep-25	2473736	TMZ007	Umzimkhulu Local FET College	Cl2 (T) OS*	0.44	-	mg Cl2/L
11-Sep-25	2473737	TMZ007	Umzimkhulu Local FET College	Coliforms*	3	±15%	MPN/100mL
11-Sep-25	2473736	TMZ007	Umzimkhulu Local FET College	Coll Time OS*	07:48	-	-
11-Sep-25	2473740	TMZ007	Umzimkhulu Local FET College	Colour	<1.00	±6.5%	mg Pt-Co/L
11-Sep-25	2473739	TMZ007	Umzimkhulu Local FET College	Conductivity	14.5	±1.5%	mS/m
11-Sep-25	2473737	TMZ007	Umzimkhulu Local FET College	E.coli*	0	±14%	MPN/100mL
11-Sep-25	2473737	TMZ007	Umzimkhulu Local FET College	HPC 37*	23	±21%	cfu/mL
11-Sep-25	2473736	TMZ007	Umzimkhulu Local FET College	pH OS*	7.20	-	-
11-Sep-25	2473736	TMZ007	Umzimkhulu Local FET College	Temperature OS*	16.4	-	°C
11-Sep-25	2473740	TMZ007	Umzimkhulu Local FET College	Turbidity	1.1	±6.1%	NTU
11-Sep-25	2473751	TNO002	Nokweja Final	Al (AE)	153	±7.6%	µg Al/L
11-Sep-25	2473746	TNO002	Nokweja Final	Batch No.*	20250401	-	-
11-Sep-25	2473746	TNO002	Nokweja Final	Cl2 (F) OS*	1.32	-	mg Cl2/L
11-Sep-25	2473746	TNO002	Nokweja Final	Cl2 (T) OS*	1.28	-	mg Cl2/L
11-Sep-25	2473747	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
11-Sep-25	2473747	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
11-Sep-25	2473746	TNO002	Nokweja Final	Coll Time OS*	08:00	-	-
11-Sep-25	2473750	TNO002	Nokweja Final	Colour	3.30	±6.5%	mg Pt-Co/L
11-Sep-25	2473749	TNO002	Nokweja Final	Conductivity	15.9	±1.5%	mS/m
11-Sep-25	2473747	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
11-Sep-25	2473747	TNO002	Nokweja Final	HPC 37*	10	±21%	cfu/mL
11-Sep-25	2473750	TNO002	Nokweja Final	Odour*	Mild Chlorinous	-	-
11-Sep-25	2473746	TNO002	Nokweja Final	pH OS*	7.30	-	-
11-Sep-25	2473746	TNO002	Nokweja Final	Temperature OS*	23.4	-	°C
11-Sep-25	2473750	TNO002	Nokweja Final	Turbidity	2.6	±6.1%	NTU
11-Sep-25	2473799	TWA002	Washbank Final	Al (AE)	211	±7.6%	µg Al/L
11-Sep-25	2473794	TWA002	Washbank Final	Batch No.*	20250201	-	-
11-Sep-25	2473794	TWA002	Washbank Final	Cl2 (F) OS*	0.38	-	mg Cl2/L
11-Sep-25	2473794	TWA002	Washbank Final	Cl2 (T) OS*	0.50	-	mg Cl2/L
11-Sep-25	2473795	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
11-Sep-25	2473794	TWA002	Washbank Final	Coll Time OS*	06:38	-	-
11-Sep-25	2473798	TWA002	Washbank Final	Colour	<1.00	±6.5%	mg Pt-Co/L
11-Sep-25	2473797	TWA002	Washbank Final	Conductivity	8.43	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Sep-25	2473795	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
11-Sep-25	2473795	TWA002	Washbank Final	HPC 37*	5	±21%	cfu/mL
11-Sep-25	2473798	TWA002	Washbank Final	Odour*	Nil	-	-
11-Sep-25	2473794	TWA002	Washbank Final	pH OS*	7.30	-	-
11-Sep-25	2473794	TWA002	Washbank Final	Temperature OS*	14.7	-	°C
11-Sep-25	2473798	TWA002	Washbank Final	Turbidity	3.8	±6.1%	NTU
12-Sep-25	2474046	TIB002	Ibisi Final	Al (AE)	111	±7.6%	µg Al/L
12-Sep-25	2474041	TIB002	Ibisi Final	Batch No.*	20250201	-	-
12-Sep-25	2474041	TIB002	Ibisi Final	Cl ₂ (F) OS*	0.15	-	mg Cl ₂ /L
12-Sep-25	2474041	TIB002	Ibisi Final	Cl ₂ (T) OS*	0.25	-	mg Cl ₂ /L
12-Sep-25	2474042	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
12-Sep-25	2474042	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
12-Sep-25	2474041	TIB002	Ibisi Final	Coll Time OS*	6:03	-	-
12-Sep-25	2474045	TIB002	Ibisi Final	Colour	1.50	±6.5%	mg Pt-Co/L
12-Sep-25	2474044	TIB002	Ibisi Final	Conductivity	14.4	±1.5%	mS/m
12-Sep-25	2474042	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
12-Sep-25	2474042	TIB002	Ibisi Final	HPC 37*	0	±21%	cfu/mL
12-Sep-25	2474045	TIB002	Ibisi Final	Odour*	Nil	-	-
12-Sep-25	2474041	TIB002	Ibisi Final	pH OS*	7.60	-	-
12-Sep-25	2474041	TIB002	Ibisi Final	Temperature OS*	14.7	-	°C
12-Sep-25	2474045	TIB002	Ibisi Final	Turbidity	1.9	±6.1%	NTU
12-Sep-25	2474047	TIB003	Ibisi Police Station Reticulation	Batch No.*	20250201	-	-
12-Sep-25	2474047	TIB003	Ibisi Police Station Reticulation	Cl ₂ (F) OS*	0.31	-	mg Cl ₂ /L
12-Sep-25	2474047	TIB003	Ibisi Police Station Reticulation	Cl ₂ (T) OS*	0.40	-	mg Cl ₂ /L
12-Sep-25	2474048	TIB003	Ibisi Police Station Reticulation	Coliforms*	0	±15%	MPN/100mL
12-Sep-25	2474047	TIB003	Ibisi Police Station Reticulation	Coll Time OS*	6:13	-	-
12-Sep-25	2474048	TIB003	Ibisi Police Station Reticulation	E.coli*	0	±14%	MPN/100mL
12-Sep-25	2474048	TIB003	Ibisi Police Station Reticulation	HPC 37*	0	±21%	cfu/mL
12-Sep-25	2474047	TIB003	Ibisi Police Station Reticulation	pH OS*	7.40	-	-
12-Sep-25	2474047	TIB003	Ibisi Police Station Reticulation	Temperature OS*	13.9	-	°C
12-Sep-25	2474050	TIB003	Ibisi Police Station Reticulation	Turbidity	4.9	±6.1%	NTU
12-Sep-25	2474055	TRT002	Rietvlei Final	Batch No.*	20250201	-	-
12-Sep-25	2474055	TRT002	Rietvlei Final	Cl ₂ (F) OS*	1.14	-	mg Cl ₂ /L
12-Sep-25	2474055	TRT002	Rietvlei Final	Cl ₂ (T) OS*	1.26	-	mg Cl ₂ /L
12-Sep-25	2474056	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
12-Sep-25	2474055	TRT002	Rietvlei Final	Coll Time OS*	5:25	-	-
12-Sep-25	2474058	TRT002	Rietvlei Final	Conductivity	20.1	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtololo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

12-Sep-25	2474056	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
12-Sep-25	2474056	TRT002	Rietvlei Final	HPC 37*	1	±21%	cfu/mL
12-Sep-25	2474055	TRT002	Rietvlei Final	pH OS*	7.40	-	-
12-Sep-25	2474055	TRT002	Rietvlei Final	Temperature OS*	15.4	-	°C
12-Sep-25	2474059	TRT002	Rietvlei Final	Turbidity	1.8	±6.1%	NTU
12-Sep-25	2474060	TRT004	Rietvlei Hospital Reticulation	Batch No.*	20250201	-	-
12-Sep-25	2474060	TRT004	Rietvlei Hospital Reticulation	Cl2 (F) OS*	0.74	-	mg Cl2/L
12-Sep-25	2474060	TRT004	Rietvlei Hospital Reticulation	Cl2 (T) OS*	0.80	-	mg Cl2/L
12-Sep-25	2474061	TRT004	Rietvlei Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
12-Sep-25	2474060	TRT004	Rietvlei Hospital Reticulation	Coll Time OS*	5:27	-	-
12-Sep-25	2474061	TRT004	Rietvlei Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
12-Sep-25	2474061	TRT004	Rietvlei Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
12-Sep-25	2474060	TRT004	Rietvlei Hospital Reticulation	pH OS*	7.50	-	-
12-Sep-25	2474060	TRT004	Rietvlei Hospital Reticulation	Temperature OS*	14.8	-	°C
12-Sep-25	2474063	TRT004	Rietvlei Hospital Reticulation	Turbidity	0.9	±6.1%	NTU
16-Sep-25	2477696	TJO001	Jolivet RRT frn Vulamehlo	Batch No.*	20250201	-	-
16-Sep-25	2477696	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (F) OS*	<0.05	-	mg Cl2/L
16-Sep-25	2477696	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (T) OS*	0.06	-	mg Cl2/L
16-Sep-25	2477697	TJO001	Jolivet RRT frn Vulamehlo	Coliforms*	0	±15%	MPN/100mL
16-Sep-25	2477696	TJO001	Jolivet RRT frn Vulamehlo	Coll Time OS*	09:10	-	-
16-Sep-25	2477697	TJO001	Jolivet RRT frn Vulamehlo	E.coli*	0	±14%	MPN/100mL
16-Sep-25	2477697	TJO001	Jolivet RRT frn Vulamehlo	HPC 37*	0	±21%	cfu/mL
16-Sep-25	2477696	TJO001	Jolivet RRT frn Vulamehlo	pH OS*	8.07	-	-
16-Sep-25	2477696	TJO001	Jolivet RRT frn Vulamehlo	Temperature OS*	18.9	-	°C
16-Sep-25	2477699	TJO001	Jolivet RRT frn Vulamehlo	Turbidity	1.2	±6.1%	NTU
16-Sep-25	2477748	TQU002	Mnqumeni Final	Al (AE)	144	±7.6%	µg Al/L
16-Sep-25	2477743	TQU002	Mnqumeni Final	Batch No.*	20250201	-	-
16-Sep-25	2477743	TQU002	Mnqumeni Final	Cl2 (F) OS*	0.58	-	mg Cl2/L
16-Sep-25	2477743	TQU002	Mnqumeni Final	Cl2 (T) OS*	0.70	-	mg Cl2/L
16-Sep-25	2477744	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
16-Sep-25	2477743	TQU002	Mnqumeni Final	Coll Time OS*	6:30	-	-
16-Sep-25	2477746	TQU002	Mnqumeni Final	Conductivity	16.0	±1.5%	mS/m
16-Sep-25	2477744	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

16-Sep-25	2477748	TQU002	Mnqumeni Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
16-Sep-25	2477744	TQU002	Mnqumeni Final	HPC 37*	0	±21%	cfu/mL
16-Sep-25	2477748	TQU002	Mnqumeni Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
16-Sep-25	2477747	TQU002	Mnqumeni Final	Odour*	Nil	-	-
16-Sep-25	2477743	TQU002	Mnqumeni Final	pH OS*	7.40	-	-
16-Sep-25	2477747	TQU002	Mnqumeni Final	Taste*	Nil	-	-
16-Sep-25	2477743	TQU002	Mnqumeni Final	Temperature OS*	14.8	-	°C
16-Sep-25	2477747	TQU002	Mnqumeni Final	Turbidity	0.4	±6.1%	NTU
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Al (AE)	96.6	±7.6%	µg Al/L
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	As (AE)*	<5.00	±7.5%	µg As/L
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	B (AE)	<25.0	±6.6%	µg B/L
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Ba (AE)	27.0	±6.9%	µg Ba/L
16-Sep-25	2477754	TSQ002	Esiqanduleni Final	Batch No.*	20250401	-	-
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Cd (AE)	1.45	±6%	µg Cd/L
16-Sep-25	2477763	TSQ002	Esiqanduleni Final	CHBr3	<10	±6.4%	µg/L
16-Sep-25	2477763	TSQ002	Esiqanduleni Final	CHCl2Br	13.3	±5.7%	µg/L
16-Sep-25	2477763	TSQ002	Esiqanduleni Final	CHCl3	16.5	±6%	µg/L
16-Sep-25	2477763	TSQ002	Esiqanduleni Final	CHClBr2	<10	±5.3%	µg/L
16-Sep-25	2477760	TSQ002	Esiqanduleni Final	Cl*	27.1	±1.8%	mg Cl/L
16-Sep-25	2477754	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	1.40	-	mg Cl2/L
16-Sep-25	2477754	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	1.46	-	mg Cl2/L
16-Sep-25	2477758	TSQ002	Esiqanduleni Final	CN (T)	<25.0	±8.6%	µg CN/L
16-Sep-25	2477755	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
16-Sep-25	2477755	TSQ002	Esiqanduleni Final	Coliphages*	0	±8%	PFU/10ml
16-Sep-25	2477754	TSQ002	Esiqanduleni Final	Coll Time OS*	6:27	-	-
16-Sep-25	2477760	TSQ002	Esiqanduleni Final	Combined NO3 + NO2 ratio*	<0.12	-	-
16-Sep-25	2477763	TSQ002	Esiqanduleni Final	Combined THM Ratio*	0.48	-	-
16-Sep-25	2477760	TSQ002	Esiqanduleni Final	Conductivity	25.1	±1.5%	mS/m
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Cr (T)*	<5.00	±5.3%	µg Cr/L
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Cu (AE)	<0.05	±4.1%	mg Cu/L
16-Sep-25	2477755	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
16-Sep-25	2477760	TSQ002	Esiqanduleni Final	F	<100	±5.3%	µg F/L
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Hg (AE)*	<1.00	±6.5%	µg Hg/L
16-Sep-25	2477755	TSQ002	Esiqanduleni Final	HPC 37*	1	±21%	cfu/mL
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Na (AE)	26.7	±7.5%	mg Na/L
16-Sep-25	2477760	TSQ002	Esiqanduleni Final	NH3*	0.24	±5.5%	mg N/L
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Ni (AE)	<10.0	±5.9%	µg Ni/L
16-Sep-25	2477760	TSQ002	Esiqanduleni Final	NO2*	<0.10	±2.4%	mg N/L
16-Sep-25	2477760	TSQ002	Esiqanduleni Final	NO3*	<0.10	±2.9%	mg N/L
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Pb (AE)	<4.00	±6.7%	µg Pb/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

16-Sep-25	2477754	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
16-Sep-25	2477759	TSQ002	Esiqanduleni Final	Phenols*	<10.0	-	µg/L
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Sb (AE)*	<5.00	±7%	µg Sb/L
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Se (AE)*	<5.00	±7.7%	µg Se/L
16-Sep-25	2477760	TSQ002	Esiqanduleni Final	SO ₄ *	11.3	±1.8%	mg SO ₄ /L
16-Sep-25	2477754	TSQ002	Esiqanduleni Final	Temperature OS*	18.2	-	°C
16-Sep-25	2477761	TSQ002	Esiqanduleni Final	TOC	1.30	±5%	mg C/L
16-Sep-25	2477761	TSQ002	Esiqanduleni Final	Turbidity	1.9	±6.1%	NTU
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	U (AE)*	<10.0	±7.6%	µg U/L
16-Sep-25	2477762	TSQ002	Esiqanduleni Final	Zn (AE)	<0.03	±7.2%	mg Zn/L
17-Sep-25	2474837	TBU002	Bulwer Final	Batch No.*	20250401	-	-
17-Sep-25	2474837	TBU002	Bulwer Final	Cl ₂ (F) OS*	1.09	-	mg Cl ₂ /L
17-Sep-25	2474837	TBU002	Bulwer Final	Cl ₂ (T) OS*	1.15	-	mg Cl ₂ /L
17-Sep-25	2474838	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
17-Sep-25	2474837	TBU002	Bulwer Final	Coll Time OS*	09:26	-	-
17-Sep-25	2474840	TBU002	Bulwer Final	Conductivity	6.82	±1.5%	mS/m
17-Sep-25	2474838	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
17-Sep-25	2474842	TBU002	Bulwer Final	Fe (AE)	0.47	±5.4%	mg Fe/L
17-Sep-25	2474838	TBU002	Bulwer Final	HPC 37*	0	±21%	cfu/mL
17-Sep-25	2474837	TBU002	Bulwer Final	pH OS*	7.40	-	-
17-Sep-25	2474837	TBU002	Bulwer Final	Temperature OS*	12.6	-	°C
17-Sep-25	2474841	TBU002	Bulwer Final	Turbidity	5.6	±6.1%	NTU
17-Sep-25	2474853	TCR002	Creighton Final	Al (AE)	330	±7.6%	µg Al/L
17-Sep-25	2474848	TCR002	Creighton Final	Batch No.*	20250401	-	-
17-Sep-25	2474848	TCR002	Creighton Final	Cl ₂ (F) OS*	1.18	-	mg Cl ₂ /L
17-Sep-25	2474848	TCR002	Creighton Final	Cl ₂ (T) OS*	1.30	-	mg Cl ₂ /L
17-Sep-25	2474849	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
17-Sep-25	2474848	TCR002	Creighton Final	Coll Time OS*	06:49	-	-
17-Sep-25	2474852	TCR002	Creighton Final	Colour	<1.00	±6.5%	mg Pt-Co/L
17-Sep-25	2474851	TCR002	Creighton Final	Conductivity	10.1	±1.5%	mS/m
17-Sep-25	2474849	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
17-Sep-25	2474853	TCR002	Creighton Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
17-Sep-25	2474849	TCR002	Creighton Final	HPC 37*	0	±21%	cfu/mL
17-Sep-25	2474853	TCR002	Creighton Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
17-Sep-25	2474852	TCR002	Creighton Final	Odour*	Nil	-	-
17-Sep-25	2474848	TCR002	Creighton Final	pH OS*	7.20	-	-
17-Sep-25	2474852	TCR002	Creighton Final	Taste*	Nil	-	-
17-Sep-25	2474848	TCR002	Creighton Final	Temperature OS*	11.2	-	°C
17-Sep-25	2474852	TCR002	Creighton Final	Turbidity	0.4	±6.1%	NTU
17-Sep-25	2474858	THL002	Hlanganani Final	Batch No.*	20250401	-	-
17-Sep-25	2474858	THL002	Hlanganani Final	Cl ₂ (F) OS*	1.03	-	mg Cl ₂ /L
17-Sep-25	2474858	THL002	Hlanganani Final	Cl ₂ (T) OS*	1.09	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

17-Sep-25	2474859	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
17-Sep-25	2474858	THL002	Hlanganani Final	Coll Time OS*	10:38	-	-
17-Sep-25	2474861	THL002	Hlanganani Final	Conductivity	11.4	±1.5%	mS/m
17-Sep-25	2474859	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
17-Sep-25	2474859	THL002	Hlanganani Final	HPC 37*	0	±21%	cfu/mL
17-Sep-25	2474858	THL002	Hlanganani Final	pH OS*	7.30	-	-
17-Sep-25	2474858	THL002	Hlanganani Final	Temperature OS*	16.7	-	°C
17-Sep-25	2474862	THL002	Hlanganani Final	Turbidity	<0.2	±6.1%	NTU
17-Sep-25	2474873	TMAN002	Mangwaneni Final	Batch No.*	20250201	-	-
17-Sep-25	2474873	TMAN002	Mangwaneni Final	Cl ₂ (F) OS*	0.40	-	mg Cl ₂ /L
17-Sep-25	2474873	TMAN002	Mangwaneni Final	Cl ₂ (T) OS*	0.52	-	mg Cl ₂ /L
17-Sep-25	2474874	TMAN002	Mangwaneni Final	Coliforms*	0	±15%	MPN/100mL
17-Sep-25	2474873	TMAN002	Mangwaneni Final	Coll Time OS*	10:10	-	-
17-Sep-25	2474876	TMAN002	Mangwaneni Final	Conductivity	14.9	±1.5%	mS/m
17-Sep-25	2474874	TMAN002	Mangwaneni Final	E.coli*	0	±14%	MPN/100mL
17-Sep-25	2474878	TMAN002	Mangwaneni Final	Fe (AE)	0.19	±5.4%	mg Fe/L
17-Sep-25	2474874	TMAN002	Mangwaneni Final	HPC 37*	3	±21%	cfu/mL
17-Sep-25	2474873	TMAN002	Mangwaneni Final	pH OS*	7.40	-	-
17-Sep-25	2474873	TMAN002	Mangwaneni Final	Temperature OS*	15.9	-	°C
17-Sep-25	2474877	TMAN002	Mangwaneni Final	Turbidity	3.0	±6.1%	NTU
17-Sep-25	2474884	TMQA002	Mqatsheni Final	Batch No.*	20250201	-	-
17-Sep-25	2474884	TMQA002	Mqatsheni Final	Cl ₂ (F) OS*	1.70	-	mg Cl ₂ /L
17-Sep-25	2474884	TMQA002	Mqatsheni Final	Cl ₂ (T) OS*	1.79	-	mg Cl ₂ /L
17-Sep-25	2474885	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
17-Sep-25	2474884	TMQA002	Mqatsheni Final	Coll Time OS*	07:48	-	-
17-Sep-25	2474887	TMQA002	Mqatsheni Final	Conductivity	24.2	±1.5%	mS/m
17-Sep-25	2474885	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
17-Sep-25	2474885	TMQA002	Mqatsheni Final	HPC 37*	0	±21%	cfu/mL
17-Sep-25	2474884	TMQA002	Mqatsheni Final	pH OS*	8.90	-	-
17-Sep-25	2474884	TMQA002	Mqatsheni Final	Temperature OS*	17.0	-	°C
17-Sep-25	2474888	TMQA002	Mqatsheni Final	Turbidity	0.9	±6.1%	NTU
17-Sep-25	2474894	TRV002	Riverside Final	Batch No.*	20250401	-	-
17-Sep-25	2474894	TRV002	Riverside Final	Cl ₂ (F) OS*	1.68	-	mg Cl ₂ /L
17-Sep-25	2474894	TRV002	Riverside Final	Cl ₂ (T) OS*	1.80	-	mg Cl ₂ /L
17-Sep-25	2474895	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
17-Sep-25	2474894	TRV002	Riverside Final	Coll Time OS*	07:38	-	-
17-Sep-25	2474897	TRV002	Riverside Final	Conductivity	10.7	±1.5%	mS/m
17-Sep-25	2474895	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
17-Sep-25	2474895	TRV002	Riverside Final	HPC 37*	2	±21%	cfu/mL
17-Sep-25	2474894	TRV002	Riverside Final	pH OS*	7.30	-	-
17-Sep-25	2474894	TRV002	Riverside Final	Temperature OS*	12.8	-	°C
17-Sep-25	2474898	TRV002	Riverside Final	Turbidity	1.4	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

17-Sep-25	2474904	TST002	St Appollinaris Final	Batch No.*	20250401	-	-
17-Sep-25	2474904	TST002	St Appollinaris Final	Cl2 (F) OS*	0.87	-	mg Cl2/L
17-Sep-25	2474904	TST002	St Appollinaris Final	Cl2 (T) OS*	0.96	-	mg Cl2/L
17-Sep-25	2474905	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
17-Sep-25	2474904	TST002	St Appollinaris Final	Coll Time OS*	08:28	-	-
17-Sep-25	2474907	TST002	St Appollinaris Final	Conductivity	11.3	±1.5%	mS/m
17-Sep-25	2474905	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
17-Sep-25	2474905	TST002	St Appollinaris Final	HPC 37*	1	±21%	cfu/mL
17-Sep-25	2474904	TST002	St Appollinaris Final	pH OS*	7.30	-	-
17-Sep-25	2474904	TST002	St Appollinaris Final	Temperature OS*	13.4	-	°C
17-Sep-25	2474908	TST002	St Appollinaris Final	Turbidity	2.7	±6.1%	NTU
17-Sep-25	2474909	TST003	St Appollinaris Hospital Reticulation	Batch No.*	20250401	-	-
17-Sep-25	2474909	TST003	St Appollinaris Hospital Reticulation	Cl2 (F) OS*	0.42	-	mg Cl2/L
17-Sep-25	2474909	TST003	St Appollinaris Hospital Reticulation	Cl2 (T) OS*	0.48	-	mg Cl2/L
17-Sep-25	2474910	TST003	St Appollinaris Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
17-Sep-25	2474909	TST003	St Appollinaris Hospital Reticulation	Coll Time OS*	08:10	-	-
17-Sep-25	2474913	TST003	St Appollinaris Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
17-Sep-25	2474912	TST003	St Appollinaris Hospital Reticulation	Conductivity	11.2	±1.5%	mS/m
17-Sep-25	2474910	TST003	St Appollinaris Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
17-Sep-25	2474910	TST003	St Appollinaris Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
17-Sep-25	2474913	TST003	St Appollinaris Hospital Reticulation	Odour*	Nil	-	-
17-Sep-25	2474909	TST003	St Appollinaris Hospital Reticulation	pH OS*	7.40	-	-
17-Sep-25	2474909	TST003	St Appollinaris Hospital Reticulation	Temperature OS*	14.2	-	°C
17-Sep-25	2474913	TST003	St Appollinaris Hospital Reticulation	Turbidity	4.5	±6.1%	NTU
17-Sep-25	2474924	TUN002	Underberg Final	Al (AE)	<25.0	±7.6%	µg Al/L
17-Sep-25	2474919	TUN002	Underberg Final	Batch No.*	20250201	-	-
17-Sep-25	2474919	TUN002	Underberg Final	Cl2 (F) OS*	0.45	-	mg Cl2/L
17-Sep-25	2474919	TUN002	Underberg Final	Cl2 (T) OS*	0.59	-	mg Cl2/L
17-Sep-25	2474920	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
17-Sep-25	2474919	TUN002	Underberg Final	Coll Time OS*	08:59	-	-
17-Sep-25	2474922	TUN002	Underberg Final	Conductivity	8.61	±1.5%	mS/m
17-Sep-25	2474920	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
17-Sep-25	2474920	TUN002	Underberg Final	HPC 37*	0	±21%	cfu/mL
17-Sep-25	2474919	TUN002	Underberg Final	pH OS*	7.50	-	-
17-Sep-25	2474919	TUN002	Underberg Final	Temperature OS*	15.5	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtololo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

17-Sep-25	2474923	TUN002	Underberg Final	Turbidity	0.6	±6.1%	NTU
18-Sep-25	2475565	TFR002	Franklin Final	Al (AE)	299	±7.6%	µg Al/L
18-Sep-25	2475560	TFR002	Franklin Final	Batch No.*	20250401	-	-
18-Sep-25	2475560	TFR002	Franklin Final	Cl ₂ (F) OS*	1.18	-	mg Cl ₂ /L
18-Sep-25	2475560	TFR002	Franklin Final	Cl ₂ (T) OS*	1.26	-	mg Cl ₂ /L
18-Sep-25	2475561	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
18-Sep-25	2475561	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
18-Sep-25	2475560	TFR002	Franklin Final	Coll Time OS*	6:33	-	-
18-Sep-25	2475563	TFR002	Franklin Final	Conductivity	12.7	±1.5%	mS/m
18-Sep-25	2475561	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
18-Sep-25	2475561	TFR002	Franklin Final	HPC 37*	0	±21%	cfu/mL
18-Sep-25	2475560	TFR002	Franklin Final	pH OS*	7.50	-	-
18-Sep-25	2475560	TFR002	Franklin Final	Temperature OS*	17.7	-	°C
18-Sep-25	2475564	TFR002	Franklin Final	Turbidity	2.4	±6.1%	NTU
18-Sep-25	2478686	TIB002	Ibisi Final	Al (AE)	318	±7.6%	µg Al/L
18-Sep-25	2478681	TIB002	Ibisi Final	Batch No.*	20250401	-	-
18-Sep-25	2478681	TIB002	Ibisi Final	Cl ₂ (F) OS*	1.04	-	mg Cl ₂ /L
18-Sep-25	2478681	TIB002	Ibisi Final	Cl ₂ (T) OS*	1.09	-	mg Cl ₂ /L
18-Sep-25	2478682	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
18-Sep-25	2478682	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
18-Sep-25	2478681	TIB002	Ibisi Final	Coll Time OS*	7:30	-	-
18-Sep-25	2478684	TIB002	Ibisi Final	Conductivity	13.6	±1.5%	mS/m
18-Sep-25	2478682	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
18-Sep-25	2478682	TIB002	Ibisi Final	HPC 37*	8	±21%	cfu/mL
18-Sep-25	2478681	TIB002	Ibisi Final	pH OS*	7.30	-	-
18-Sep-25	2478681	TIB002	Ibisi Final	Temperature OS*	18.2	-	°C
18-Sep-25	2478685	TIB002	Ibisi Final	Turbidity	5.3	±6.1%	NTU
18-Sep-25	2475576	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
18-Sep-25	2475571	TKK002	Kokstad Final	Batch No.*	20250401	-	-
18-Sep-25	2475571	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.22	-	mg Cl ₂ /L
18-Sep-25	2475571	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.31	-	mg Cl ₂ /L
18-Sep-25	2475572	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
18-Sep-25	2475572	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
18-Sep-25	2475571	TKK002	Kokstad Final	Coll Time OS*	7:18	-	-
18-Sep-25	2475574	TKK002	Kokstad Final	Conductivity	17.0	±1.5%	mS/m
18-Sep-25	2475572	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
18-Sep-25	2475576	TKK002	Kokstad Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
18-Sep-25	2475572	TKK002	Kokstad Final	HPC 37*	1	±21%	cfu/mL
18-Sep-25	2475571	TKK002	Kokstad Final	pH OS*	7.50	-	-
18-Sep-25	2475571	TKK002	Kokstad Final	Temperature OS*	16.6	-	°C
18-Sep-25	2475575	TKK002	Kokstad Final	Turbidity	0.3	±6.1%	NTU
18-Sep-25	2475582	TKK011	Kokstad Hospital Reticulation	Batch No.*	20250401	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

18-Sep-25	2475582	TKK011	Kokstad Hospital Reticulation	Cl ₂ (F) OS*	0.42	-	mg Cl ₂ /L
18-Sep-25	2475582	TKK011	Kokstad Hospital Reticulation	Cl ₂ (T) OS*	0.53	-	mg Cl ₂ /L
18-Sep-25	2475583	TKK011	Kokstad Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
18-Sep-25	2475582	TKK011	Kokstad Hospital Reticulation	Coll Time OS*	8:35	-	-
18-Sep-25	2475586	TKK011	Kokstad Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
18-Sep-25	2475585	TKK011	Kokstad Hospital Reticulation	Conductivity	16.8	±1.5%	mS/m
18-Sep-25	2475583	TKK011	Kokstad Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
18-Sep-25	2475583	TKK011	Kokstad Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
18-Sep-25	2475582	TKK011	Kokstad Hospital Reticulation	pH OS*	7.40	-	-
18-Sep-25	2475582	TKK011	Kokstad Hospital Reticulation	Temperature OS*	17.0	-	°C
18-Sep-25	2475586	TKK011	Kokstad Hospital Reticulation	Turbidity	<0.2	±6.1%	NTU
18-Sep-25	2478319	TMZ002	Umzimkhulu Final	Al (AE)	96.7	±7.6%	µg Al/L
18-Sep-25	2478314	TMZ002	Umzimkhulu Final	Batch No.*	20250401	-	-
18-Sep-25	2478314	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	1.22	-	mg Cl ₂ /L
18-Sep-25	2478314	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	1.26	-	mg Cl ₂ /L
18-Sep-25	2478315	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
18-Sep-25	2478315	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
18-Sep-25	2478314	TMZ002	Umzimkhulu Final	Coll Time OS*	8:00	-	-
18-Sep-25	2478318	TMZ002	Umzimkhulu Final	Colour	<1.00	±6.5%	mg Pt-Co/L
18-Sep-25	2478317	TMZ002	Umzimkhulu Final	Conductivity	14.5	±1.5%	mS/m
18-Sep-25	2478315	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
18-Sep-25	2478315	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	cfu/mL
18-Sep-25	2478318	TMZ002	Umzimkhulu Final	Odour*	Nil	-	-
18-Sep-25	2478314	TMZ002	Umzimkhulu Final	pH OS*	7.30	-	-
18-Sep-25	2478314	TMZ002	Umzimkhulu Final	Temperature OS*	19.3	-	°C
18-Sep-25	2478318	TMZ002	Umzimkhulu Final	Turbidity	1.1	±6.1%	NTU
18-Sep-25	2475609	TNJU002	KwaNjunga Final	Batch No.*	20250401	-	-
18-Sep-25	2475609	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	0.71	-	mg Cl ₂ /L
18-Sep-25	2475609	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	0.82	-	mg Cl ₂ /L
18-Sep-25	2475610	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
18-Sep-25	2475609	TNJU002	KwaNjunga Final	Coll Time OS*	5:49	-	-
18-Sep-25	2475612	TNJU002	KwaNjunga Final	Conductivity	18.6	±1.5%	mS/m
18-Sep-25	2475610	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
18-Sep-25	2475614	TNJU002	KwaNjunga Final	Fe (AE)	0.13	±5.4%	mg Fe/L
18-Sep-25	2475610	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	cfu/mL
18-Sep-25	2475614	TNJU002	KwaNjunga Final	Mn (AE)	<0.01	±6.2%	mg Mn/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

18-Sep-25	2475613	TNJU002	KwaNjunga Final	Odour*	Nil	-	-
18-Sep-25	2475609	TNJU002	KwaNjunga Final	pH OS*	7.30	-	-
18-Sep-25	2475609	TNJU002	KwaNjunga Final	Temperature OS*	17.2	-	°C
18-Sep-25	2475613	TNJU002	KwaNjunga Final	Turbidity	0.5	±6.1%	NTU
18-Sep-25	2478330	TNO002	Nokweja Final	Al (AE)	120	±7.6%	µg Al/L
18-Sep-25	2478325	TNO002	Nokweja Final	Batch No.*	20250401	-	-
18-Sep-25	2478325	TNO002	Nokweja Final	Cl ₂ (F) OS*	1.38	-	mg Cl ₂ /L
18-Sep-25	2478325	TNO002	Nokweja Final	Cl ₂ (T) OS*	1.49	-	mg Cl ₂ /L
18-Sep-25	2478326	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
18-Sep-25	2478326	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
18-Sep-25	2478325	TNO002	Nokweja Final	Coll Time OS*	8:35	-	-
18-Sep-25	2478328	TNO002	Nokweja Final	Conductivity	15.7	±1.5%	mS/m
18-Sep-25	2478326	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
18-Sep-25	2478326	TNO002	Nokweja Final	HPC 37*	7	±21%	cfu/mL
18-Sep-25	2478325	TNO002	Nokweja Final	pH OS*	7.30	-	-
18-Sep-25	2478325	TNO002	Nokweja Final	Temperature OS*	17.6	-	°C
18-Sep-25	2478329	TNO002	Nokweja Final	Turbidity	2.4	±6.1%	NTU
18-Sep-25	2478696	TRT002	Rietvlei Final	Al (AE)	489	±7.6%	µg Al/L
18-Sep-25	2478691	TRT002	Rietvlei Final	Batch No.*	20250401	-	-
18-Sep-25	2478691	TRT002	Rietvlei Final	Cl ₂ (F) OS*	1.12	-	mg Cl ₂ /L
18-Sep-25	2478691	TRT002	Rietvlei Final	Cl ₂ (T) OS*	1.24	-	mg Cl ₂ /L
18-Sep-25	2478692	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
18-Sep-25	2478691	TRT002	Rietvlei Final	Coll Time OS*	6:44	-	-
18-Sep-25	2478694	TRT002	Rietvlei Final	Conductivity	19.8	±1.5%	mS/m
18-Sep-25	2478692	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
18-Sep-25	2478696	TRT002	Rietvlei Final	Fe (AE)	0.05	±5.4%	mg Fe/L
18-Sep-25	2478692	TRT002	Rietvlei Final	HPC 37*	0	±21%	cfu/mL
18-Sep-25	2478696	TRT002	Rietvlei Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
18-Sep-25	2478695	TRT002	Rietvlei Final	Odour*	Nil	-	-
18-Sep-25	2478691	TRT002	Rietvlei Final	pH OS*	7.20	-	-
18-Sep-25	2478691	TRT002	Rietvlei Final	Temperature OS*	15.0	-	°C
18-Sep-25	2478695	TRT002	Rietvlei Final	Turbidity	1.7	±6.1%	NTU
18-Sep-25	2478374	TWA002	Washbank Final	Al (AE)	231	±7.6%	µg Al/L
18-Sep-25	2478369	TWA002	Washbank Final	Batch No.*	20250401	-	-
18-Sep-25	2478369	TWA002	Washbank Final	Cl ₂ (F) OS*	0.44	-	mg Cl ₂ /L
18-Sep-25	2478369	TWA002	Washbank Final	Cl ₂ (T) OS*	0.46	-	mg Cl ₂ /L
18-Sep-25	2478370	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
18-Sep-25	2478369	TWA002	Washbank Final	Coll Time OS*	7:50	-	-
18-Sep-25	2478372	TWA002	Washbank Final	Conductivity	8.62	±1.5%	mS/m
18-Sep-25	2478370	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
18-Sep-25	2478370	TWA002	Washbank Final	HPC 37*	4	±21%	cfu/mL
18-Sep-25	2478369	TWA002	Washbank Final	pH OS*	7.40	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

18-Sep-25	2478369	TWA002	Washbank Final	Temperature OS*	19.1	-	°C
18-Sep-25	2478373	TWA002	Washbank Final	Turbidity	4.4	±6.1%	NTU
22-Sep-25	2479785	TFR002	Franklin Final	Al (AE)	299	±7.6%	µg Al/L
22-Sep-25	2479780	TFR002	Franklin Final	Batch No.*	20250201	-	-
22-Sep-25	2479780	TFR002	Franklin Final	Cl2 (F) OS*	1.25	-	mg Cl2/L
22-Sep-25	2479780	TFR002	Franklin Final	Cl2 (T) OS*	1.31	-	mg Cl2/L
22-Sep-25	2479781	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
22-Sep-25	2479781	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
22-Sep-25	2479780	TFR002	Franklin Final	Coll Time OS*	07:50	-	-
22-Sep-25	2479784	TFR002	Franklin Final	Colour	<1.00	±6.5%	mg Pt-Co/L
22-Sep-25	2479783	TFR002	Franklin Final	Conductivity	13.0	±1.5%	mS/m
22-Sep-25	2479781	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
22-Sep-25	2479785	TFR002	Franklin Final	Fe (AE)	0.12	±5.4%	mg Fe/L
22-Sep-25	2479781	TFR002	Franklin Final	HPC 37*	1	±21%	cfu/mL
22-Sep-25	2479785	TFR002	Franklin Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
22-Sep-25	2479784	TFR002	Franklin Final	Odour*	Mild Chlorinous	-	-
22-Sep-25	2479780	TFR002	Franklin Final	pH OS*	7.40	-	-
22-Sep-25	2479780	TFR002	Franklin Final	Temperature OS*	17.5	-	°C
22-Sep-25	2479784	TFR002	Franklin Final	Turbidity	2.3	±6.1%	NTU
22-Sep-25	2479786	TFR003	Franklin Police Station Retic	Batch No.*	20250201	-	-
22-Sep-25	2479786	TFR003	Franklin Police Station Retic	Cl2 (F) OS*	1.07	-	mg Cl2/L
22-Sep-25	2479786	TFR003	Franklin Police Station Retic	Cl2 (T) OS*	1.15	-	mg Cl2/L
22-Sep-25	2479787	TFR003	Franklin Police Station Retic	Coliforms*	0	±15%	MPN/100mL
22-Sep-25	2479786	TFR003	Franklin Police Station Retic	Coll Time OS*	08:00	-	-
22-Sep-25	2479790	TFR003	Franklin Police Station Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
22-Sep-25	2479789	TFR003	Franklin Police Station Retic	Conductivity	13.0	±1.5%	mS/m
22-Sep-25	2479787	TFR003	Franklin Police Station Retic	E.coli*	0	±14%	MPN/100mL
22-Sep-25	2479787	TFR003	Franklin Police Station Retic	HPC 37*	0	±21%	cfu/mL
22-Sep-25	2479790	TFR003	Franklin Police Station Retic	Odour*	Strong Chlorinous	-	-
22-Sep-25	2479786	TFR003	Franklin Police Station Retic	pH OS*	7.30	-	-
22-Sep-25	2479786	TFR003	Franklin Police Station Retic	Temperature OS*	16.8	-	°C
22-Sep-25	2479790	TFR003	Franklin Police Station Retic	Turbidity	2.7	±6.1%	NTU
22-Sep-25	2479818	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
22-Sep-25	2479813	TKK002	Kokstad Final	Batch No.*	20250401	-	-
22-Sep-25	2479813	TKK002	Kokstad Final	Cl2 (F) OS*	1.36	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

22-Sep-25	2479813	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.47	-	mg Cl ₂ /L
22-Sep-25	2479814	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
22-Sep-25	2479814	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
22-Sep-25	2479813	TKK002	Kokstad Final	Coll Time OS*	08:00	-	-
22-Sep-25	2479817	TKK002	Kokstad Final	Colour	<1.00	±6.5%	mg Pt-Co/L
22-Sep-25	2479816	TKK002	Kokstad Final	Conductivity	17.3	±1.5%	mS/m
22-Sep-25	2479814	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
22-Sep-25	2479814	TKK002	Kokstad Final	HPC 37*	0	±21%	cfu/mL
22-Sep-25	2479817	TKK002	Kokstad Final	Odour*	Nil	-	-
22-Sep-25	2479813	TKK002	Kokstad Final	pH OS*	7.30	-	-
22-Sep-25	2479817	TKK002	Kokstad Final	Taste*	Nil	-	-
22-Sep-25	2479813	TKK002	Kokstad Final	Temperature OS*	17.3	-	°C
22-Sep-25	2479817	TKK002	Kokstad Final	Turbidity	0.3	±6.1%	NTU
22-Sep-25	2479828	TKK006	Kokstad Bongweni Correctional Serv Retic	Batch No.*	20250401	-	-
22-Sep-25	2479828	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl ₂ (F) OS*	0.48	-	mg Cl ₂ /L
22-Sep-25	2479828	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl ₂ (T) OS*	0.56	-	mg Cl ₂ /L
22-Sep-25	2479829	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliforms*	0	±15%	MPN/100mL
22-Sep-25	2479828	TKK006	Kokstad Bongweni Correctional Serv Retic	Coll Time OS*	07:28	-	-
22-Sep-25	2479831	TKK006	Kokstad Bongweni Correctional Serv Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
22-Sep-25	2479829	TKK006	Kokstad Bongweni Correctional Serv Retic	E.coli*	0	±14%	MPN/100mL
22-Sep-25	2479829	TKK006	Kokstad Bongweni Correctional Serv Retic	HPC 37*	0	±21%	cfu/mL
22-Sep-25	2479831	TKK006	Kokstad Bongweni Correctional Serv Retic	Odour*	Nil	-	-
22-Sep-25	2479828	TKK006	Kokstad Bongweni Correctional Serv Retic	pH OS*	7.30	-	-
22-Sep-25	2479831	TKK006	Kokstad Bongweni Correctional Serv Retic	Taste*	Nil	-	-
22-Sep-25	2479828	TKK006	Kokstad Bongweni Correctional Serv Retic	Temperature OS*	16.2	-	°C
22-Sep-25	2479831	TKK006	Kokstad Bongweni Correctional Serv Retic	Turbidity	0.3	±6.1%	NTU
22-Sep-25	2479832	TKK007	Kokstad Shayamoya Reticulation	Batch No.*	20250401	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

22-Sep-25	2479832	TKK007	Kokstad Shayamoya Reticulation	Cl ₂ (F) OS*	0.52	-	mg Cl ₂ /L
22-Sep-25	2479832	TKK007	Kokstad Shayamoya Reticulation	Cl ₂ (T) OS*	0.60	-	mg Cl ₂ /L
22-Sep-25	2479833	TKK007	Kokstad Shayamoya Reticulation	Coliforms*	0	±15%	MPN/100mL
22-Sep-25	2479832	TKK007	Kokstad Shayamoya Reticulation	Coll Time OS*	08:30	-	-
22-Sep-25	2479833	TKK007	Kokstad Shayamoya Reticulation	E.coli*	0	±14%	MPN/100mL
22-Sep-25	2479833	TKK007	Kokstad Shayamoya Reticulation	HPC 37*	0	±21%	cfu/mL
22-Sep-25	2479832	TKK007	Kokstad Shayamoya Reticulation	pH OS*	7.30	-	-
22-Sep-25	2479832	TKK007	Kokstad Shayamoya Reticulation	Temperature OS*	17.8	-	°C
22-Sep-25	2479835	TKK007	Kokstad Shayamoya Reticulation	Turbidity	0.3	±6.1%	NTU
22-Sep-25	2479836	TKK009	Kokstad Farm Fresh Produce Market	Batch No.*	20250401	-	-
22-Sep-25	2479836	TKK009	Kokstad Farm Fresh Produce Market	Cl ₂ (F) OS*	0.78	-	mg Cl ₂ /L
22-Sep-25	2479836	TKK009	Kokstad Farm Fresh Produce Market	Cl ₂ (T) OS*	0.88	-	mg Cl ₂ /L
22-Sep-25	2479837	TKK009	Kokstad Farm Fresh Produce Market	Coliforms*	0	±15%	MPN/100mL
22-Sep-25	2479836	TKK009	Kokstad Farm Fresh Produce Market	Coll Time OS*	08:47	-	-
22-Sep-25	2479839	TKK009	Kokstad Farm Fresh Produce Market	Colour	<1.00	±6.5%	mg Pt-Co/L
22-Sep-25	2479837	TKK009	Kokstad Farm Fresh Produce Market	E.coli*	0	±14%	MPN/100mL
22-Sep-25	2479837	TKK009	Kokstad Farm Fresh Produce Market	HPC 37*	1	±21%	cfu/mL
22-Sep-25	2479839	TKK009	Kokstad Farm Fresh Produce Market	Odour*	Nil	-	-
22-Sep-25	2479836	TKK009	Kokstad Farm Fresh Produce Market	pH OS*	7.40	-	-
22-Sep-25	2479839	TKK009	Kokstad Farm Fresh Produce Market	Taste*	Nil	-	-
22-Sep-25	2479836	TKK009	Kokstad Farm Fresh Produce Market	Temperature OS*	19.3	-	°C
22-Sep-25	2479839	TKK009	Kokstad Farm Fresh Produce Market	Turbidity	0.2	±6.1%	NTU
22-Sep-25	2479840	TKK012	Kokstad FET College Reticulation	Batch No.*	20250401	-	-
22-Sep-25	2479840	TKK012	Kokstad FET College Reticulation	Cl ₂ (F) OS*	0.68	-	mg Cl ₂ /L
22-Sep-25	2479840	TKK012	Kokstad FET College Reticulation	Cl ₂ (T) OS*	0.74	-	mg Cl ₂ /L
22-Sep-25	2479841	TKK012	Kokstad FET College Reticulation	Coliforms*	0	±15%	MPN/100mL
22-Sep-25	2479840	TKK012	Kokstad FET College Reticulation	Coll Time OS*	07:00	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

22-Sep-25	2479841	TKK012	Kokstad FET College Reticulation	E.coli*	0	±14%	MPN/100mL
22-Sep-25	2479841	TKK012	Kokstad FET College Reticulation	HPC 37*	0	±21%	cfu/mL
22-Sep-25	2479840	TKK012	Kokstad FET College Reticulation	pH OS*	7.20	-	-
22-Sep-25	2479840	TKK012	Kokstad FET College Reticulation	Temperature OS*	15.5	-	°C
22-Sep-25	2479843	TKK012	Kokstad FET College Reticulation	Turbidity	0.3	±6.1%	NTU
22-Sep-25	2479889	TNJU002	KwaNjunga Final	Batch No.*	20250201	-	-
22-Sep-25	2479889	TNJU002	KwaNjunga Final	Cl2 (F) OS*	0.95	-	mg Cl2/L
22-Sep-25	2479889	TNJU002	KwaNjunga Final	Cl2 (T) OS*	1.08	-	mg Cl2/L
22-Sep-25	2479890	TNJU002	KwaNjunga Final	Coliforms*	34	±15%	MPN/100mL
22-Sep-25	2479889	TNJU002	KwaNjunga Final	Coll Time OS*	08:46	-	-
22-Sep-25	2479892	TNJU002	KwaNjunga Final	Conductivity	20.0	±1.5%	mS/m
22-Sep-25	2479890	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
22-Sep-25	2479890	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	cfu/mL
22-Sep-25	2479889	TNJU002	KwaNjunga Final	pH OS*	7.50	-	-
22-Sep-25	2479889	TNJU002	KwaNjunga Final	Temperature OS*	17.9	-	°C
22-Sep-25	2479893	TNJU002	KwaNjunga Final	Turbidity	0.2	±6.1%	NTU
22-Sep-25	2479894	TNJU003	KwaNjunga Reticulation	Batch No.*	20250201	-	-
22-Sep-25	2479894	TNJU003	KwaNjunga Reticulation	Cl2 (F) OS*	0.15	-	mg Cl2/L
22-Sep-25	2479894	TNJU003	KwaNjunga Reticulation	Cl2 (T) OS*	0.22	-	mg Cl2/L
22-Sep-25	2479895	TNJU003	KwaNjunga Reticulation	Coliforms*	2	±15%	MPN/100mL
22-Sep-25	2479894	TNJU003	KwaNjunga Reticulation	Coll Time OS*	08:525	-	-
22-Sep-25	2479895	TNJU003	KwaNjunga Reticulation	E.coli*	0	±14%	MPN/100mL
22-Sep-25	2479895	TNJU003	KwaNjunga Reticulation	HPC 37*	1	±21%	cfu/mL
22-Sep-25	2479894	TNJU003	KwaNjunga Reticulation	pH OS*	7.40	-	-
22-Sep-25	2479894	TNJU003	KwaNjunga Reticulation	Temperature OS*	17.4	-	°C
22-Sep-25	2479897	TNJU003	KwaNjunga Reticulation	Turbidity	0.3	±6.1%	NTU
23-Sep-25	2480447	TQU002	Mnqumeni Final	Batch No.*	20250401	-	-
23-Sep-25	2480447	TQU002	Mnqumeni Final	Cl2 (F) OS*	0.50	-	mg Cl2/L
23-Sep-25	2480447	TQU002	Mnqumeni Final	Cl2 (T) OS*	0.58	-	mg Cl2/L
23-Sep-25	2480448	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
23-Sep-25	2480447	TQU002	Mnqumeni Final	Coll Time OS*	06:40	-	-
23-Sep-25	2480450	TQU002	Mnqumeni Final	Conductivity	19.8	±1.5%	mS/m
23-Sep-25	2480448	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
23-Sep-25	2480448	TQU002	Mnqumeni Final	HPC 37*	0	±21%	cfu/mL
23-Sep-25	2480447	TQU002	Mnqumeni Final	pH OS*	7.60	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

23-Sep-25	2480447	TQU002	Mnqumeni Final	Temperature OS*	17.5	-	°C
23-Sep-25	2480451	TQU002	Mnqumeni Final	Turbidity	<0.2	±6.1%	NTU
23-Sep-25	2480452	TQU003	Mnqumeni Reticulation	Batch No.*	20250401	-	-
23-Sep-25	2480452	TQU003	Mnqumeni Reticulation	Cl ₂ (F) OS*	0.44	-	mg Cl ₂ /L
23-Sep-25	2480452	TQU003	Mnqumeni Reticulation	Cl ₂ (T) OS*	0.49	-	mg Cl ₂ /L
23-Sep-25	2480453	TQU003	Mnqumeni Reticulation	Coliforms*	0	±15%	MPN/100mL
23-Sep-25	2480452	TQU003	Mnqumeni Reticulation	Coll Time OS*	06:44	-	-
23-Sep-25	2480453	TQU003	Mnqumeni Reticulation	E.coli*	0	±14%	MPN/100mL
23-Sep-25	2480453	TQU003	Mnqumeni Reticulation	HPC 37*	0	±21%	cfu/mL
23-Sep-25	2480452	TQU003	Mnqumeni Reticulation	pH OS*	7.30	-	-
23-Sep-25	2480452	TQU003	Mnqumeni Reticulation	Temperature OS*	17.7	-	°C
23-Sep-25	2480455	TQU003	Mnqumeni Reticulation	Turbidity	0.9	±6.1%	NTU
23-Sep-25	2480466	TSQ002	Esiqanduleni Final	Al (AE)	60.9	±7.6%	µg Al/L
23-Sep-25	2480461	TSQ002	Esiqanduleni Final	Batch No.*	20250401	-	-
23-Sep-25	2480461	TSQ002	Esiqanduleni Final	Cl ₂ (F) OS*	1.20	-	mg Cl ₂ /L
23-Sep-25	2480461	TSQ002	Esiqanduleni Final	Cl ₂ (T) OS*	1.38	-	mg Cl ₂ /L
23-Sep-25	2480462	TSQ002	Esiqanduleni Final	Coliforms*	5	±15%	MPN/100mL
23-Sep-25	2480461	TSQ002	Esiqanduleni Final	Coll Time OS*	08:20	-	-
23-Sep-25	2480465	TSQ002	Esiqanduleni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
23-Sep-25	2480464	TSQ002	Esiqanduleni Final	Conductivity	24.0	±1.5%	mS/m
23-Sep-25	2480462	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
23-Sep-25	2480462	TSQ002	Esiqanduleni Final	HPC 37*	5	±21%	cfu/mL
23-Sep-25	2480465	TSQ002	Esiqanduleni Final	Odour*	Nil	-	-
23-Sep-25	2480461	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
23-Sep-25	2480465	TSQ002	Esiqanduleni Final	Taste*	Nil	-	-
23-Sep-25	2480461	TSQ002	Esiqanduleni Final	Temperature OS*	14.3	-	°C
23-Sep-25	2480465	TSQ002	Esiqanduleni Final	Turbidity	0.7	±6.1%	NTU
23-Sep-25	2480467	TSQ003	Esiqanduleni Reticulation	Batch No.*	20250401	-	-
23-Sep-25	2480467	TSQ003	Esiqanduleni Reticulation	Cl ₂ (F) OS*	0.84	-	mg Cl ₂ /L
23-Sep-25	2480467	TSQ003	Esiqanduleni Reticulation	Cl ₂ (T) OS*	0.99	-	mg Cl ₂ /L
23-Sep-25	2480468	TSQ003	Esiqanduleni Reticulation	Coliforms*	0	±15%	MPN/100mL
23-Sep-25	2480467	TSQ003	Esiqanduleni Reticulation	Coll Time OS*	08:30	-	-
23-Sep-25	2480468	TSQ003	Esiqanduleni Reticulation	E.coli*	0	±14%	MPN/100mL
23-Sep-25	2480468	TSQ003	Esiqanduleni Reticulation	HPC 37*	0	±21%	cfu/mL
23-Sep-25	2480467	TSQ003	Esiqanduleni Reticulation	pH OS*	7.30	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

23-Sep-25	2480467	TSQ003	Esiqanduleni Reticulation	Temperature OS*	12.4	-	°C
23-Sep-25	2480470	TSQ003	Esiqanduleni Reticulation	Turbidity	0.9	±6.1%	NTU
25-Sep-25	2479740	TBU002	Bulwer Final	Batch No.*	20250401	-	-
25-Sep-25	2479740	TBU002	Bulwer Final	Cl ₂ (F) OS*	0.54	-	mg Cl ₂ /L
25-Sep-25	2479740	TBU002	Bulwer Final	Cl ₂ (T) OS*	0.60	-	mg Cl ₂ /L
25-Sep-25	2479741	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
25-Sep-25	2479740	TBU002	Bulwer Final	Coll Time OS*	09:03	-	-
25-Sep-25	2479744	TBU002	Bulwer Final	Colour	2.30	±6.5%	mg Pt-Co/L
25-Sep-25	2479743	TBU002	Bulwer Final	Conductivity	7.08	±1.5%	mS/m
25-Sep-25	2479741	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
25-Sep-25	2479741	TBU002	Bulwer Final	HPC 37*	12	±21%	cfu/mL
25-Sep-25	2479744	TBU002	Bulwer Final	Odour*	Nil	-	-
25-Sep-25	2479740	TBU002	Bulwer Final	pH OS*	7.40	-	-
25-Sep-25	2479740	TBU002	Bulwer Final	Temperature OS*	13.5	-	°C
25-Sep-25	2479744	TBU002	Bulwer Final	Turbidity	5.8	±6.1%	NTU
25-Sep-25	2479745	TBU005	Bulwer Mountain Park Hotel Retic	Batch No.*	20250401	-	-
25-Sep-25	2479745	TBU005	Bulwer Mountain Park Hotel Retic	Cl ₂ (F) OS*	0.40	-	mg Cl ₂ /L
25-Sep-25	2479745	TBU005	Bulwer Mountain Park Hotel Retic	Cl ₂ (T) OS*	0.48	-	mg Cl ₂ /L
25-Sep-25	2479746	TBU005	Bulwer Mountain Park Hotel Retic	Coliforms*	0	±15%	MPN/100mL
25-Sep-25	2479745	TBU005	Bulwer Mountain Park Hotel Retic	Coll Time OS*	09:20	-	-
25-Sep-25	2479746	TBU005	Bulwer Mountain Park Hotel Retic	E.coli*	0	±14%	MPN/100mL
25-Sep-25	2479746	TBU005	Bulwer Mountain Park Hotel Retic	HPC 37*	0	±21%	cfu/mL
25-Sep-25	2479745	TBU005	Bulwer Mountain Park Hotel Retic	pH OS*	7.20	-	-
25-Sep-25	2479745	TBU005	Bulwer Mountain Park Hotel Retic	Temperature OS*	11.2	-	°C
25-Sep-25	2479748	TBU005	Bulwer Mountain Park Hotel Retic	Turbidity	4.8	±6.1%	NTU
25-Sep-25	2479759	TCR002	Creighton Final	Al (AE)	277	±7.6%	µg Al/L
25-Sep-25	2479754	TCR002	Creighton Final	Batch No.*	20250401	-	-
25-Sep-25	2479754	TCR002	Creighton Final	Cl ₂ (F) OS*	1.47	-	mg Cl ₂ /L
25-Sep-25	2479754	TCR002	Creighton Final	Cl ₂ (T) OS*	1.54	-	mg Cl ₂ /L
25-Sep-25	2479755	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
25-Sep-25	2479754	TCR002	Creighton Final	Coll Time OS*	06:50	-	-
25-Sep-25	2479757	TCR002	Creighton Final	Conductivity	10.6	±1.5%	mS/m
25-Sep-25	2479755	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
25-Sep-25	2479755	TCR002	Creighton Final	HPC 37*	0	±21%	cfu/mL
25-Sep-25	2479754	TCR002	Creighton Final	pH OS*	7.30	-	-
25-Sep-25	2479754	TCR002	Creighton Final	Temperature OS*	10.7	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

25-Sep-25	2479758	TCR002	Creighton Final	Turbidity	0.3	±6.1%	NTU
25-Sep-25	2479760	TCR004	Creighton Madondo Cottages	Batch No.*	2025401	-	-
25-Sep-25	2479760	TCR004	Creighton Madondo Cottages	Cl2 (F) OS*	0.71	-	mg Cl2/L
25-Sep-25	2479760	TCR004	Creighton Madondo Cottages	Cl2 (T) OS*	0.89	-	mg Cl2/L
25-Sep-25	2479761	TCR004	Creighton Madondo Cottages	Coliforms*	0	±15%	MPN/100mL
25-Sep-25	2479760	TCR004	Creighton Madondo Cottages	Coll Time OS*	06:30	-	-
25-Sep-25	2479764	TCR004	Creighton Madondo Cottages	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Sep-25	2479763	TCR004	Creighton Madondo Cottages	Conductivity	10.7	±1.5%	mS/m
25-Sep-25	2479761	TCR004	Creighton Madondo Cottages	E.coli*	0	±14%	MPN/100mL
25-Sep-25	2479761	TCR004	Creighton Madondo Cottages	HPC 37*	0	±21%	cfu/mL
25-Sep-25	2479760	TCR004	Creighton Madondo Cottages	pH OS*	7.20	-	-
25-Sep-25	2479760	TCR004	Creighton Madondo Cottages	Temperature OS*	10.1	-	°C
25-Sep-25	2479764	TCR004	Creighton Madondo Cottages	Turbidity	0.4	±6.1%	NTU
25-Sep-25	2479795	THL002	Hlanganani Final	Batch No.*	20250401	-	-
25-Sep-25	2479795	THL002	Hlanganani Final	Cl2 (F) OS*	0.50	-	mg Cl2/L
25-Sep-25	2479795	THL002	Hlanganani Final	Cl2 (T) OS*	0.60	-	mg Cl2/L
25-Sep-25	2479796	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
25-Sep-25	2479795	THL002	Hlanganani Final	Coll Time OS*	09:45	-	-
25-Sep-25	2479799	THL002	Hlanganani Final	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Sep-25	2479798	THL002	Hlanganani Final	Conductivity	11.7	±1.5%	mS/m
25-Sep-25	2479796	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
25-Sep-25	2479796	THL002	Hlanganani Final	HPC 37*	0	±21%	cfu/mL
25-Sep-25	2479799	THL002	Hlanganani Final	Odour*	Nil	-	-
25-Sep-25	2479795	THL002	Hlanganani Final	pH OS*	7.30	-	-
25-Sep-25	2479799	THL002	Hlanganani Final	Taste*	Nil	-	-
25-Sep-25	2479795	THL002	Hlanganani Final	Temperature OS*	12.5	-	°C
25-Sep-25	2479799	THL002	Hlanganani Final	Turbidity	<0.2	±6.1%	NTU
25-Sep-25	2479800	THL003	Hlanganani Clinic Reticulation	Batch No.*	20250401	-	-
25-Sep-25	2479800	THL003	Hlanganani Clinic Reticulation	Cl2 (F) OS*	0.34	-	mg Cl2/L
25-Sep-25	2479800	THL003	Hlanganani Clinic Reticulation	Cl2 (T) OS*	0.39	-	mg Cl2/L
25-Sep-25	2479801	THL003	Hlanganani Clinic Reticulation	Coliforms*	0	±15%	MPN/100mL
25-Sep-25	2479800	THL003	Hlanganani Clinic Reticulation	Coll Time OS*	09:58	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

25-Sep-25	2479801	THL003	Hlanganani Clinic Reticulation	E.coli*	0	±14%	MPN/100mL
25-Sep-25	2479801	THL003	Hlanganani Clinic Reticulation	HPC 37*	0	±21%	cfu/mL
25-Sep-25	2479800	THL003	Hlanganani Clinic Reticulation	pH OS*	7.20	-	-
25-Sep-25	2479800	THL003	Hlanganani Clinic Reticulation	Temperature OS*	11.6	-	°C
25-Sep-25	2479803	THL003	Hlanganani Clinic Reticulation	Turbidity	<0.2	±6.1%	NTU
25-Sep-25	2479903	TRV002	Riverside Final	Batch No.*	20250401	-	-
25-Sep-25	2479903	TRV002	Riverside Final	Cl2 (F) OS*	1.88	-	mg Cl2/L
25-Sep-25	2479903	TRV002	Riverside Final	Cl2 (T) OS*	1.99	-	mg Cl2/L
25-Sep-25	2479904	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
25-Sep-25	2479903	TRV002	Riverside Final	Coll Time OS*	07:48	-	-
25-Sep-25	2479907	TRV002	Riverside Final	Colour	3.70	±6.5%	mg Pt-Co/L
25-Sep-25	2479906	TRV002	Riverside Final	Conductivity	12.6	±1.5%	mS/m
25-Sep-25	2479904	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
25-Sep-25	2479904	TRV002	Riverside Final	HPC 37*	0	±21%	cfu/mL
25-Sep-25	2479907	TRV002	Riverside Final	Odour*	Mild Chlorinous	-	-
25-Sep-25	2479903	TRV002	Riverside Final	pH OS*	7.30	-	-
25-Sep-25	2479903	TRV002	Riverside Final	Temperature OS*	12.4	-	°C
25-Sep-25	2479907	TRV002	Riverside Final	Turbidity	1.5	±6.1%	NTU
25-Sep-25	2479908	TRV003	Riverside Reticulation	Batch No.*	20250401	-	-
25-Sep-25	2479908	TRV003	Riverside Reticulation	Cl2 (F) OS*	0.62	-	mg Cl2/L
25-Sep-25	2479908	TRV003	Riverside Reticulation	Cl2 (T) OS*	0.68	-	mg Cl2/L
25-Sep-25	2479909	TRV003	Riverside Reticulation	Coliforms*	0	±15%	MPN/100mL
25-Sep-25	2479908	TRV003	Riverside Reticulation	Coll Time OS*	07:40	-	-
25-Sep-25	2479911	TRV003	Riverside Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Sep-25	2479909	TRV003	Riverside Reticulation	E.coli*	0	±14%	MPN/100mL
25-Sep-25	2479909	TRV003	Riverside Reticulation	HPC 37*	0	±21%	cfu/mL
25-Sep-25	2479911	TRV003	Riverside Reticulation	Odour*	Mild Chlorinous	-	-
25-Sep-25	2479908	TRV003	Riverside Reticulation	pH OS*	7.20	-	-
25-Sep-25	2479908	TRV003	Riverside Reticulation	Temperature OS*	12.0	-	°C
25-Sep-25	2479911	TRV003	Riverside Reticulation	Turbidity	1.2	±6.1%	NTU
25-Sep-25	2479917	TST002	St Appollinaris Final	Batch No.*	20250401	-	-
25-Sep-25	2479917	TST002	St Appollinaris Final	Cl2 (F) OS*	1.03	-	mg Cl2/L
25-Sep-25	2479917	TST002	St Appollinaris Final	Cl2 (T) OS*	1.09	-	mg Cl2/L
25-Sep-25	2479918	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

25-Sep-25	2479917	TST002	St Appollinaris Final	Coll Time OS*	08:14	-	-
25-Sep-25	2479921	TST002	St Appollinaris Final	Colour	1.30	±6.5%	mg Pt-Co/L
25-Sep-25	2479920	TST002	St Appollinaris Final	Conductivity	11.2	±1.5%	mS/m
25-Sep-25	2479918	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
25-Sep-25	2479918	TST002	St Appollinaris Final	HPC 37*	5	±21%	cfu/mL
25-Sep-25	2479921	TST002	St Appollinaris Final	Odour*	Nil	-	-
25-Sep-25	2479917	TST002	St Appollinaris Final	pH OS*	7.20	-	-
25-Sep-25	2479917	TST002	St Appollinaris Final	Temperature OS*	11.1	-	°C
25-Sep-25	2479921	TST002	St Appollinaris Final	Turbidity	4.2	±6.1%	NTU
25-Sep-25	2479932	TUN002	Underberg Final	Al (AE)	31.6	±7.6%	µg Al/L
25-Sep-25	2479927	TUN002	Underberg Final	Batch No.*	20250401	-	-
25-Sep-25	2479927	TUN002	Underberg Final	Cl2 (F) OS*	0.72	-	mg Cl2/L
25-Sep-25	2479927	TUN002	Underberg Final	Cl2 (T) OS*	0.80	-	mg Cl2/L
25-Sep-25	2479928	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
25-Sep-25	2479927	TUN002	Underberg Final	Coll Time OS*	07:30	-	-
25-Sep-25	2479931	TUN002	Underberg Final	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Sep-25	2479930	TUN002	Underberg Final	Conductivity	8.66	±1.5%	mS/m
25-Sep-25	2479928	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
25-Sep-25	2479928	TUN002	Underberg Final	HPC 37*	2	±21%	cfu/mL
25-Sep-25	2479931	TUN002	Underberg Final	Odour*	Nil	-	-
25-Sep-25	2479927	TUN002	Underberg Final	pH OS*	7.60	-	-
25-Sep-25	2479931	TUN002	Underberg Final	Taste*	Nil	-	-
25-Sep-25	2479927	TUN002	Underberg Final	Temperature OS*	18.8	-	°C
25-Sep-25	2479931	TUN002	Underberg Final	Turbidity	0.6	±6.1%	NTU
26-Sep-25	2481542	TIB002	Ibisi Final	Al (AE)	157	±7.6%	µg Al/L
26-Sep-25	2481537	TIB002	Ibisi Final	Batch No.*	20250401	-	-
26-Sep-25	2481537	TIB002	Ibisi Final	Cl2 (F) OS*	0.57	-	mg Cl2/L
26-Sep-25	2481537	TIB002	Ibisi Final	Cl2 (T) OS*	0.65	-	mg Cl2/L
26-Sep-25	2481538	TIB002	Ibisi Final	Coliforms*	5	±15%	MPN/100mL
26-Sep-25	2481538	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
26-Sep-25	2481537	TIB002	Ibisi Final	Coll Time OS*	07:00	-	-
26-Sep-25	2481541	TIB002	Ibisi Final	Colour	1.30	±6.5%	mg Pt-Co/L
26-Sep-25	2481540	TIB002	Ibisi Final	Conductivity	12.7	±1.5%	mS/m
26-Sep-25	2481538	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
26-Sep-25	2481538	TIB002	Ibisi Final	HPC 37*	25	±21%	cfu/mL
26-Sep-25	2481541	TIB002	Ibisi Final	Odour*	Nil	-	-
26-Sep-25	2481537	TIB002	Ibisi Final	pH OS*	7.30	-	-
26-Sep-25	2481537	TIB002	Ibisi Final	Temperature OS*	18.6	-	°C
26-Sep-25	2481541	TIB002	Ibisi Final	Turbidity	10.0	±6.1%	NTU
26-Sep-25	2481543	TIB003	Ibisi Police Station Reticulation	Batch No.*	20250401	-	-
26-Sep-25	2481543	TIB003	Ibisi Police Station Reticulation	Cl2 (F) OS*	0.40	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

26-Sep-25	2481543	TIB003	Ibisi Police Station Reticulation	Cl ₂ (T) OS*	0.50	-	mg Cl ₂ /L
26-Sep-25	2481544	TIB003	Ibisi Police Station Reticulation	Coliforms*	0	±15%	MPN/100mL
26-Sep-25	2481543	TIB003	Ibisi Police Station Reticulation	Coll Time OS*	07:15	-	-
26-Sep-25	2481547	TIB003	Ibisi Police Station Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Sep-25	2481546	TIB003	Ibisi Police Station Reticulation	Conductivity	12.9	±1.5%	mS/m
26-Sep-25	2481544	TIB003	Ibisi Police Station Reticulation	E.coli*	0	±14%	MPN/100mL
26-Sep-25	2481544	TIB003	Ibisi Police Station Reticulation	HPC 37*	0	±21%	cfu/mL
26-Sep-25	2481543	TIB003	Ibisi Police Station Reticulation	pH OS*	7.40	-	-
26-Sep-25	2481543	TIB003	Ibisi Police Station Reticulation	Temperature OS*	19.2	-	°C
26-Sep-25	2481547	TIB003	Ibisi Police Station Reticulation	Turbidity	9.5	±6.1%	NTU
26-Sep-25	2481059	TMZ002	Umzimkhulu Final	Al (AE)	190	±7.6%	µg Al/L
26-Sep-25	2481054	TMZ002	Umzimkhulu Final	Batch No.*	20250401	-	-
26-Sep-25	2481054	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	2.60	-	mg Cl ₂ /L
26-Sep-25	2481054	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	2.70	-	mg Cl ₂ /L
26-Sep-25	2481055	TMZ002	Umzimkhulu Final	Coliforms*	1	±15%	MPN/100mL
26-Sep-25	2481055	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
26-Sep-25	2481054	TMZ002	Umzimkhulu Final	Coll Time OS*	07:41	-	-
26-Sep-25	2481057	TMZ002	Umzimkhulu Final	Conductivity	16.1	±1.5%	mS/m
26-Sep-25	2481055	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
26-Sep-25	2481055	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	cfu/mL
26-Sep-25	2481054	TMZ002	Umzimkhulu Final	pH OS*	7.30	-	-
26-Sep-25	2481054	TMZ002	Umzimkhulu Final	Temperature OS*	16.8	-	°C
26-Sep-25	2481058	TMZ002	Umzimkhulu Final	Turbidity	1.6	±6.1%	NTU
26-Sep-25	2481060	TMZ004	Umzikhulu Informal Settlement Retic	Batch No.*	20250401	-	-
26-Sep-25	2481060	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (F) OS*	0.92	-	mg Cl ₂ /L
26-Sep-25	2481060	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (T) OS*	1.11	-	mg Cl ₂ /L
26-Sep-25	2481061	TMZ004	Umzikhulu Informal Settlement Retic	Coliforms*	0	±15%	MPN/100mL
26-Sep-25	2481060	TMZ004	Umzikhulu Informal Settlement Retic	Coll Time OS*	08:58	-	-
26-Sep-25	2481064	TMZ004	Umzikhulu Informal Settlement Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Sep-25	2481063	TMZ004	Umzikhulu Informal Settlement Retic	Conductivity	16.0	±1.5%	mS/m
26-Sep-25	2481061	TMZ004	Umzikhulu Informal Settlement Retic	E.coli*	0	±14%	MPN/100mL
26-Sep-25	2481061	TMZ004	Umzikhulu Informal Settlement Retic	HPC 37*	0	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

26-Sep-25	2481064	TMZ004	Umzikhulu Informal Settlement Retic	Odour*	Mild Chlorinous	-	-
26-Sep-25	2481060	TMZ004	Umzikhulu Informal Settlement Retic	pH OS*	7.20	-	-
26-Sep-25	2481060	TMZ004	Umzikhulu Informal Settlement Retic	Temperature OS*	19.2	-	°C
26-Sep-25	2481064	TMZ004	Umzikhulu Informal Settlement Retic	Turbidity	1.5	±6.1%	NTU
26-Sep-25	2481065	TMZ005	Umzimkhulu Local Municipality Offices	Batch No.*	20250401	-	-
26-Sep-25	2481065	TMZ005	Umzimkhulu Local Municipality Offices	Cl2 (F) OS*	2.80	-	mg Cl2/L
26-Sep-25	2481065	TMZ005	Umzimkhulu Local Municipality Offices	Cl2 (T) OS*	2.90	-	mg Cl2/L
26-Sep-25	2481066	TMZ005	Umzimkhulu Local Municipality Offices	Coliforms*	0	±15%	MPN/100mL
26-Sep-25	2481065	TMZ005	Umzimkhulu Local Municipality Offices	Coll Time OS*	09:10	-	-
26-Sep-25	2481069	TMZ005	Umzimkhulu Local Municipality Offices	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Sep-25	2481068	TMZ005	Umzimkhulu Local Municipality Offices	Conductivity	16.2	±1.5%	mS/m
26-Sep-25	2481066	TMZ005	Umzimkhulu Local Municipality Offices	E.coli*	0	±14%	MPN/100mL
26-Sep-25	2481066	TMZ005	Umzimkhulu Local Municipality Offices	HPC 37*	0	±21%	cfu/mL
26-Sep-25	2481065	TMZ005	Umzimkhulu Local Municipality Offices	pH OS*	7.40	-	-
26-Sep-25	2481065	TMZ005	Umzimkhulu Local Municipality Offices	Temperature OS*	19.5	-	°C
26-Sep-25	2481069	TMZ005	Umzimkhulu Local Municipality Offices	Turbidity	2.0	±6.1%	NTU
26-Sep-25	2481070	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Batch No.*	20250401	-	-
26-Sep-25	2481070	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl2 (F) OS*	0.16	-	mg Cl2/L
26-Sep-25	2481070	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl2 (T) OS*	0.24	-	mg Cl2/L
26-Sep-25	2481071	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
26-Sep-25	2481070	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coll Time OS*	08:27	-	-
26-Sep-25	2481071	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
26-Sep-25	2481071	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
26-Sep-25	2481070	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	pH OS*	7.20	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

26-Sep-25	2481070	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Temperature OS*	15.4	-	°C
26-Sep-25	2481073	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Turbidity	0.6	±6.1%	NTU
26-Sep-25	2481074	TMZ007	Umzimkhulu Local FET College	Batch No.*	20250401	-	-
26-Sep-25	2481074	TMZ007	Umzimkhulu Local FET College	Cl2 (F) OS*	1.34	-	mg Cl2/L
26-Sep-25	2481074	TMZ007	Umzimkhulu Local FET College	Cl2 (T) OS*	1.42	-	mg Cl2/L
26-Sep-25	2481075	TMZ007	Umzimkhulu Local FET College	Coliforms*	74	±15%	MPN/100mL
26-Sep-25	2481074	TMZ007	Umzimkhulu Local FET College	Coll Time OS*	08:15	-	-
26-Sep-25	2481075	TMZ007	Umzimkhulu Local FET College	E.coli*	1	±14%	MPN/100mL
26-Sep-25	2481075	TMZ007	Umzimkhulu Local FET College	HPC 37*	18	±21%	cfu/mL
26-Sep-25	2481074	TMZ007	Umzimkhulu Local FET College	pH OS*	7.30	-	-
26-Sep-25	2481074	TMZ007	Umzimkhulu Local FET College	Temperature OS*	16.4	-	°C
26-Sep-25	2481077	TMZ007	Umzimkhulu Local FET College	Turbidity	2.1	±6.1%	NTU
26-Sep-25	2481088	TNO002	Nokweja Final	Al (AE)	200	±7.6%	µg Al/L
26-Sep-25	2481083	TNO002	Nokweja Final	Batch No.*	20250401	-	-
26-Sep-25	2481083	TNO002	Nokweja Final	Cl2 (F) OS*	1.28	-	mg Cl2/L
26-Sep-25	2481083	TNO002	Nokweja Final	Cl2 (T) OS*	1.39	-	mg Cl2/L
26-Sep-25	2481084	TNO002	Nokweja Final	Coliforms*	3	±15%	MPN/100mL
26-Sep-25	2481084	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
26-Sep-25	2481083	TNO002	Nokweja Final	Coll Time OS*	06:30	-	-
26-Sep-25	2481087	TNO002	Nokweja Final	Colour	1.80	±6.5%	mg Pt-Co/L
26-Sep-25	2481086	TNO002	Nokweja Final	Conductivity	16.1	±1.5%	mS/m
26-Sep-25	2481084	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
26-Sep-25	2481084	TNO002	Nokweja Final	HPC 37*	49	±21%	cfu/mL
26-Sep-25	2481087	TNO002	Nokweja Final	Odour*	Nil	-	-
26-Sep-25	2481083	TNO002	Nokweja Final	pH OS*	7.20	-	-
26-Sep-25	2481083	TNO002	Nokweja Final	Temperature OS*	15.4	-	°C
26-Sep-25	2481087	TNO002	Nokweja Final	Turbidity	2.9	±6.1%	NTU
26-Sep-25	2481552	TRT002	Rietvlei Final	Batch No.*	20250401	-	-
26-Sep-25	2481552	TRT002	Rietvlei Final	Cl2 (F) OS*	0.83	-	mg Cl2/L
26-Sep-25	2481552	TRT002	Rietvlei Final	Cl2 (T) OS*	0.90	-	mg Cl2/L
26-Sep-25	2481553	TRT002	Rietvlei Final	Coliforms*	0	±15%	MPN/100mL
26-Sep-25	2481552	TRT002	Rietvlei Final	Coll Time OS*	05:57	-	-
26-Sep-25	2481555	TRT002	Rietvlei Final	Conductivity	20.1	±1.5%	mS/m
26-Sep-25	2481553	TRT002	Rietvlei Final	E.coli*	0	±14%	MPN/100mL
26-Sep-25	2481553	TRT002	Rietvlei Final	HPC 37*	0	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

26-Sep-25	2481552	TRT002	Rietvlei Final	pH OS*	7.30	-	-
26-Sep-25	2481552	TRT002	Rietvlei Final	Temperature OS*	13.1	-	°C
26-Sep-25	2481556	TRT002	Rietvlei Final	Turbidity	2.6	±6.1%	NTU
26-Sep-25	2481557	TRT004	Rietvlei Hospital Reticulation	Batch No.*	20250401	-	-
26-Sep-25	2481557	TRT004	Rietvlei Hospital Reticulation	Cl2 (F) OS*	0.46	-	mg Cl2/L
26-Sep-25	2481557	TRT004	Rietvlei Hospital Reticulation	Cl2 (T) OS*	0.60	-	mg Cl2/L
26-Sep-25	2481558	TRT004	Rietvlei Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
26-Sep-25	2481557	TRT004	Rietvlei Hospital Reticulation	Coll Time OS*	06:06	-	-
26-Sep-25	2481561	TRT004	Rietvlei Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Sep-25	2481560	TRT004	Rietvlei Hospital Reticulation	Conductivity	20.0	±1.5%	mS/m
26-Sep-25	2481558	TRT004	Rietvlei Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
26-Sep-25	2481558	TRT004	Rietvlei Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
26-Sep-25	2481557	TRT004	Rietvlei Hospital Reticulation	pH OS*	7.40	-	-
26-Sep-25	2481557	TRT004	Rietvlei Hospital Reticulation	Temperature OS*	11.7	-	°C
26-Sep-25	2481561	TRT004	Rietvlei Hospital Reticulation	Turbidity	1.9	±6.1%	NTU
26-Sep-25	2481133	TWA002	Washbank Final	Al (AE)	208	±7.6%	µg Al/L
26-Sep-25	2481128	TWA002	Washbank Final	Batch No.*	20250401	-	-
26-Sep-25	2481128	TWA002	Washbank Final	Cl2 (F) OS*	0.46	-	mg Cl2/L
26-Sep-25	2481128	TWA002	Washbank Final	Cl2 (T) OS*	0.53	-	mg Cl2/L
26-Sep-25	2481129	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
26-Sep-25	2481128	TWA002	Washbank Final	Coll Time OS*	06:55	-	-
26-Sep-25	2481132	TWA002	Washbank Final	Colour	3.80	±6.5%	mg Pt-Co/L
26-Sep-25	2481131	TWA002	Washbank Final	Conductivity	9.03	±1.5%	mS/m
26-Sep-25	2481129	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
26-Sep-25	2481129	TWA002	Washbank Final	HPC 37*	2	±21%	cfu/mL
26-Sep-25	2481132	TWA002	Washbank Final	Odour*	Strong Chlorinous	-	-
26-Sep-25	2481128	TWA002	Washbank Final	pH OS*	7.40	-	-
26-Sep-25	2481128	TWA002	Washbank Final	Temperature OS*	13.6	-	°C
26-Sep-25	2481132	TWA002	Washbank Final	Turbidity	3.9	±6.1%	NTU
29-Sep-25	2483710	TFR002	Franklin Final	Al (AE)	162	±7.6%	µg Al/L
29-Sep-25	2483705	TFR002	Franklin Final	Batch No.*	210250401	-	-
29-Sep-25	2483705	TFR002	Franklin Final	Cl2 (F) OS*	1.12	-	mg Cl2/L
29-Sep-25	2483705	TFR002	Franklin Final	Cl2 (T) OS*	1.26	-	mg Cl2/L
29-Sep-25	2483706	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
29-Sep-25	2483706	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

29-Sep-25	2483705	TFR002	Franklin Final	Coll Time OS*	08:06	-	-
29-Sep-25	2483708	TFR002	Franklin Final	Conductivity	14.4	±1.5%	mS/m
29-Sep-25	2483706	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
29-Sep-25	2483706	TFR002	Franklin Final	HPC 37*	0	±21%	cfu/mL
29-Sep-25	2483705	TFR002	Franklin Final	pH OS*	7.30	-	-
29-Sep-25	2483705	TFR002	Franklin Final	Temperature OS*	16.3	-	°C
29-Sep-25	2483709	TFR002	Franklin Final	Turbidity	1.2	±6.1%	NTU
29-Sep-25	2483721	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
29-Sep-25	2483716	TKK002	Kokstad Final	Batch No.*	20250401	-	-
29-Sep-25	2483716	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.23	-	mg Cl ₂ /L
29-Sep-25	2483716	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.30	-	mg Cl ₂ /L
29-Sep-25	2483717	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
29-Sep-25	2483717	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
29-Sep-25	2483716	TKK002	Kokstad Final	Coll Time OS*	09:01	-	-
29-Sep-25	2483719	TKK002	Kokstad Final	Conductivity	17.1	±1.5%	mS/m
29-Sep-25	2483717	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
29-Sep-25	2483717	TKK002	Kokstad Final	HPC 37*	1	±21%	cfu/mL
29-Sep-25	2483716	TKK002	Kokstad Final	pH OS*	7.30	-	-
29-Sep-25	2483716	TKK002	Kokstad Final	Temperature OS*	11.6	-	°C
29-Sep-25	2483720	TKK002	Kokstad Final	Turbidity	<0.2	±6.1%	NTU
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Al (AE)	<25.0	±7.6%	µg Al/L
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	As (AE)*	<5.00	±7.5%	µg As/L
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	B (AE)	<25.0	±6.6%	µg B/L
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Ba (AE)	23.1	±6.9%	µg Ba/L
29-Sep-25	2483727	TKK011	Kokstad Hospital Reticulation	Batch No.*	20250401	-	-
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Cd (AE)	<1.00	±6%	µg Cd/L
29-Sep-25	2483736	TKK011	Kokstad Hospital Reticulation	CHBr ₃	<10	±6.4%	µg/L
29-Sep-25	2483736	TKK011	Kokstad Hospital Reticulation	CHCl ₂ Br	<10	±5.7%	µg/L
29-Sep-25	2483736	TKK011	Kokstad Hospital Reticulation	CHCl ₃	18.6	±6%	µg/L
29-Sep-25	2483736	TKK011	Kokstad Hospital Reticulation	CHClBr ₂	<10	±5.3%	µg/L
29-Sep-25	2483733	TKK011	Kokstad Hospital Reticulation	Cl*	9.13	±1.8%	mg Cl/L
29-Sep-25	2483727	TKK011	Kokstad Hospital Reticulation	Cl ₂ (F) OS*	0.99	-	mg Cl ₂ /L
29-Sep-25	2483727	TKK011	Kokstad Hospital Reticulation	Cl ₂ (T) OS*	1.13	-	mg Cl ₂ /L
29-Sep-25	2483731	TKK011	Kokstad Hospital Reticulation	CN (T)	<25.0	±8.6%	µg CN/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,

Telephone (033) 341 1111

E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

29-Sep-25	2483728	TKK011	Kokstad Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
29-Sep-25	2483728	TKK011	Kokstad Hospital Reticulation	Coliphages*	0	±8%	PFU/10ml
29-Sep-25	2483727	TKK011	Kokstad Hospital Reticulation	Coll Time OS*	08:50	-	-
29-Sep-25	2483733	TKK011	Kokstad Hospital Reticulation	Combined NO3 + NO2 ratio*	<0.12	-	-
29-Sep-25	2483736	TKK011	Kokstad Hospital Reticulation	Combined THM Ratio*	0.43	-	-
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Cr (T)*	<5.00	±5.3%	µg Cr/L
29-Sep-25	2483728	TKK011	Kokstad Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
29-Sep-25	2483733	TKK011	Kokstad Hospital Reticulation	F	128	±5.3%	µg F/L
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Fe (AE)	<0.02	±5.4%	mg Fe/L
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Hg (AE)*	<1.00	±6.5%	µg Hg/L
29-Sep-25	2483728	TKK011	Kokstad Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Mn (AE)	<0.01	±6.2%	mg Mn/L
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Na (AE)	9.66	±7.5%	mg Na/L
29-Sep-25	2483733	TKK011	Kokstad Hospital Reticulation	NH3*	0.13	±5.5%	mg N/L
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Ni (AE)	<10.0	±5.9%	µg Ni/L
29-Sep-25	2483733	TKK011	Kokstad Hospital Reticulation	NO2*	<0.10	±2.4%	mg N/L
29-Sep-25	2483733	TKK011	Kokstad Hospital Reticulation	NO3*	<0.10	±2.9%	mg N/L
29-Sep-25	2483734	TKK011	Kokstad Hospital Reticulation	Odour*	Nil	-	-
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Pb (AE)	<4.00	±6.7%	µg Pb/L
29-Sep-25	2483727	TKK011	Kokstad Hospital Reticulation	pH OS*	7.30	-	-
29-Sep-25	2483732	TKK011	Kokstad Hospital Reticulation	Phenols*	<10.0	-	µg/L
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Sb (AE)*	<5.00	±7%	µg Sb/L
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Se (AE)*	<5.00	±7.7%	µg Se/L
29-Sep-25	2483733	TKK011	Kokstad Hospital Reticulation	SO4*	1.08	±1.8%	mg SO4/L
29-Sep-25	2483734	TKK011	Kokstad Hospital Reticulation	SS	<10.0	±3.7%	mg /L
29-Sep-25	2483734	TKK011	Kokstad Hospital Reticulation	Taste*	Nil	-	-
29-Sep-25	2483734	TKK011	Kokstad Hospital Reticulation	TDS	89.00	±2.5%	mg /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

29-Sep-25	2483727	TKK011	Kokstad Hospital Reticulation	Temperature OS*	12.2	-	°C
29-Sep-25	2483734	TKK011	Kokstad Hospital Reticulation	TOC	2.25	±5%	mg C/L
29-Sep-25	2483734	TKK011	Kokstad Hospital Reticulation	Turbidity	0.2	±6.1%	NTU
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	U (AE)*	<10.0	±7.6%	µg U/L
29-Sep-25	2483735	TKK011	Kokstad Hospital Reticulation	Zn (AE)	<0.03	±7.2%	mg Zn/L
29-Sep-25	2483759	TNJU002	KwaNjunga Final	Batch No.*	20250401	-	-
29-Sep-25	2483759	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	0.57	-	mg Cl ₂ /L
29-Sep-25	2483759	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	0.66	-	mg Cl ₂ /L
29-Sep-25	2483760	TNJU002	KwaNjunga Final	Coliforms*	2	±15%	MPN/100mL
29-Sep-25	2483759	TNJU002	KwaNjunga Final	Coll Time OS*	07:30	-	-
29-Sep-25	2483762	TNJU002	KwaNjunga Final	Conductivity	21.0	±1.5%	mS/m
29-Sep-25	2483760	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
29-Sep-25	2483760	TNJU002	KwaNjunga Final	HPC 37*	1	±21%	cfu/mL
29-Sep-25	2483759	TNJU002	KwaNjunga Final	pH OS*	7.40	-	-
29-Sep-25	2483759	TNJU002	KwaNjunga Final	Temperature OS*	16.9	-	°C
29-Sep-25	2483763	TNJU002	KwaNjunga Final	Turbidity	0.3	±6.1%	NTU
30-Sep-25	2484171	TJO001	Jolivet RRT frn Vulamehlo	Batch No.*	20250401	-	-
30-Sep-25	2484171	TJO001	Jolivet RRT frn Vulamehlo	Cl ₂ (F) OS*	<0.05	-	mg Cl ₂ /L
30-Sep-25	2484171	TJO001	Jolivet RRT frn Vulamehlo	Cl ₂ (T) OS*	<0.05	-	mg Cl ₂ /L
30-Sep-25	2484172	TJO001	Jolivet RRT frn Vulamehlo	Coliforms*	16	±15%	MPN/100mL
30-Sep-25	2484171	TJO001	Jolivet RRT frn Vulamehlo	Coll Time OS*	08:33	-	-
30-Sep-25	2484172	TJO001	Jolivet RRT frn Vulamehlo	E.coli*	1	±14%	MPN/100mL
30-Sep-25	2484172	TJO001	Jolivet RRT frn Vulamehlo	HPC 37*	145	±21%	cfu/mL
30-Sep-25	2484171	TJO001	Jolivet RRT frn Vulamehlo	pH OS*	8.04	-	-
30-Sep-25	2484171	TJO001	Jolivet RRT frn Vulamehlo	Temperature OS*	18.2	-	°C
30-Sep-25	2484174	TJO001	Jolivet RRT frn Vulamehlo	Turbidity	2.5	±6.1%	NTU
30-Sep-25	2484218	TQU002	Mnqumeni Final	Batch No.*	20250401	-	-
30-Sep-25	2484218	TQU002	Mnqumeni Final	Cl ₂ (F) OS*	0.14	-	mg Cl ₂ /L
30-Sep-25	2484218	TQU002	Mnqumeni Final	Cl ₂ (T) OS*	0.18	-	mg Cl ₂ /L
30-Sep-25	2484219	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
30-Sep-25	2484218	TQU002	Mnqumeni Final	Coll Time OS*	08:11	-	-
30-Sep-25	2484221	TQU002	Mnqumeni Final	Conductivity	16.4	±1.5%	mS/m
30-Sep-25	2484219	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
30-Sep-25	2484219	TQU002	Mnqumeni Final	HPC 37*	0	±21%	cfu/mL
30-Sep-25	2484218	TQU002	Mnqumeni Final	pH OS*	7.40	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

30-Sep-25	2484218	TQU002	Mnqumeni Final	Temperature OS*	17.9	-	°C
30-Sep-25	2484222	TQU002	Mnqumeni Final	Turbidity	0.7	±6.1%	NTU
30-Sep-25	2484233	TSQ002	Esiqanduleni Final	Al (AE)	129	±7.6%	µg Al/L
30-Sep-25	2484228	TSQ002	Esiqanduleni Final	Batch No.*	20250401	-	-
30-Sep-25	2484228	TSQ002	Esiqanduleni Final	Cl ₂ (F) OS*	1.05	-	mg Cl ₂ /L
30-Sep-25	2484228	TSQ002	Esiqanduleni Final	Cl ₂ (T) OS*	0.99	-	mg Cl ₂ /L
30-Sep-25	2484229	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
30-Sep-25	2484228	TSQ002	Esiqanduleni Final	Coll Time OS*	07:17	-	-
30-Sep-25	2484231	TSQ002	Esiqanduleni Final	Conductivity	22.9	±1.5%	mS/m
30-Sep-25	2484229	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
30-Sep-25	2484229	TSQ002	Esiqanduleni Final	HPC 37*	10	±21%	cfu/mL
30-Sep-25	2484228	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
30-Sep-25	2484228	TSQ002	Esiqanduleni Final	Temperature OS*	16.5	-	°C
30-Sep-25	2484232	TSQ002	Esiqanduleni Final	Turbidity	1.2	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)